

**DELHI TRANSCO LTD.
STATE LOAD DESPATCH CENTER
(REGD. OFFICE : SHAKTI SADAN BUILDING, KOTLA ROAD, NEW DELHI-110002)**

Dy. G. M. (System Operation)
33kV Grid Sub-Station Building
Minto Road, New Delhi-110002
Ph. No.23221064, 23221175
Fax No. 23221012, 23221059

No. F.DTL/207/2013-14/DGM(SO)/

To

DATE 10.10.2013


1. Managing Director (IPGCL)
2. Managing Director (PPCL)
3. CEO TPDDL
4. G.M.(GT)
5. G.M.(PPCL)

Sub. : Open Cycle Certification for GT , PPCL , BAWANA & RITHALA for APR'13, MAY'13 & JUNE'13

Sir,

Please find herewith with the Statement of Open Cycle Certification of GT , PPCL, BAWANA & RITHALA for the period APR'13 to JUNE'13 for further necessary action please.

. Yours faithfully



Dy. G. M. (System Operation)

Encl : As above

Copy for favour of kind information to:
Secretary, DERC
Director (Operations), DTL
General Manager (SLDC)
Chair Person (DPPG)
CEO, BSES Rajdhani Power Ltd.
CEO, BSES Yamuna Power Ltd.
Dy. General Manager (SCADA)

DELHI TRANSCO LTD.

Certification of Open Cycle Generation of GTPS , PPCL , BAWANA & RITHALA generating stations

(All Fig. in Mus)

A) Gas Turbine

Month	Total General in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'13	125.603065	0.938603	0.789147	0.63
MAY'13	105.176329	0.472263	0.418743	0.40
JUNE'13	97.128390	0.492146	0.425637	0.44

B) PPCL



Month	Total General in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'13	195.757297	1.183756	1.127403	0.58
MAY'13	208.007958	0.111095	0.090579	0.04
JUNE'13	170.021496	0.581086	0.546129	0.32

C) PRAGATI III,BAWANA

Month	Total General in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'13	16.7873979	2.490770	1.769486	10.54
MAY'13	170.201848	0.632754	0.449235	0.26
JUNE'13	90.6660377	1.404576	1.096451	1.21

D) Rithala

Month	Total General in Mus	Open Cycle Claimed in Mu	Open Cycle Certified in Mus	Certified %
APR'13	-0.139000	NIL	NIL	
MAY'13	-0.142000	NIL	NIL	
JUNE'13	0.066195	0.081600	0.039495	59.66



MANAGER(SO/EA)