

DELHI TRANSCO LTD.

STATE LOAD DISPATCH CENTER

PROGRESS REPORT

FEBRUARY 2014

S. No.	CONTENTS	Page No.
1.	Salient Features of Delhi Power System	3
2.	Performance of Generating Stations within Delhi	4
3.	Details of Outage of Generating Stations within Delhi	5-21
4.	Allocation of Power to Delhi from unallocated quota of central sector	22-27
5.	Allocation of Power to Discoms	28-29
6.	Power Availability Demand Position of Delhi at the time of occurrence of Peak Demand	30
7.	Power Availability Demand Position of Delhi at the time of occurrence of Maximum Un-Restricted Demand	31
8.	Source wise scheduled drawl from grid and Availability within Delhi	32-24
9.	Shedding Details	35-38
10.	Load Curve for the Day of Peak Demand	39
11.	Load Curve for the day of occurrence of Maximum Un-Restricted Demand	40
12.	Load Curve for the day of Maximum Energy Consumed	41
13.	Load Curve for the day of Maximum Un-Restricted Energy Demand	42
14.	Load Duration Curve	43
15.	Frequency Analysis	44
16.	Voltage Profile for significant 220kV Sub-Stations	45
17.	Voltage Profile for significant 400kV Sub-Stations	46-47
18.	Details of Capacitors Installations in Delhi	48-53
19.	Tripping Details of 400/220 KV System in Delhi Power System	54-55
20.	Details of Under frequency Relay operations in Delhi Power System	56

SALIENT FEATURES OF DELHI POWER SYSTEM

Sr. No.	Features	FEBRUARY 2013	FEBRUARY 2014
1	Effective Generation Capacity within Delhi in MW		
	Rajghat Power House	135	135
	Gas Turbine	270	270
	Pragati Power Corporation Ltd.	330	330
	Badapur Thermal Power Station	705	705
	Rithala GT	108	108
	Bawana	685	1118
	TOWMCL	16	16
	Total	2249	2682
2	Maximum Unrestricted Demand (MW)	3590	3670
	Date	01.02.2013	16.02.2014
	Time	09.59.52	10.36.32
3	Peak Demand met (MW)	3590	3670
	Date	01.02.2013	16.02.2014
	Time	09.59.52	10.36.32
4	Peak Availability (MW)	3514	3489
5	Shortage (-) / Surplus (+) in MW	(-) 76	(-) 181
6	Percentage Shortage (-) / Surplus (+)	(-) 2.12	(-) 4.93
7	Maximum Energy Consume in a day (Mus)	59.532	63.299
8	Energy Consumed during the month	1536.498	1705.084
9	Load Shedding in Mus		
A)	Due to Grid Restrictions		
i)	Under Frequency Relay Operations	0.000	0.000
ii)	Manual Load shedding from DTL S/Stns.	0.000	0.000
iii)	Load Shedding due to low frequency / Low Voltage / TTC/ATC Violation		
	NDPL	0.021	1.246
	BRPL	0.161	1.376
	BYPL	0.085	1.426
	NDMC	0.000	0.000
	MES	0.000	0.000
iv)	Due to transmission Constraints in Central Sector	0.000	0.437
	Total due to Grid Restriction	0.267	4.485
B)	Due to Constraints in System in Mus		
	DTL	0.363	0.164
	NDPL	0.312	1.189
	BRPL	0.458	0.122
	BYPL	0.280	0.233
	NDMC	0.000	0.004
	MES	0.000	0.000
	Other Agencies	0.019	0.015
	Total	1.432	1.727
11	Grand Total in Mus	1.699	6.212

2. PERFORMANCE OF GENERATING STATIONS WITHIN DELHI DURING FEBRUARY 2014

A) For the month of February 2014

All Figures in MUs

S. No	Stations	Gross Generation	Aux. Consumption	Net Generation	Availability (%)	Backing Down
1.	RPH	5.932	1.181	4.751	83.66	61.694
2.	GT	84.316	2.329	81.987	75.34	51.195
3.	PPCL	196.638	4.782	191.856	98.15	19.233
4.	BTPS	325.624	27.917	297.707	102.65	133.153
5.	Rithala	0.000	0.072	-0.072	62.37	38.540
6.	Bawana	9.161	2.258	6.903	107.13	629.60
7.	Towmcl	7.347	1.425	5.922	--	0
	TOTAL	629.018	39.964	589.054	--	933.415

B) For the Year 2013-14 (Upto February 2014)

Power Station	Effective Capacity (MW)	Net Generation in MUs for Feb 2014	Availability (%) for Feb 2014	PLF (%) for Feb 2014	Cumulative Generation in MUs upto Feb 2014 for the year 2013-14	Cumulative Availability in % upto Feb 2014 for the year 2013-14	Cumulative PLF in % upto Feb 2014 for the year 2013-14
RPH	135	4.751	83.66	5.99	305.782	65.57	32.42
GT	270	81.987	75.34	46.25	951.995	86.68	45.28
PPCL	330	191.856	98.15	89.21	2170.717	91.94	84.17
BTPS	705	297.707	102.65	71.07	3531.440	94.10	69.99
Rithala	108	-0.072	62.37	0.00	-1.060	83.54	0.04
Bawana	1118	6.903	107.13	0.00	619.151	93.68	9.13
Towmcl	16	5.922	--	68.33	82.467	--	--
TOTAL	2682	589.054	--	--	7660.492	--	--

3
(A)

**DETAILS OF OUTAGES OF GENERATING STNS. WITHIN DELHI W.E.F. APRIL 2012
RPH STATION**

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	67.5	03.04.13	18.35	03.04.13	19.45	Unit tripped due to drum level very low.
		04.04.13	08.55	04.04.13	09.45	Unit tripped due to drum level low.
		14.04.13	10.20	14.04.13	15.40	Unit desynchronised to attend the CW line leakage.
		19.04.13	08.25	19.04.13	16.40	Unit desynchronised to attend the Boiler window repairing.
		19.04.13	17.00	19.04.13	17.30	Unit tripped due to bay no. 20 tripped.
		03.05.13	20.00	05.05.13	03.30	Unit desynchronised to attend the Boiler tube leakage.
		05.05.13	11.40	05.05.13	13.40	Unit tripped due to drum level low.
		05.05.13	15.55	05.05.13	20.15	Dark out due to Reactor on bay no. 9 had been blasted.
		19.05.13	07.10	24.05.13	04.40	Unit desynchronised due to shortage of coal fuel and to attend the CW line leakage.
		25.05.13	01.50	25.05.13	03.20	Unit tripped due to Furnace pr. very high.
		01.06.13	12.40	01.06.13	13.55	Unit tripped due to drum level low.
		02.06.13	11.55	02.06.13	13.05	Unit tripped due to Furnace pr. very high.
		06.06.13	17.10	06.06.13	20.05	Dark out due to 22K 9F, unit tripped.
		16.06.13	18.35	19.06.13	13.50	Unit desynchronised as per system operation.
		21.06.13	22.50	24.06.13	14.50	Unit desynchronised to attend the Boiler tube leakage.
		02.07.13	12.55	02.07.13	14.25	Dark out due to grid disturbance.
		09.07.13	23.30	10.07.13	00.25	Unit tripped due to flame failure.
		10.07.13	00.40	10.07.13	03.40	Unit tripped due to ST-1 trip.
		10.07.13	04.10	10.07.13	04.35	Unit tripped due to furnace pressure high.
		10.07.13	04.40	15.07.13	12.05	Unit tripped due to furnace pressure high (suspected boiler tube leakage).
		16.07.13	11.00	22.07.13	00.05	Unit tripped due to furnace pressure very high.
		22.07.13	03.55	22.07.13	04.25	
		22.07.13	10.45	22.07.13	12.00	Dark out due to 220kv supply failure.
		23.07.13	19.15	01.08.13	23.00	Unit tripped on furnace pressure very high due to boiler tube leakage.
		02.08.13	10.00	02.08.13	10.50	Unit tripped due to flame failure
		03.08.13	10.55	03.08.13	12.35	Dark out due to grid disturbance
		03.08.13	12.45	03.08.13	13.05	Unit tripped due to drum level low
		03.08.13	13.15	03.08.13	13.45	Unit tripped due to turbine trip
		07.08.13	19.35	07.08.13	20.55	Unit tripped due to flame failure
		07.08.13	21.05	07.08.13	22.25	Unit tripped due to drum level very low
		08.08.13	08.05	16.08.13	17.40	Stopped due to low demand and high frequency
		21.08.13	06.55	21.08.13	08.35	Unit tripped due to turbine trip
		22.08.13	02.15	22.08.13	03.00	Unit tripped on furnace pressure very high
		22.08.13	22.00	27.08.13	17.40	Unit tripped due to heavy steam leakage from turbine control valve
		11.09.13	03.23	12.09.13	15.15	Shortage of raw water
		16.09.13	05.05	16.09.13	12.19	Coal mill problem
		22.09.13	05.58	24.09.13	14.00	Stopped due to low demand and high frequency
		27.09.13	23.00	27.09.13	23.30	Furnance pressure high
		28.09.13	17.00	28.09.13	18.00	Flame failure
		28.09.13	18.10	28.09.13	18.35	Furnance pressure very high
29.09.13	18.45	29.09.13	19.10	Flame failure		
29.09.13	23.20	07.10.13	18.15	Desynchronised to attend main stream temp; control line leakage		
07.10.13	20.50	07.10.13	21.25	Furnance pressure very high		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	67.5	10.10.13	10.35	14.10.13	10.40	Boiler tube leakage
		25.10.13	23.15	28.10.13	10.25	Stopped due to less demand and high frequency
		28.10.13	10.45	28.10.13	11.15	Drum level high
		04.11.13	12:00	28.02.14	23.59	Stopped due to low demand

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	67.5	03.04.13	04.10	03.04.13	05.35	Unit tripped due to turbine trip.
		05.04.13	20.00	06.04.13	04.05	Unit desynchronised to attend the economiser tube leakage.
		14.04.13	10.10	14.04.13	18.15	Unit desynchronised to attend the CW line leakage.
		04.05.13	09.20	06.05.13	03.25	Unit desynchronised to attend the Economiser tube leakage.
		11.05.13	17.15	11.05.13	18.00	Unit tripped due to turbine trip.
		11.05.13	23.20	11.05.13	23.45	
		19.05.13	07.15	19.05.13	20.55	Unit desynchronised to attend the CW line leakage.
		24.05.13	05.50	01.06.13	00.25	Unit desynchronised due to shortage of coal fuel.
		01.06.13	19.20	07.06.13	14.20	Unit tripped due to Boiler tube leakage.
		11.06.13	07.15	11.06.13	08.30	Unit tripped due to birdage, bay No. 1 to 9 tripped.
		18.06.13	14.20	18.06.13	15.00	Unit tripped due to turbine trip.
		02.07.13	12.55	02.07.13	14.10	Dark out due to grid disturbance.
		02.07.13	23.55	03.07.13	00.55	Unit tripped due to loss of fuel.
		10.07.13	00.45	10.07.13	02.00	Unit tripped due to emergency board supply failure.
		10.07.13	10.45	10.07.13	11.55	Unit tripped due to furnace pressure very high.
		10.07.13	13.50	10.07.13	17.10	Unit desynchronised due to furnace pressure hunting.
		11.07.13	09.20	12.07.13	19.25	Unit desynchronised, furnace disturbance due to wet coal.
		14.07.13	15.35	14.07.13	16.10	Unit tripped due to furnace pressure very high.
		15.07.13	03.45	15.07.13	04.45	Unit tripped due to furnace pressure high.
		19.07.13	07.50	19.07.13	08.20	Unit tripped due to condensor vacuum low.
		21.07.13	03.55	23.07.13	22.20	Unit desynchronised due to no coal flow.
		24.07.13	17.40	02.08.13	13.20	Unit desynchronised to attend the leakage from ACW line.
		03.08.13	10.55	03.08.13	12.10	Dark out due to grid disturbance
		16.08.13	19.30	23.08.13	22.20	Stopped due to low demand and high frequency
		26.08.13	12.15	26.08.13	13.20	Dark out due to grid disturbance
		28.08.13	22.15	13.09.13	16.23	Unit desynchronised to attend the boiler tube leakage / coal mill problem
		26.09.13	09.55	21.10.13	11.30	Boiler tube leakage
		25.10.13	23.15	26.10.13	00.50	Electrical fault
		30.10.13	16.10	24.02.14	08.14	Stopped due to low demand and high frequency
		24.02.14	16.16	24.02.14	20.11	MS-2 valve closed
28.02.14	14.55	28.02.14	16.09	Turbine tripped		

(B)

Gas Turbine

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	01.04.13	0:00	01-04-13	5:45	Stopped due to low demand and high frequency
		03.04.13	16:30	10-04-13	11:25	
		18.04.13	23:20	19-04-13	12:01	Machine stopped to rectify the faulty Controller
		19.04.13	12:15	22-04-13	5:47	Stopped due to low demand and high frequency
		29.04.13	11:31	29-04-13	23:37	
		07.05.13	1:45	13-05-13	14:25	
		13.05.13	16:48	13-05-13	17:10	Machine came on FSNL during charging of 160 MVA Trf.
		18.05.13	13:25	21-05-13	21:10	Stopped due to low demand and high frequency
		30.05.13	21:45	17-06-13	22:55	
		17.06.13	23:15	18-06-13	20:15	
		28.06.13	10:52	28-06-13	22:00	
		28.06.13	22:00	29-06-13	17:00	Machine not available due to problem in Diesel Engine
		29.06.13	17:00	01-07-13	18:05	Stopped due to low demand and high frequency
		01.07.13	21:35	02-07-13	17:45	
		02.07.13	17:45	03-07-13	11:45	Machine could not be started due to problem in EOP
		03.07.13	11:45	08-07-13	8:55	Stopped due to low demand and high frequency
		12.07.13	11:50	15-07-13	8:00	
		15.07.13	9:10	15-07-13	10:40	
		17.07.13	11:20	18-07-13	20:35	
		20.07.13	12:05	27-07-13	21:30	
		27.07.13	21:40	28-07-13	0:12	Machine could not be synchronised due to ignition pressure high trip.
		29.07.13	13:55	29-07-13	15:10	Machine tripped due to GCV reference not followed and loss of flame
		31.07.13	10:40	31-07-13	11:27	Machine came on FSNL due to grid disturbance
		31.07.13	17:30	01.08.13	23:42	Stopped due to low demand and high frequency
		02.08.13	1:40	02.08.13	11:45	
		02.08.13	12:40	04.08.13	10:41	
		06.08.13	15:30	08.08.13	20:41	
		09.08.13	1:20	28.08.13	0:30	
		28.08.13	0:30	28.08.13	3:00	Machine taken out from DC due to leakage in ACW line.
		28.08.13	3:00	28.08.13	11:45	Stopped due to low demand and high frequency
		28.08.13	11:45	28.08.13	14:00	due to leakage in ACW line,GT# 1 not available
		28.08.13	14:00	05.09.13	10:53	
		06.09.13	02:17	12.09.13	21:27	
		13.09.13	18:18	07.10.13	12:20	
		11.10.13	09:37	14.10.13	11:15	Stopped due to low demand and high frequency
		15.10.13	03:02	16.10.13	13:44	
		23.10.13	13:15	15.02.14	15:01	
		17.02.14	16:58	27.02.14	13:37	
		28.02.14	18:06	28.02.14	23:59	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	30	01-04-13	0:00	01-04-13	5:35	Stopped due to low demand and high frequency
		03-04-13	12:02	09-04-13	5:50	
		10-04-13	17:25	11-04-13	11:45	
		28-04-13	21:40	28-04-13	23:45	
		07-05-13	16:30	13-05-13	17:20	
		17-05-13	16:20	28-06-13	22:00	
		28-06-13	22:00	29-06-13	17:00	Machine not available due to problem in Gas Valve
		29-06-13	17:00	02-07-13	17:45	Stopped due to low demand and high frequency
		02-07-13	17:45	03-07-13	13:15	Machine could not be started due to problem in EOP
		03-07-13	13:15	28.08.13	0:30	Stopped due to low demand and high frequency
		28.08.13	0:30	28.08.13	3:00	Machine taken out from DC due to leakage in ACW line.
		28.08.13	3:00	28.08.13	11:45	Stopped due to low demand and high frequency
		28.08.13	11:45	28.08.13	14:00	due to leakage in ACW line,GT# 2 not available
		28.08.13	14:00	01.02.14	17.00	Stopped due to low demand and high frequency
		01.02.14	17.00	28.02.14	23.59	Machine stopped due to high vibration

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	01-04-13	0:00	01-04-13	7:30	Stopped due to low demand and high frequency
		17-04-13	10:40	22-04-13	8:10	
		28-04-13	21:46	29-04-13	10:55	
		04-05-13	0:05	06-05-13	14:00	
		07-05-13	1:50	07-05-13	12:00	
		11-05-13	19:30	14-05-13	17:15	
		14-05-13	18:23	14-05-13	21:00	
		14-05-13	21:00	17-05-13	15:45	
		06-06-13	17:04	06-06-13	19:00	Machine came on FSNL due to tripping of 160 MVA Tr-I & II at IP Extension end.
		06-06-13	22:47	07-06-13	11:55	Stopped due to low demand and high frequency
		09-06-13	8:09	09-06-13	9:50	Machine came on FSNL due to tripping of 160 MVA Tr-I & II Buchholtz relay operated after that tripped on Lube oil temperature high as the auxiliary supply failed .
		11-06-13	12:45	12-06-13	7:56	Stopped due to low demand and high frequency
		14-06-13	8:45	17-06-13	20:50	
		23-06-13	23:40	24-06-13	8:16	
		28-06-13	9:40	28-06-13	21:13	
		30-06-13	9:18	01-07-13	17:23	
		02-07-13	12:44	02-07-13	13:40	
		12-07-13	14:25	12-07-13	21:30	Stopped due to low demand and high frequency
		11-07-13	11:30	18-07-13	20:40	
		20-07-13	12:06	20-07-13	13:22	
		22-07-13	10:32	22-07-13	10:46	Machine came on FSNL due to grid disturbance
		22-07-13	11:20	22-07-13	12:55	Machine taken on FSNL due to voltage problem,160 MVA Tx. Not synchronised
		27-07-13	11:05	27-07-13	21:45	Stopped due to low demand and high frequency
		28-07-13	20:05	30-07-13	20:53	
		31-07-13	10:40	31-07-13	15:55	Machine tripped due to grid disturbance

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	03.08.13	10:56	03.08.13	11:23	Machine came on FSNL due to grid disturbance
		03.08.13	11:23	05.08.13	19:30	Stopped due to low demand and high frequency
		06.08.13	15:34	07.08.13	15:40	
		09.08.13	22:15	26.08.13	9:15	
		26.08.13	12:12	26.08.13	12:58	machine tripped due to Grid disturbance
		28.08.13	0:30	28.08.13	2:50	due to leakage in ACW line,GT not available
		08.09.13	12:32	11.09.13	11:55	Stopped due to low demand and high frequency
		12.09.13	12:45	12.09.13	15:06	
		13.09.13	09:15	13.09.13	17:05	
		21.09.13	14:46	24.09.13	08:48	
		02.10.13	00:32	06.10.13	04:55	Machine tripped due to Exhaust overtemperature trip
		02.11.13	09:20	02.11.13	09:50	
		02.11.13	09:50	02.11.13	17:25	
		13.11.13	05:05	13.11.13	06:35	
		23.11.13	13:25	23.11.13	17:10	
		2.12.13	23:56	3.12.13	00:22	
		16.12.13	02:47	16.12.13	03:40	
		16.12.13	04:41	16.12.13	08:00	
		16.12.13	08:00	20.12.13	15:30	
		27.12.13	14:29	27.12.13	18:12	
		07.01.14	21:50	08.01.14	00:30	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
		08.01.14	10:10	08.01.14	11:12	machine tripped due to battery undervoltage
		12.01.14	00:00	12.01.14	11:15	Stopped due to low demand and high frequency
		16.01.14	06:45	16.01.14	07:10	Machine came on FSNL as 220 KV Ckt I & II from IP to Parpargung tripped
		23.01.14	14:58	26.01.14	18:30	Machine tripped on electrical normal shut down and Rotating diode earth fault alarm on Protection panel.
		26.01.14	18:30	27.01.14	05:50	Stopped due to low demand and high frequency
		14.02.14	04:20	14.02.14	20:15	
		20.02.14	00:06	20.02.14	18:15	
		21.02.14	16:23	21.02.14	17:51	Machine tripped due to loss of excitation
		21.02.14	17:51	27.02.14	14:36	Stopped due to low demand and high frequency
		27.02.14	18:05	28.02.14	15:55	
		28.02.14	22:16	28.02.14	23:59	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	30	01-04-13	0:00	03-04-13	15:50	Stopped due to low demand and high frequency
		17-04-13	10:40	27-04-13	3:15	
		04-05-13	0:02	06-05-13	14:13	
		07-05-13	13:20	07-05-13	15:55	
		11-05-13	19:32	14-05-13	9:58	
		21-05-13	13:10	21-05-13	17:10	
		30-05-13	3:05	05-06-13	11:58	
		06-06-13	17:04	06-06-13	17:15	Machine came on FSNL due to tripping of 160 MVA Tr-I & II at IP Extension end.
		09-06-13	8:09	09-06-13	9:40	Machine came on FSNL due to tripping of 160 MVA Tr-I & II Buchholtz relay operated after that tripped on Lube oil temperature high as the auxiliary supply failed .
		11-06-13	12:45	12-06-13	7:54	Stopped due to low demand and high frequency
		14-06-13	10:20	17-06-13	23:59	
		18-06-13	0:00	19-06-13	21:45	machine not available due to non availability of 66 KV breaker.
		19-06-13	21:45	21-06-13	9:22	Machine not taken on bar due to less schedule from SLDC.
		24-06-13	14:46	24-06-13	15:30	Stopped due to low demand and high frequency
		28-06-13	9:30	28-06-13	22:00	
		28-06-13	22:00	29-06-13	12:10	machine not available due to non availability of AC AOP
		02-07-13	12:44	02-07-13	13:05	Machine came on FSNL due to grid disturbance
		17-07-13	11:30	18-07-13	23:27	Stopped due to low demand and high frequency
		22-07-13	10:32	22-07-13	11:02	Machine came on FSNL due to grid disturbance
		24-07-13	10:10	01.08.13	22:55	Stopped due to low demand and high frequency
		03.08.13	10:56	03.08.13	11:58	Machine came on FSNL due to grid disturbance
		04.08.13	12:50	05.08.13	20:05	Stopped due to low demand and high frequency
		10.08.13	13:32	26.08.13	9:10	
		26.08.13	12:12	26.08.13	13:05	Machine came on FSNL due to grid disturbance
		28.08.13	0:32	28.08.13	3:00	due to leakage in ACW line,GT not available
		28.08.13	3:00	28.08.13	5:12	Stopped due to low demand and high frequency
		08.09.13	12:34	11.09.13	11:56	
		12.09.13	12:45	12.09.13	15:05	
		15.09.13	12:37	15.09.13	20:02	
		17.09.13	21:30	19.09.13	09:27	
		21.09.13	14:48	24.09.13	07:40	
		03.10.13	16:55	06.10.13	10:05	
		11.10.13	08:36	11.10.13	10:30	Machine tripped on high exhaust temperature
		18.11.13	14:05	18.11.13	17:45	Tripped to clean air filter
		16.12.13	10:15	20.12.13	19:56	Stopped due to low demand and high frequency
		04.01.14	00:05	04.01.14	12:55	
		07.01.14	21:50	08.01.14	00:20	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
		16.01.14	06:45	16.01.14	07:15	Machine came on FSNL as 220 KV Ckt I & II from IP to Parpargung tripped
		16.01.14	07:22	16.01.14	08:24	machine tripped on loss of excitation.
		23.01.14	06:05	23.01.14	16:00	Stopped due to low demand and high frequency
20.02.14	18:56	27.02.14	15:38			
27.02.14	19:04	28.02.14	12:26			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	28-04-13	9:34	06-05-13	13:25	Stopped due to low demand and high frequency
		13-05-13	16:48	14-05-13	9:27	
		14-05-13	9:47	18-05-13	10:56	
		24-05-13	18:52	25-05-13	9:55	Tripped due to R-communication link failure alarm & master protective alarm appeared.
		06-06-13	17:04	06-06-13	17:48	Machine came on FSNL due to tripping of 160 MVA Tr-I & II at IP Extension end.
		09-06-13	8:09	09-06-13	8:54	Machine came on FSNL due to tripping of 160 MVA Tr-I & II Buchholtz relay operated after that tripped on Lube oil temperature high as the auxiliary supply failed .
		09-06-13	8:54	10-06-13	7:47	Machine not taken on load due to low schedule from SLDC
		17-06-13	12:17	17-06-13	14:00	Machine tripped on Bus under Voltage alarm as 66 KV bus became dead due to tripping of 160 MVA Tx-I & II .
		18-06-13	13:53	18-06-13	15:45	Machine tripped at IGV Control trouble and Fire Protection Alarm.
		02-07-13	12:44	02-07-13	13:08	Machine came on FSNL due to grid disturbance
		06-07-13	10:55	08-07-13	9:15	Stopped due to low demand and high frequency
		08-07-13	11:32	11-07-13	23:00	
		11-07-13	23:00	12-07-13	10:29	Machine could not be synchronised due to Overall diff. opearted problem
		12-07-13	20:42	15-07-13	8:55	Stopped due to low demand and high frequency
		16-07-13	8:29	16-07-13	9:55	Machine tripped on electrical trouble normal shut down (Due to MVR problem)
		17-07-13	3:00	17-07-13	5:00	
		20-07-13	13:33	23-07-13	21:15	Stopped due to low demand and high frequency
		31-07-13	10:40	31-07-13	10:50	Machine came on FSNL due to grid disturbance
		03.08.13	10:56	03.08.13	11:10	Machine came on FSNL due to grid disturbance
		07.08.13	14:45	08.08.13	21:05	Stopped due to low demand and high frequency
		26.07.13	12:12	26.08.13	12:38	Machine came on FSNL due to grid disturbance
		26.08.13	20:00	27.08.13	11:10	Stopped due to low demand and high frequency
		28.08.13	0:25	28.08.13	2:55	due to leakage in ACW line,GT not available
		30.08.13	22:15	04.09.13	15:00	Stopped due to low demand and high frequency
		02.10.13	00:30	03.10.13	15:15	
		05.10.13	21:14	05.10.13	22:05	Machine tripped due to Grid disturbance
		06.10.13	10:08	07.10.13	07:45	Stopped due to low demand and high frequency
		07.10.13	14:03	16.12.13	10:45	
		23.12.13	12:16	01.1.14	09:35	
		04.01.14	13:46	06.01.14	05:21	
		07.01.14	21:50	07.01.14	23:20	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
		16.01.14	06:45	16.01.14	07:11	Machine came on FSNL as 220 KV Ckt I & II from IP to Parpargung tripped
		20.01.14	11:16	20.01.14	15:22	Stopped due to low demand and high frequency.
12.02.14	00:02	17.02.14	16:20			
27.02.14	12:00	27.02.14	20:00	Machine tripped due to grid disturbance		
27.02.14	20:00	28.02.14	15:45	Machine could not be taken on load due to problem in diesel engine		
28.02.14	20:45	28.02.14	23:59	Stopped due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	10-04-13	12:45	10-04-13	16:30	Stopped due to low demand and high frequency
		21-04-13	12:42	22-04-13	10:15	
		28-04-13	9:32	30-04-13	0:40	
		13-05-13	13:00	13-05-13	16:48	Tripped due to heavy jerk observed in control room.
		13-05-13	16:48	14-05-13	10:38	Stopped due to low demand and high frequency
		14-05-13	18:00	21-05-13	11:05	
		29-05-13	10:42	29-05-13	12:30	Oil temp gauge which is mounted on T/F was founded tilted by at least 30 which leads to maloperation of mercury switch and relay 26 TP-I & 26TP-II operated causing the machine tripped on Electrical trouble normal shutdown
		06-06-13	17:04	06-06-13	17:52	Machine came on FSNL due to tripping of 160 MVA Tr-I & II at IP Extension end.
		06-06-13	22:50	07-06-13	12:04	Stopped due to low demand and high frequency
		09-06-13	8:09	09-06-13	8:54	Machine came on FSNL due to tripping of 160 MVA Tr-I & II Buchholtz relay operated after that tripped on Lube oil temperature high as the auxiliary supply failed .
		09-06-13	8:54	10-06-13	7:52	Machine not taken on load due to low schedule from SLDC
		14-06-13	8:50	14-06-13	10:05	Stopped due to low demand and high frequency
		17-06-13	12:17	17-06-13	17:10	Machine tripped on Reverse Power relay operated as 66 KV bus become dead due to tripping of 160 MVA transformer I & II.
		30-06-13	9:07	01-07-13	17:25	Stopped due to low demand and high frequency
		02-07-13	12:44	02-07-13	13:10	Machine came on FSNL due to grid disturbance
		06-07-13	10:50	08-07-13	9:01	Stopped due to low demand and high frequency
		08-07-13	11:37	11-07-13	19:50	
		12-07-13	14:25	15-07-13	6:24	
		20-07-13	13:30	24-07-13	9:25	
		31-07-13	10:40	31-07-13	11:36	Machine came on FSNL due to grid disturbance
		03.08.13	10:56	03.08.13	11:15	Machine came on FSNL due to grid disturbance
		07.08.13	16:30	08.08.13	20:47	
		09.08.13	22:15	10.08.13	12:30	Stopped due to low demand and high frequency
		26.08.13	12:12	26.08.13	12:18	Machine came on FSNL due to grid disturbance
		26.08.13	19:20	27.08.13	11:45	Stopped due to low demand and high frequency
		28.08.13	0:26	28.08.13	0:30	due to leakage in ACW line,GT not available
		28.08.13	0:30	28.08.13	11:45	Stopped due to low demand and high frequency
		28.08.13	11:45	28.08.13	14:00	Machine not available due to Gas Valve leakage
		28.08.13	14:00	04.09.13	15:15	
		17.09.13	21:31	19.09.13	09:30	Stopped due to low demand and high frequency
		05.10.13	21:14	05.10.13	23:02	Machine tripped due to Grid disturbance
		06.10.13	05:20	08.10.13	07:49	
		07.10.13	13:03	31.10.13	23:59	
		1.11.13	00:00	2.11.13	08:32	
		2.11.13	12:55	2.11.13	16:35	Stopped due to low demand and high frequency
		2.11.13	18:45	16.12.13	07:55	
		23.12.13	12:17	01.01.14	10:15	
		04.01.14	00:05	06.01.14	05:21	
		07.01.14	21:50	08.01.14	01:40	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
		16.01.14	06:45	16.01.14	07:17	Machine came on FSNL as 220 KV Ckt I & II from IP to Parpargung tripped
16.01.14	07:25	16.01.14	08:25	Machine tripped on loss of excitation.		
31.01.14	20:30	01.02.14	15:46	Stopped due to low demand and high frequency.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	11.02.14	20.20	14.02.14	20.15	Stopped due to low demand and high frequency.
		14.02.14	20.15	15.02.14	14.00	Diesel engine speed could not be increased after 1200RPM so machine could not be taken on load
		15.02.14	14.00	17.02.14	11.02	Stopped due to low demand and high frequency.
		20.02.14	00.04	21.02.14	17.51	
		27.02.14	12.00	27.02.14	17.04	Machine tripped due to grid disturbance
		28.02.14	15.15	28.02.14	23.59	Stopped due to low demand and high frequency.

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-1	30	01-04-13	0:00	01-04-13	9:15	Stopped due to low demand and high frequency
		01-04-13	9:30	01-04-13	11:10	Machine stopped due to inspection of high Vibration
		03-04-13	16:30	09-04-13	8:25	Stopped due to low demand and high frequency
		29-04-13	11:31	30-04-13	2:05	
		07-05-13	16:30	13-05-13	19:15	
		18-05-13	13:25	22-05-13	0:10	
		30-05-13	21:45	18-06-13	23:54	
		28-06-13	10:52	28-06-13	22:00	
		28-06-13	22:00	29-06-13	17:00	Machine not available due to Non availability of GTs
		29-06-13	17:00	01-07-13	21:00	Stopped due to low demand and high frequency
		01-07-13	21:00	01-07-13	23:59	Machine not available due to problem in both BFPs.
		02-07-13	0:00	02-07-13	17:45	Stopped due to low demand and high frequency
		02-07-13	17:45	03-07-13	11:45	Machine not available due to non availability of GTs.
		03-07-13	13:15	08-07-13	10:15	Stopped due to low demand and high frequency
		12-07-13	11:50	15-07-13	13:00	
		17-07-13	11:25	18-07-13	23:15	
		20-07-13	12:10	27-07-13	21:30	
		27-07-13	21:30	28-07-13	0:12	
		28-07-13	0:12	28-07-13	1:55	
		29-07-13	13:55	29-07-13	16:00	Tripped due to tripping of GT#1
		31-07-13	10:40	31-07-13	13:55	Machine tripped due to grid disturbance
		31-07-13	17:30	02.08.13	13:15	Stopped due to low demand and high frequency
		02.08.13	13:15	02.08.13	18:15	Due to oil leakage from Turbine side machine taken under shut down by M-II
		02.08.13	18:15	04.08.13	12:45	
		06.08.13	15:29	08.08.13	22:40	Stopped due to low demand and high frequency
		09.08.13	1:20	25.08.13	23:59	
		28.08.13	0:30	28.08.13	3:00	Machine not available due to Non availability of GT#1 and 2
		28.08.13	3:00	28.08.13	11:45	Stopped due to low demand and high frequency
		28.08.13	11:45	28.08.13	14:10	due to leakage in ACW line,GT# 1 and 2 not available
		28.08.13	14:00	05.09.13	15:45	
		06.09.13	02:13	12.09.13	22:30	Stopped due to low demand and high frequency
		13.09.13	18:18	07.10.13	17:10	
		10.10.13	12:12	10.10.13	13:48	machine stopped to carry out C&I work
		11.10.13	09:37	14.10.13	13:58	Stopped due to low demand and high frequency
14.10.13	21:50	16.10.13	16:58	Machine not available due to PROBLEM IN CONTROL VALVE		
23.10.13	23:15	11.02.14	20:07			
17.02.14	16.58	27.02.14	21.02	Stopped due to low demand and high frequency		
28.02.14	18.06	28.02.14	23.59			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-2	30	01.04.13	0:00	01.04.13	11:25	Stopped due to low demand and high frequency
		16.04.13	10:40	22.04.13	11:45	
		23.04.13	12:14	23.04.13	13:09	Machine tripped due to malfunctioning of MS-14 Valve
		27.04.13	5:30	27.04.13	6:15	Machine tripped in the jerk.
		28.04.13	21:46	29.04.13	11:30	Stopped due to low demand and high frequency
		04.05.13	0:02	06.05.13	17:05	
		11.05.13	19:30	14.05.13	13:57	
		19.05.13	1:25	19.05.13	3:05	Machine Tripped on Exhaust pressure high.
		05.06.13	1:01	05.06.13	2:21	Tripped due to sudden drop in vaccum without appearing alarm in annunciation pannel.
		06.06.13	17:04	06.06.13	18:55	Machine tripped as the GT#3 & 4 came on FSNL due to tripping of 160 MVA Tx-I & II at IP Extn end.
		09.06.13	8:09	09.06.13	11:52	Machine tripped as corresponding GT came on FSNL due to tripping of 160 MVA Tr-I & II on Buchholtz relay operated .
		10.06.13	11:42	10.06.13	12:50	Machine stopped to attend
		11.06.13	12:45	12.06.13	10:35	Stopped due to low demand and high frequency
		14.06.13	8:45	17.06.13	23:45	
		23.06.13	21:35	23.06.13	23:20	Machine tripped on LLVT tank v. High Alarm
		28.06.13	9:40	28.06.13	23:15	Stopped due to low demand and high frequency
		02.07.13	12:44	02.07.13	14:25	Machine tripped due to grid disturbance.
		17.07.13	11:35	18.07.13	23:20	Stopped due to low demand and high frequency
		22.07.13	9:35	22.07.13	12:40	Machine tripped due to grid disturbance.
		27.07.13	11:07	27.07.13	23:15	Stopped due to low demand and high frequency
		28.07.13	20:07	31.07.13	3:00	
		31.07.13	10:40	31.07.13	17:24	Machine tripped due to grid disturbance.
		03.08.13	10:56	03.08.13	13:07	machine tripped due to Grid disturbance
		04.08.13	12:50	05.08.13	21:35	
		10.08.13	13:32	26.08.13	18:39	Stopped due to low demand and high frequency
		28.08.13	0:32	28.08.13	3:00	Machine not available due to Non availability of GT#3 and 4
		28.08.13	3:00	28.08.13	4:45	
		08.09.13	12:37	11.09.13	14:15	
		13.09.13	09:15	13.09.13	11:13	Stopped due to low demand and high frequency
		21.09.13	14:48	24.09.13	10:20	
		03.10.13	16:55	06.10.13	09:34	
		16.12.13	10:15	20.12.13	21:05	
		07.01.14	21:50	08.01.14	03:55	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
16.01.14	06:45	16.01.14	08:58	Machine Tripped as both GT 3 & 4 came on FSNL due to Grid disturbance		
23.01.14	14:58	23.01.14	17:40	Machine tripped due to tripping of GT# 3.		
21.02.14	17:51	27.02.14	20:00	Stopped due to low demand and high frequency.		
27.02.14	20:00	28.02.14	15:05	Machine could not be taken on load due to Problem in ESV		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-3	30	05-04-13	17:05	05-04-13	18:20	Machine stopped manually to attend oil Leakage from Secondary oil Pressure line
		28-04-13	9:34	30-04-13	4:25	Stopped due to low demand and high frequency
		03-05-13	17:41	03-05-13	19:04	Machine stopped due to problem in drum level indication and level problem.
		13-05-13	13:00	13-05-13	16:48	Tripped due to heavy jerk observed in control room.
		13-05-13	16:48	14-05-13	13:50	Stopped due to low demand and high frequency
		14-05-13	18:00	18-05-13	13:05	
		03-06-13	9:22	03-06-13	10:07	Machine tripped on Hot well very high alarm as the Control valve CD-34 left the auto and closed. Another Stream CD-37 tried to be taken into service, in the mean time machine tripped on hot well high alarm.
		06-06-13	17:04	06-06-13	18:30	Machine tripped as the GT#5 & 6 came on FSNL due to tripping of 160 MVA Tx-I & II at IP Extn end.
		09-06-13	8:09	09-06-13	8:54	Machine tripped as corresponding GT came on FSNL due to tripping of 160 MVA Tr-I & II on Buchholtz relay operated .
		09-06-13	8:54	10-06-13	10:14	Machine not taken on load due to low schedule from SLDC
		15-06-13	1:58	15-06-13	2:58	Tripped due to LLVT tank level high.
		17-06-13	12:17	17-06-13	15:12	Machine tripped due to both GTs tripped due to Tripping of 160 MVA Tx.
		02-07-13	12:44	02-07-13	14:35	Machine tripped due to grid disturbance.
		06-07-13	10:55	08-07-13	10:15	Stopped due to low demand and high frequency
		08-07-13	10:15	11-07-13	23:07	Machine stopped to attend oil leakage from Oil catcher.
		12-07-13	20:42	15-07-13	8:40	Stopped due to low demand and high frequency
		20-07-13	12:37	20-07-13	13:33	Machine tripped manually due to sticking of MS-14 valve and not opening of MS-11 and MS-13 valve.
		20-07-13	13:33	24-07-13	2:05	Stopped due to low demand and high frequency
		31-07-13	10:40	31-07-13	12:27	Machine tripped due to grid disturbance.
		03.08.13	10:56	03.08.13	12:02	Machine tripped due to Grid disturbance
		07.08.13	16:32	09.08.13	1:12	Stopped due to low demand and high frequency
		17.08.13	11:48	17.08.13	12:45	All the parameters of Turbovisiory and Electronic governor disappeared resulting tripping of steam turbine.
		26.08.13	12:12	26.08.13	13:57	Machine tripped due to Grid disturbance
		26.08.13	18:24	27.08.13	13:48	Stopped due to low demand and high frequency
		28.08.13	0:30	28.08.13	3:00	Machine not available due to Non availability of GT#5 and 6
		28.08.13	3:00	28.08.13	6:30	Stopped due to low demand and high frequency
		30.08.13	22:18	04.09.13	18:00	
		05.10.13	21:14	07.10.13	12:00	Machine tripped due to Grid disturbance and not taken on load due to less demand
		07.10.13	12:00	02.11.13	23:59	Machine not available due to problem in control valve
		02.11.13	18:50	16.12.13	10:59	
		23.12.13	12:17	01.01.14	12:30	Stopped due to low demand and high frequency
		04.01.14	13:50	06.01.14	07:55	Machine stopped as per SLDC message
		07.01.14	21:50	08.01.14	01:58	Due to bursting of PT of SL-1 ckt.machine tripped due to grid disturbance
		12.01.14	13:29	12.01.14	14:24	Machine tripped on False alarm appeared on BCS desk, i.e. Emergency push button Operated.All parameters were normal
		16.01.14	06:45	16.01.14	09:17	Machine Tripped as both GT 3 & 4 came on FSNL due to Grid disturbance
		21.01.14	20:30	21.01.14	21:43	Failure of Communication Module 70BK02 for CH02 Station
		21.01.14	21:53	21.01.14	22:21	Class 'A" (Relay 86GA1& timer for 3242A)
		12.02.14	00:02	13.02.14	23:59	Machine stopped to attend various leakages
		14.02.14	00:00	14.02.14	20:15	Stopped due to low demand and high frequency.
		14.02.14	20:15	15.02.14	14:00	Machine could not be taken on load due to misc. problem
15.02.14	14:00	17.02.14	15:35	Stopped due to low demand and high frequency.		
27.02.14	12:00	27.02.14	20:42	Machine tripped due to grid disturbance		
28.02.14	15:17	28.02.14	23:59	Stopped due to low demand and high frequency.		

(C) PRAGATI STATION

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	104	23.05.13	14.29	23.05.13	14.56	Tripped due to Gas Fuel Pr. Low by GAIL
		15.06.13	21.55	17.06.13	9.00	No schedule to run GT#1 on Open Cycle.
		17.06.13	9.00	24.06.13	0.26	Tripped on internal fault
		25.06.13	22.00	26.06.13	2.00	
		26.06.13	2.00	26.06.13	13.42	No schedule of GT#1 in OC due to low demand, HRSG#1 not available-FW104 stuck
		09.07.13	19.03	09.07.13	19.50	Tripped on internal fault
		22.07.13	10.43	22.07.13	12.26	Tripped due to Grid Disturbance
		23.07.13	16.28	23.07.13	19.29	Tripped on internal fault
		03.09.13	13.10	03.09.13	14.14	
		28.09.13	06.01	29.09.13	16.30	Stopped to attend generation winding temprature.
		14.10.13	12.22	14.10.13	12.49	Tripped on internal fault
		17.10.13	12.39	17.10.13	13.47	
		16.12.13	09.59	16.12.13	19:37	Stopped to replace Air Filters of G.T. #1
		06.01.14	07.26	06.01.14	10.20	Tripped due to 125V DC earth fault
		16.01.14	08.28	16.01.14	10.56	Tripped due to grid disturbance
		25.02.14	12.00	26.02.14	19.30	Stopped due to Boroscopic Inspection

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	104	21.04.13	8.15	21.04.13	18.15	Stopped by DTL to attend hot spot.
		21.04.13	18.15	23.04.13	6.31	Tripped on internal fault
		26.04.13	6.45	26.04.13	8.37	
		14.05.13	13.28	14.05.13	14.13	
		06.06.13	17.10	06.06.13	18.05	Tripped due to Grid Disturbance
		01.07.13	16.02	01.07.13	17.40	Tripped on internal fault
		02.07.13	12.54	02.07.13	13.55	Tripped due to Grid Disturbance
		08.07.13	11.37	08.07.13	12.48	Tripped on internal fault
		22.07.13	10.43	22.07.13	11.52	Tripped due to Grid Disturbance
		03.08.13	10.57	03.08.13	11.08	Tripped due to Grid Disturbance
		15.08.13	10.48	16.08.13	16.31	Stopped due to low demand and high frequency
		26.08.13	12.15	26.08.13	12.26	Tripped due to Grid Disturbance
		28.08.13	6.07	29.08.13	8.53	Stopped due to low demand and high frequency
		29.08.13	20.40	29.08.13	22.30	Tripped on internal fault
		24.09.13	02.34	24.09.13	09.44	Tripped due to grid disturbance
		05.10.13	21.17	05.10.13	22.05	
		15.10.13	13.06	19.10.13	12.19	Tripped on internal fault
		17.12.13	02.48	17.12.13	18.13	Stopped to replace Air Filters of G.T. #1
		06.01.14	07.13	10.01.14	12.10	G.T.-#2 unloaded and tripped due to fire in load compartment
		16.01.14	06.56	16.01.14	07.18	Tripped ;due to grid disturbance
17.01.14	21.58	21.01.14	12.52	Stopped for inspection of exhaust compartment by BGGTSs engineers		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	122	17.04.13	18.37	17.04.13	19.52	Tripped on internal fault
		21.04.13	11.44	21.04.13	14.15	
		21.04.13	14.15	21.04.13	18.36	Shut down continued by DTL to attend hot spot.
		06.06.13	17.10	06.06.13	18.50	Tripped due to Grid Disturbance
		02.07.13	12.54	02.07.13	15.02	
		09.07.13	19.03	09.07.13	20.15	Tripped on internal fault
		22.07.13	10.43	22.07.13	15.53	Tripped due to Grid Disturbance
		23.07.13	16.28	23.07.13	17.42	Tripped on internal fault
		03.08.13	10.57	03.08.13	11.47	Tripped due to Grid Disturbance
		26.08.13	12.15	26.08.13	13.35	Tripped due to Grid Disturbance
		29.08.13	20.45	29.08.13	22.52	
		03.09.13	13.18	03.09.13	14.25	Tripped on internal fault
		10.09.13	00.34	10.09.13	01.32	
		05.10.13	21.17	05.10.13	23.30	Tripped due to Grid Disturbance
		07.10.13	18.55	10.10.13	09.03	Tripped on internal fault
		17.10.13	12.39	17.10.13	14.31	
		06.01.14	07.26	06.01.14	14.44	Tripped due to both GT's tripped
		16.01.14	06.42	16.01.14	09.07	Tripped due to grid disturbance

(D) **BADARPUR THERMAL POWER STATION**

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	95	01.04.13	0:00	01.04.13	19:18	Stopped due to low demand and high frequency
		12.05.13	18:18	12.05.13	21:20	Grid Disturbance
		04.06.13	22:45	05.06.13	23:45	Water Wall tube leakage
		13.06.13	10:58	13.06.13	11:32	Furnace Disturbance
		16.06.13	18:38	21.06.13	14:14	
		09.07.13	20:41	15.07.13	24:00	Stopped due to low demand and high frequency
		19.07.13	3:28	20.07.13	18:14	
		26.07.13	14:36	29.07.13	16:00	
		10.08.13	15:12	10.08.13	16:00	
		10.08.13	17:11	10.08.13	23:15	Furnace Disturbance
		10.08.13	23:15	14.09.13	21:06	Stopped due to low demand and high frequency
		17.09.13	03:13	17.09.13	04:06	
		22.09.13	14:00	22.09.13	15:08	
		22.09.13	23:52	23.09.13	01:00	Furnace Disturbance
		23.09.13	01:00	23.09.13	21:00	Platen Superheater leakage
		23.09.13	21:00	22.10.13	12:54	
		09.11.13	22:34	25.11.13	02:15	Stopped due to low demand and high frequency
		28.11.13	23:57	12.12.13	11:00	
		20.12.13	00:00	01.01.14	08:55	
		11.01.14	14.38	11.01.14	16.42	Tripped on DC earth fault
11.01.14	16.42	13.01.14	05.59			
12.02.14	18.24	28.02.14	23.59	Stopped due to low demand and high frequency		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	95	12.05.13	18:18	12.05.13	20:07	Grid Disturbance
		28.06.13	10:32	28.07.13	9:56	Stopped due to low demand and high frequency
		08.08.13	11:01	10.08.13	22:09	
		23.08.13	13:14	23.08.13	14:15	Furnace Disturbance
		21.09.13	19:57	23.09.13	19:49	Stopped due to low demand and high frequency
		02.10.13	07:50	02.10.13	08:40	Furnace Disturbance
		02.10.13	09:21	02.10.13	10:01	
		02.10.13	11:07	04.10.13	00:12	Superheater leakage
		04.11.13	19:52	24.11.13	20:50	Stopped due to low demand and high frequency
		28.11.13	09:16	28.11.13	14:23	GT Overall Differential
		05.12.13	17:49	20.12.13	17:17	Stopped due to low demand and high frequency
		01.01.14	08:35	10.01.14	20:53	
		21.01.14	22:10	27.01.14	08:55	
		12.02.14	12:01	28.02.14	23:59	

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	95	03.04.13	19:55	22.04.13	13:40	Planned Shutdown
		12.05.13	18:18	12.05.13	20:20	Grid Disturbance
		26.05.13	12:41	27.05.13	12:58	Economiser Tube leakage
		13.06.13	10:40	18.06.13	12:04	Stopped due to low demand and high frequency
		04.07.13	5:45	04.07.13	7:06	Furnace Disturbance
		18.07.13	11:39	19.07.13	2:48	Stopped due to low demand and high frequency
		01.08.13	21:28	02.08.13	13:43	Water Wall tube leakage
		03.08.13	3:45	03.08.13	6:14	Furnace Disturbance
		03.08.13	17:10	03.08.13	18:02	
		06.08.13	11:15	06.08.13	11:56	Furnace Disturbance
		07.08.13	11:40	15.09.13	07:21	Stopped due to low demand and high frequency
		19.09.13	05:19	19.09.13	06:50	Furnace Disturbance
		19.09.13	21:01	19.09.13	21:42	
		28.09.13	10:05	28.09.13	19:22	Furnace Disturbance
		02.10.13	00:08	03.10.13	05:28	Stopped due to low demand and high frequency
		08.10.13	19:16	08.10.13	20:32	Furnace Disturbance
		09.10.13	22:20	10.10.13	00:49	HT motor problem- feed pump drive
		11.10.13	17:15	16.10.13	18:40	Stopped due to low demand and high frequency
		22.10.13	14:04	22.10.13	14:42	Furnace Disturbance
		31.10.13	21:22	31.10.13	22:03	
		10.11.13	10:13	10.11.13	11:22	Furnace Disturbance
		18.11.13	05:40	18.11.13	06:35	Furnace Disturbance
		18.11.13	18:38	18.11.13	19:48	Furnace Disturbance
		21.11.13	06:39	21.11.13	07:21	Furnace Disturbance
22.11.13	00:05	20.01.14	04:17	Stopped due to low demand and high frequency		
25.01.14	23:03	10.02.14	14:16			

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	210	09.04.13	22:17	10.04.13	2:07	MDBFP relay malfunction
		12.05.13	18:18	12.05.13	21:35	Grid Disturbance
		25.05.13	7:28	23.05.13	15:34	UAT 4A diff relay casing shorted
		11.06.13	15:35	13.06.13	07:48	Stopped due to low demand and high frequency
		10.08.13	10:24	10.08.13	13:40	AVR & Excitation system
		14.09.13	04:34	15.09.13	23:01	Water Wall tube leakage
		25.11.13	03:58	28.11.13	11:07	ID Fan 4B impeller shaft replaced
		11.12.13	23:24	17.12.13	23:16	Boiler tube leakage
		10.02.14	06:08	11.02.14	15:15	Water wall tube leakage
		11.02.14	15:15	12.02.14	07:17	3.3/6.6/11kV Bus/Breaker problem

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	210	09.05.13	0:06	09.05.13	15:57	APH 5B NDE Bearing vibration high
		11.05.13	19:48	14.05.13	12:17	Stopped due to low demand and high frequency
		16.06.13	15:58	16.06.13	17:09	CW Shortage
		24.06.13	16:23	24.06.13	17:45	Furnace Disturbance
		24.06.13	18:04	24.06.13	19:03	
		27.06.13	14:20	27.06.13	18:31	AVR & Excitation System
		04.07.13	0:12	04.07.13	1:15	Furnace Disturbance
		27.07.13	19:16	30.07.13	1:24	Steam Cooled W/Wall leakage
		01.08.13	20:43	02.08.13	18:30	Drum manhole leakage
		14.08.13	19:00	15.08.13	10:15	Water Wall tube leakage
		15.08.13	10:15	16.08.13	7:13	Stopped due to low demand and high frequency
		04.09.13	13:23	06.09.13	09:11	Water Wall tube leakage
		06.09.13	13:39	07.09.13	21:32	Economiser Tube leakage
		04.10.13	14:37	05.10.13	17:55	Stopped due to low demand and high frequency
		07.10.13	03:48	08.10.13	23:48	3.3/6.6/11KV Bus breaker problem
		23.10.13	00:50	20.11.13	18:42	Planned shutdown
		21.11.13	08:00	21.11.13	19:35	Shutdown of main GT Transformer
		07.12.13	14:50	07.12.13	18:47	To attend hot spot at bushing clamp
		08.12.13	14:39	08.12.13	17:38	To attend hot spot
		13.01.14	12:30	13.01.14	19:51	Generator transformer Y phase busing temp. high
28.01.14	12:06	30.01.14	15:05	Boiler tube leakage		

(E) BAWANA CCGT POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	216	01.04.13	00:00	01.04.13	8:39	Combustion inspection
		05.04.13	10:55	21.04.13	23:59	M/C under planned shut down due to CW interconnection/CW sump cleaning/Diverter Damper setting
		19.06.13	00:26	19.06.13	02:42	G.T. -1 tripped due to Hot gas temp high.
		20.06.13	20:42	05.08.13	09:10	Stopped due to low demand and high frequency
		19.08.13	14:27	26.08.13	11:54	Stopped due to low demand and high frequency
		25.09.13	12:05	28.02.14	23:59	

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	216	05.04.13	13:13	12.04.13	19:02	M/C under planned shut down due to CW interconnection/CW sump cleaning/Diverter Damper setting up to 12.04.13
		14.04.13	13:40	25.04.13	08:57	Stopped due to low demand and high frequency
		29.04.13	22:25	30.04.13	06:25	M/C Stopped due to gas leakage in pipe line
		07.05.13	20:38	08.05.13	0:26	CW Pump Motor Failure
		29.05.13	13:57	29.05.13	15:30	GT#2 tripped on EPB press by default
		03.06.13	10:54	03.06.13	13:53	GT #2 tripped due to its rotor earth fault
		06.06.13	22:50	10.06.13	12:38	Stopped due to low demand and high frequency
		13.06.13	08:14	20.06.13	18:33	Stopped due to low demand and high frequency
		21.06.13	08:21	21.06.13	12:54	GT #2 tripped due to difference in G-1 feedback
		30.06.13	14:16	30.06.13	14:58	GT#2 Tripped on Excitation tripping
		12.07.13	15:00	03.10.13	13:22	Stopped due to low demand and high frequency
		03.10.13	16:07	07.10.13	14:48	
		10.10.13	15:56	10.10.13	17:10	Tripped due to isolation of LPC 02
11.10.13	10:40	28.02.14	23:59			

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	216	28.10.13	00:00	28.02.14	23:59	Commissioned on 28.10.13 and Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	216	27.02.14	00:00	28.02.14	23:59	Commissioned on 27.02.14 and Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	254	01.04.13	0:00	27.04.13	19:19	M/C under planned shut down due to CW interconnection/CW sump cleaning/Diverter Damper setting up to 12.04.13 after force shutdown due to bearing failure of turbine up to 25.04.13 and 25.04.13 to 27.04.13 due to generator IR value low
		29.04.13	22:25	30.04.13	6:25	M/C Stopped due to gas leakage in pipe line
		30.04.13	22:07	30.04.13	23:37	GT#2 Diverted damper is closed
		07.05.13	20:35	08.05.13	3:12	CW Pump A Motor Failure
		08.05.13	11:57	08.05.13	13:19	CW Pump B Motor winding temperature increased up to threshold limit
		29.05.13	13:57	29.05.13	16:50	STG trip on GT trip
		03.06.13	10:54	03.06.13	15:57	Stopped due to low demand and high frequency
		06.06.13	22:50	10.06.13	17:50	
		13.06.13	08:16	19.06.13	09:10	
		21.06.13	08:21	21.06.13	13:00	STG trip on GT trip
		27.06.13	18:01	27.06.13	18:42	GT#2 Diverted damper is closed
		29.06.13	17:31	29.06.13	18:29	CW Pump B Discharge valve closed
		30.06.13	14:16	30.06.13	15:34	STG trip on GT trip
		12.07.13	15:00	05.08.13	11:58	Stopped due to low demand and high frequency
		19.08.13	14:29	26.08.13	17:41	
		31.08.13	12:52	31.08.13	14:12	STG tripped on internal fault
		25.09.13	12:00	07.10.13	20:20	Stopped due to low demand and high frequency
10.10.13	15:56	10.10.13	18:06	Tripped due to tripping of GT-2		
11.10.13	10:50	31.01.14	23:59	Stopped due to low demand and high frequency		

(E) RITHALA POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	31.8	19.03.13	17:32	31.01.14	23:59	No schedule have been given by SLDC on Spot gas

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	31.8	05.03.13	15:38	07.06.13	12:05	No schedule have been given by SLDC on Spot gas Gas turbine taken on spot)
		07.06.13	22:41	31.01.14	23:59	No schedule have been given by SLDC on Spot gas

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	31.8	27.02.13	00:01	07.06.13	17:40	No schedule have been given by SLDC on Spot gas
		07.06.13	22:38	31.01.14	23:59	No schedule have been given by SLDC on Spot gas

4

ALLOCATION OF POWER TO DELHI

A)

Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 16.03.2013**Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	500	75	66	57	0	0	57
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	9282	1227	2240	1959	0	0	1959
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3305	206	380	361	0	0	361
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
THDC							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	135	0	0	135
Total	16807	1915	3007	2680	0	0	2680
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	1500	114	377	327	0	0	327
Grand Total	24517	2182	3674	3249	0	0	3249

B) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 30.06.2013

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	154	23	20	19	0	0	19
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhaulti Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3228	195	370	352	0	0	352
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
THDC							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	127	0	0	127
Total	16230	1828	2932	2593	0	0	2593
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	1000	76	231	201	0	0	201
Grand Total	23440	2057	3453	3036	0	0	3036

C) **Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 04.07.2013**

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhaulti Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3305	206	380	361	0	0	361
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
THDC							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	127	0	0	127
Total	16307	1840	2941	2603	0	0	2603
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	1000	76	231	201	0	0	201
Grand Total	23517	2069	3462	3045	0	0	3045

D) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 01.08.2013

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	500	75	66	57	0	0	57
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	9282	1227	2240	1959	0	0	1959
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhaulti Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3305	206	380	361	0	0	361
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
THDC							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	127	0	0	127
Total	16807	1915	3007	2660	0	0	2660
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	1500	114	377	327	0	0	327
Grand Total	24517	2182	3674	3229	0	0	3229

E) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 11.10.2013

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	500	75	66	57	0	0	57
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	9282	1227	2240	1959	0	0	1959
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI HEP-I	480	0	53	50	0	0	50
URI HEP-II	120	18	16	15	0	0	15
Sewa HEP	120	18	16	15	0	0	15
Dhaulti Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3425	224	396	377	0	0	377
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP (C)	440	64	56	49	0	0	49
TOTAL	880	128	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
THDC							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	135	0	0	135
Total	16487	1867	3023	2695	0	0	2695
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	4960	153	261	217	0	0	217
Joint Venture							
Jhajjar TPS	1500	114	377	327	0	0	327
Grand Total	22947	2134	3661	3240	0	0	3240

F) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 19.11.2013

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	500	75	66	57	0	0	57
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	9282	1227	2240	1959	0	0	1959
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3305	206	380	361	0	0	361
<u>NPC</u>							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	400	40	39	37	0	0	37
TOTAL	1400	139	142	127	0	0	127
Total	16807	1915	3007	2660	0	0	2660
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	1500	114	377	327	0	0	327
Grand Total	24517	2182	3674	3229	0	0	3229

5 ALLOCATION OF POWER TO DISCOMS

A) ALLOCATION OF POWER TO VARIOUS LICENCEES AS PER ORDER OF DERC AND DECISION OF GNCTD FOR ALLOCATION OF CENTRAL SECTOR STATIONS (DADRI THERMAL & BTPS) AND STATE SECTOR GENERATING STATIONS w.e.f. 01.04.2011.

(Allocation In %)

(A) 10.00hrs. to 17.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.98	0.00	24.18	36.87	23.97	100.00
3. BTPS	15.94	7.09	21.88	33.37	21.72	100.00
4. RPH	0.85	0.00	28.39	42.97	27.79	100.00
5. GT	0.93	0.00	28.28	42.99	27.80	100.00
6. Pragati	26.69	0.00	20.77	31.76	20.7	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

(B) 00.00hrs. to 10.00hrs. and 17.00hrs. to 24.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.05	0.00	24.18	36.87	24.90	100.00
3. BTPS	15.07	7.09	21.88	33.37	22.59	100.00
4. RPH	0.00	0.00	28.390	42.97	28.64	100.00
5. GT	0.00	0.00	28.28	42.99	28.73	100.00
6. Pragati	25.76	0.00	20.77	31.76	21.71	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

* 20% POWER OF BAWANA CCGT ALLOCATED TO HARYANA (10%) & PUNJAB (10%)

B) ALLOCATION OF POWER TO VARIOUS LICENCEES AS PER ORDER OF DERC AND DECISION OF GNCTD FOR ALLOCATION OF CENTRAL SECTOR STATIONS (DADRI THERMAL & BTPS) AND STATE SECTOR GENERATING STATIONS w.e.f. 06.08.2013.

(Allocation In %)

(A) 10.00hrs. to 17.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0	0	29.18	43.58	27.24	100.00
2. Dadri (Th)	16.63	0	24.22	36.86	22.39	100.00
3. BTPS	17.73	7.09	21.81	33.2	20.17	100.00
4. RPH	0	0	29.025	44.133	26.842	100.00
5. GT	0	0	29.02	44.16	26.82	100.00
6. Pragati	30.3	0	20.22	30.78	18.7	100.00
7. DVC	0	0	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

(B) 00.00hrs. to 10.00hrs. and 17.00hrs. to 24.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0	0	29.18	43.58	27.24	100.00
2. Dadri (Th)	16.53	0	24.22	36.86	22.39	100.00
3. BTPS	17.73	7.09	21.81	33.2	20.17	100.00
4. RPH	0	0	29.025	44.133	26.842	100.00
5. GT	0	0	29.02	44.16	26.82	100.00
6. Pragati	30.3	0	20.22	30.78	18.7	100.00
7. DVC	0	0	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

* 20% POWER OF BAWANA CCGT ALLOCATED TO HARYANA (10%) & PUNJAB (10%)

6 POWER AVAILABILITY-DEMAND POSITION AT THE TIME OF PEAK DEMAND MET DURING FEBRUARY 2014

All figures in MW

Date	Time of peak demand	Generation within Delhi								Import from the Grid	Schedule from the Grid	OD(-)/UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	Rithala	Bawana	Towmcl	BTPS	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)	
1	10.01.35	0	120	323	0	-2	8	551	1000	2622	2492	130	3622	0	3622
2	10.30.47	0	162	320	0	-2	2	452	934	2687	2558	129	3621	0	3621
3	09.56.00	0	155	310	0	-2	0	543	1006	2478	2602	-124	3484	0	3484
4	09.54.45	0	159	309	0	-5	3	523	989	2486	2461	25	3475	0	3475
5	09.50.28	0	161	314	0	-9	8	453	927	2518	2511	7	3445	0	3445
6	09.52.25	0	160	309	0	-2	10	550	1027	2377	2606	-229	3404	0	3404
7	09.47.09	0	156	309	0	-4	14	547	1022	2492	2651	-159	3514	0	3514
8	09.52.59	0	164	318	0	-2	11	559	1050	2428	2299	129	3478	0	3478
9	10.21.00	0	162	320	0	-2	13	554	1047	2454	2316	138	3501	0	3501
10	10.13.19	0	162	320	0	-2	7	356	843	2638	2527	111	3481	0	3481
11	09.33.29	0	158	321	0	-2	8	442	927	2519	2590	-71	3446	13	3459
12	10.06.32	0	116	321	0	-2	12	619	1066	2486	2512	-26	3552	10	3562
13	09.35.06	0	118	321	0	-3	10	463	909	2587	2489	98	3496	0	3496
14	10.39.51	0	73	266	0	-1	14	434	786	2811	2447	364	3597	0	3597
15	10.23.41	0	115	322	0	-2	2	443	880	2746	2733	13	3626	5	3631
16	10.36.32	0	115	322	0	-3	11	467	912	2758	2577	181	3670	0	3670
17	09.44.10	0	117	323	0	209	2	424	1075	2567	2645	-78	3642	0	3642
18	10.04.56	0	161	320	0	-2	4	452	935	2627	2649	-22	3562	0	3562
19	10.04.56	0	163	319	0	-5	4	427	908	2670	2697	-27	3578	0	3578
20	10.10.17	0	76	310	0	-1	3	360	748	2779	2562	217	3527	0	3527
21	09.51.34	0	79	314	0	38	6	457	894	2711	2501	210	3605	0	3605
22	10.21.03	0	83	300	0	-2	13	363	757	2704	2499	205	3461	36	3497
23	10.43.20	0	83	301	0	-8	15	377	768	2642	2497	145	3410	8	3418
24	10.00.32	47	84	300	0	-5	14	380	820	2650	2619	31	3470	0	3470
25	10.04.56	52	83	299	0	-6	13	374	815	2503	2603	-100	3318	0	3318
26	10:37:46	50	82	148	0	-7	14	371	658	2719	2301	418	3377	0	3377
27	09:47:19	53	83	262	0	-5	10	394	797	2638	2454	184	3435	13	3448
28	09:19:33	52	77	277	0	-6	10	376	786	2607	2397	210	3393	12	3405

POWER AVAILABILITY- DEMAND POSITION AT THE TIME OF MAXIMUM UNRESTRICTED DEMAND DURING FEBRUARY 2014

Date	Time of peak demand	Generation within Delhi								Import from the Grid	Schedule from the Grid	OD(-)/UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	Rithala	Bawana	Towmcl	BTPS	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)		(9)=(3) to (8)	(10)	(11)	(12)=(11) - (10)	(13)=(11)+ (12)	(14)	(15)= (13)+ (14)
1	10.01.35	0	120	323	0	-2	8	551	1000	2622	2492	130	3622	0	3622
2	10.30.47	0	162	320	0	-2	2	452	934	2687	2558	129	3621	0	3621
3	09.56.00	0	155	310	0	-2	0	543	1006	2478	2602	-124	3484	0	3484
4	09.54.45	0	159	309	0	-5	3	523	989	2486	2461	25	3475	0	3475
5	09.50.28	0	161	314	0	-9	8	453	927	2518	2511	7	3445	0	3445
6	09.52.25	0	160	309	0	-2	10	550	1027	2377	2606	-229	3404	0	3404
7	09.47.09	0	156	309	0	-4	14	547	1022	2492	2651	-159	3514	0	3514
8	09.52.59	0	164	318	0	-2	11	559	1050	2428	2299	129	3478	0	3478
9	10.21.00	0	162	320	0	-2	13	554	1047	2454	2316	138	3501	0	3501
10	10.13.19	0	162	320	0	-2	7	356	843	2638	2527	111	3481	0	3481
11	09.33.29	0	158	321	0	-2	8	442	927	2519	2590	-71	3446	13	3459
12	10.06.32	0	116	321	0	-2	12	619	1066	2486	2512	-26	3552	10	3562
13	09.35.06	0	118	321	0	-3	10	463	909	2587	2489	98	3496	0	3496
14	10.39.51	0	73	266	0	-1	14	434	786	2811	2447	364	3597	0	3597
15	10.23.41	0	115	322	0	-2	2	443	880	2746	2733	13	3626	5	3631
16	10.36.32	0	115	322	0	-3	11	467	912	2758	2577	181	3670	0	3670
17	09.44.10	0	117	323	0	209	2	424	1075	2567	2645	-78	3642	0	3642
18	10.04.56	0	161	320	0	-2	4	452	935	2627	2649	-22	3562	0	3562
19	10.04.56	0	163	319	0	-5	4	427	908	2670	2697	-27	3578	0	3578
20	10.10.17	0	76	310	0	-1	3	360	748	2779	2562	217	3527	0	3527
21	09.51.34	0	79	314	0	38	6	457	894	2711	2501	210	3605	0	3605
22	10.21.03	0	83	300	0	-2	13	363	757	2704	2499	205	3461	36	3497
23	10.43.20	0	83	301	0	-8	15	377	768	2642	2497	145	3410	8	3418
24	10.00.32	47	84	300	0	-5	14	380	820	2650	2619	31	3470	0	3470
25	10.04.56	52	83	299	0	-6	13	374	815	2503	2603	-100	3318	0	3318
26	10:37:46	50	82	148	0	-7	14	371	658	2719	2301	418	3377	0	3377
27	09:47:19	53	83	262	0	-5	10	394	797	2638	2454	184	3435	13	3448
28	09:19:33	52	77	277	0	-6	10	376	786	2607	2397	210	3393	12	3405

SOURCEWISE SCHEDULED DRAWL FROM NORTHERN GRID AS WELL AS AVAILABILITY WITHIN DELHI FOR FEBRUAR 2014

A) AVAILABILITY FROM GENCO AND PRAGATI STNs. (all fig in MUs)

A (i) RPH	5.932
(ii) GT+STG	84.316
(iii) PRAGATI	196.638
(iv) RITHALA	0.000
(v) BAWANA CCGT	9.161
(vi) Timarpur – Okhla	7.347
TOTAL	303.394
B) AVAILABILITY FROM BTPS	297.700
C) AUXILIARY CONSUMPTION OF GENERATING STNs. EXCLUDING BTPS	12.047
D) NET GENERATION AVAILABLE WITHIN DELHI(A+B-C)	589.047

B) SOURCE WISE SCHEDULED DRAWL FROM THE NORTHERN GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
B/SUIL	3.358	3.229	3.358	3.229
SALAL	11.447	11.005	11.447	11.005
SASAN	61.217	58.892	60.126	57.840
TANKAPUR	0.000	0.000	0.000	0.000
CHAMERA	6.145	5.908	6.145	5.908
CHAMERA -II	4.594	4.417	4.594	4.417
CHAMERA -III	1.486	1.431	1.486	1.431
DHAULIGANGA	0.000	0.000	0.000	0.000
SEWA -2	5.524	5.312	5.524	5.312
URI	14.367	13.814	14.367	13.814
URI-II	9.179	8.825	9.179	8.825
KOTESHWAR	7.739	7.439	7.739	7.439
MUNDRA_UMPP	0.000	0.000	0.000	0.000
ANTA (GAS)	25.023	24.056	19.986	19.210
ANTA (RLNG)	4.803	4.616	0.000	0.000
ANTA (LIQUID)	0.000	0.000	0.000	0.000
DADRI (GAS)	49.297	47.384	33.918	32.598
DADRI (RLNG)	12.779	12.289	0.000	0.000
DADRI (LIQUID)	0.000	0.000	0.000	0.000
AURAIYA (GAS)	19.512	18.746	13.747	13.208
AURAIYA (RLNG)	29.613	28.477	0.000	0.000
AURAIYA (LIQUID)	0.000	0.000	0.000	0.000
SINGRAULI	93.411	89.794	91.515	87.968
RIHAND -I	62.568	60.146	56.672	54.474
RIHAND -II	82.492	79.298	77.326	74.327
RIHAND -III	35.305	33.943	33.820	32.513
UNCHAHAAR-I	15.614	15.010	13.229	12.715
UNCHAHAAR-II	30.700	29.512	27.712	26.637
UNCHAHAAR-III	18.783	18.056	16.818	16.166
DADRI (TH)	440.976	423.861	399.606	384.088
DADRI (TH) STAGE-II	453.218	435.649	421.859	405.485
NAPP	21.236	20.414	21.236	20.414
RAPP 'B'	0.000	0.000	0.000	0.000
RAPP 'C'	36.576	35.160	36.576	35.160
NATHPA JHAKRI	17.402	16.729	12.835	12.339
DULASTI	8.977	8.630	8.977	8.630
TEHRI	20.867	20.058	20.867	20.058
JHAJJAR	253.310	243.504	57.284	55.080
KHELGAON	31.567	30.343	27.220	26.165
KHELGAON-II	93.657	90.025	88.418	84.985

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
FARAKA	14.269	13.717	13.227	12.715
TALA	1.071	1.029	1.071	1.029
TALCHER	0.000	0.000	0.000	0.000
DVC	123.027	121.565	121.565	116.903
CHATTISHGARH	1.871	1.834	1.834	1.760
DVC CTPS (BRPL)	0.000	0.000	0.000	0.000
DVC CTPS (BYPL)	0.000	0.000	0.000	0.000
DVC CTPS (NDPL)	0.000	0.000	0.000	0.000
METHON POWER(NDPL)LT-06	167.992	165.999	165.999	159.554
DVC (FOR NDPL) LT-09	4.013	3.965	3.965	3.820
HARYANA (LT-05)	19.671	19.322	19.322	18.564
UTTAR PRADESH	22.197	21.677	21.677	20.837
ORISSA	0.000	0.000	0.000	0.000
TO MEGHALAYA	-4.576	-4.668	-4.668	-4.848
TO ORISSA	0.000	0.000	0.000	0.000
TO UTTAR PRADESH	-21.588	-22.105	-22.105	-22.994
TO JAMMU & KASHMIR	-155.799	-159.064	-159.064	-165.504
TO TRIPURA	0.000	0.000	0.000	0.000
TO ANDHRA	0.000	0.000	0.000	0.000
TO MADHYA PRADESH	-38.071	-38.808	-38.808	-40.371
TO GUJRAT	0.000	0.000	0.000	0.000
TO RAJASTHAN	-77.842	-79.465	-79.465	-82.666
TO MAHARASHTRA	-4.667	-4.772	-4.772	-4.964
TO UTTRANCHAL	-108.928	-111.535	-111.535	-116.016
TO HIMACHAL PRADESH	-83.737	-85.225	-85.225	-88.665
TO WEST BENGAL	-3.248	-3.287	-3.287	-3.420
POWER EXCHANGE(IEX)	3.117	2.993	3.117	2.993
TO POWER EXCHANGE (IEX)	-167.585	-174.359	-167.585	-174.359
POWER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TO POWER EXCHANGE (PX)	-20.626	-21.462	-20.626	-21.462
TOTAL	1653.306	1553.322	1258.226	1154.347

C) AGENCY WISE BREAKUP OF ENERGY SCHEDULED DRAWL FROM THE GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
NTPC - NR	1374.095	1320.836	1206.209	1159.391
NTPC - ER	139.493	134.085	128.866	123.864
NHPC	65.078	62.571	65.078	62.571
NPC	57.812	55.574	57.812	55.574
SASAN	61.217	58.892	60.126	57.840
KOTESHWAR	7.739	7.439	7.739	7.439
MUNDRA_UMPP	0.000	0.000	0.000	0.000
NATHPA JHAKRI	17.402	16.729	12.835	12.339
TEHRI	20.867	20.058	20.867	20.058
TALA	1.071	1.029	1.071	1.029
JHAJJAR	253.310	243.504	57.284	55.080
TALCHER	0.000	0.000	0.000	0.000
DVC	123.027	121.565	121.565	116.903
UTTRANCHAL	0.000	0.000	0.000	0.000
HARYANA	0.000	0.000	0.000	0.000
CHATTISHGARH	1.871	1.834	1.834	1.760
DVC CTPS (BRPL)	0.000	0.000	0.000	0.000
DVC CTPS (BYPL)	0.000	0.000	0.000	0.000
DVC CTPS (NDPL)	0.000	0.000	0.000	0.000
METHON POWER (NDPL)-LT-06	167.992	165.999	165.999	159.554
DVC (FOR NDPL) LT-09	4.013	3.965	3.965	3.820
HARYANA (LT -05)	19.671	19.322	19.322	18.564
UTTAR PRADESH	22.197	21.677	21.677	20.837
ORISSA	0.000	0.000	0.000	0.000
POWER EXCHANGE(IEX)	3.117	2.993	3.117	2.993
POWER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TOTAL	2339.973	2258.073	1955.366	1879.616

D) AGENCY WISE BREAKUP OF ENERGY SCHEDULED BY NRLDC FOR EXPORT TO OTHER UTILITIES FROM DTL

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT POWER PERIPHERY
TO MEGHALAYA	-4.576	-4.668	-4.668	-4.848
TO ORISSA	0.000	0.000	0.000	0.000
TO UTTAR PRADESH	-21.588	-22.105	-22.105	-22.994
TO JAMMU & KASHMIR	-155.799	-159.064	-159.064	-165.504
TO ANDHRA	0.000	0.000	0.000	0.000
TO TRIPURA	0.000	0.000	0.000	0.000
TO MADHYA PRADESH	-38.071	-38.808	-38.808	-40.371
TO GUJRAT	0.000	0.000	0.000	0.000
TO RAJASTHAN	-77.842	-79.465	-79.465	-82.666
TO MAHARASHTRA	-4.667	-4.772	-4.772	-4.964
TO UTTRANCHAL	-108.928	-111.535	-111.535	-116.016
TO HIMACHAL PRADESH	-83.737	-85.225	-85.225	-88.665
TO WEST BENGAL	-3.248	-3.287	-3.287	-3.420
TO POWER EXCHANGE (IEX)	-167.585	-174.359	-167.585	-174.359
TO POWER EXCHANGE (PX)	-20.626	-21.462	-20.626	-21.462
TO SHARE PROJECT (HARYANA)	0.000	0.000	0.000	0.000
TO SHARE PROJECT (PUNJAB)	0.000	0.000	0.000	0.000
TOTAL	-686.667	-704.750	-697.140	-725.269
TOTAL SCHEDULED DRAWAL FROM THE GRID	1653.306	1553.322	1228.226	1154.347
TOTAL CONSUMPTION INCLUDING AUX. OF GENERATING STNs. EXCLUDING BTPS				1717.131
NET CONSUMPTION				1705.084
AVAILABILITY WITHIN DELHI				589.047
ACTUAL DRAWAL FROM THE GRID				1116.037
OVER DRAWAL(+)/UNDER DRAWAL(-) FROM THE GRID ON THE BASIS OF SCHEDULED ALLOCATION MADE BY NRLDC TO DELHI AT PERIPHERY				-38.310
LOAD SHEDDING				6.212
UNRESTRICTED DEMAND (GROSS)				1723.343
UNRESTRICTED DEMAND (NET)				1711.296
MAX. NET CONSUMPTION				63.299 ON 15.02.2014
MAX. LOAD SHEDDING				316MW ON 14.02.2014 AT 11.050HRS.
PEAK LOAD	Peak Demand during the month			SHEDDING AT PEAK TIME
DAY PEAK	3670MW AT 10.36.32HRS ON 16.02.2014			0 MW
EVENING PEAK	3370MW AT 19.00.00HRS ON 14.02.2014			37 MW
P.L.F. OF GENCO AND PRAGATI STNs.	RPH			6.54%
	GT			46.47%
	PRAGATI			88.67%
	RITHALA			0.00%
	BAWANA			1.51%
	Timarpur Okhla			68.33%

SHEDDING DETAILS DURING THE MONTH OF FEBRUARY 2014.

ALL FIGURES IN MUs

DATE	No. of Under Freq. Relay Operated	Shedding due to under frequency relay operation in MUs					Shedding due to Grid Restrictions (Over drawl / low freq.)			
		BSES		NDPL	NDMC	TOTAL	BSES		NDPL	NDMC
		BYPL	BRPL				BYPL	BRPL		
1	2	3	4	5	6	7=3 to 6	8	9	10	11
01-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.029	0.000
04-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000
05-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.044	0.000
06-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.000
07-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.094	0.214	0.007	0.000
09-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.024	0.002	0.000
10-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.008	0.006	0.000
11-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.017	0.016	0.000	0.000
13-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.375	0.372	0.000	0.000
15-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.029	0.024	0.000	0.000
16-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007	0.000
19-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.055	0.000
20-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.115	0.045	0.263	0.000
21-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.075	0.073	0.090	0.000
22-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.107	0.068	0.000	0.000
23-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.017	0.002	0.000
25-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.016	0.046	0.000
26-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.020	0.076	0.042	0.000
28-Feb-14	0	0.000	0.000	0.000	0.000	0.000	0.074	0.018	0.030	0.000
TOTAL	0	0.000	0.000	0.000	0.000	0.000	0.906	0.971	0.629	0.000

ALL FIGURES IN MU_s

Date	Shedding due to Transmission/Grid Constraints in Central Sector Stations / TTC / ATC VIOLATION				TOTAL	TOTAL SHEDDING DUE TO GRID RESTRICTIONS	Due to T&D Constraints				
	BSES		NDPL	NDMC			DTL				
	BYPL	BRPL					BSES		NDPL	NDMC	MES
			BYPL	BRPL							
	12	13	14	15	16=8to15	17=16+7	18	19	20	21	22
01-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.000	0.000	0.000
03-Feb-14	0.000	0.000	0.000	0.000	0.029	0.029	0.000	0.000	0.000	0.000	0.000
04-Feb-14	0.000	0.000	0.000	0.000	0.001	0.001	0.000	0.000	0.000	0.000	0.000
05-Feb-14	0.000	0.000	0.000	0.000	0.044	0.044	0.000	0.000	0.000	0.000	0.000
06-Feb-14	0.000	0.000	0.000	0.000	0.005	0.005	0.000	0.000	0.000	0.000	0.000
07-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08-Feb-14	0.000	0.000	0.025	0.000	0.340	0.340	0.000	0.000	0.000	0.000	0.000
09-Feb-14	0.063	0.000	0.093	0.000	0.182	0.182	0.000	0.000	0.002	0.000	0.000
10-Feb-14	0.005	0.008	0.072	0.000	0.099	0.099	0.000	0.000	0.000	0.000	0.000
11-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12-Feb-14	0.000	0.000	0.000	0.000	0.033	0.033	0.000	0.000	0.000	0.000	0.000
13-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14-Feb-14	0.093	0.056	0.173	0.000	1.069	1.069	0.000	0.000	0.015	0.000	0.000
15-Feb-14	0.000	0.000	0.000	0.000	0.053	0.053	0.000	0.000	0.000	0.000	0.000
16-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17-Feb-14	0.090	0.091	0.000	0.000	0.181	0.181	0.000	0.014	0.000	0.000	0.000
18-Feb-14	0.000	0.000	0.000	0.000	0.007	0.007	0.000	0.000	0.000	0.000	0.000
19-Feb-14	0.000	0.000	0.000	0.000	0.055	0.055	0.000	0.000	0.000	0.000	0.000
20-Feb-14	0.182	0.183	0.003	0.000	0.791	0.791	0.000	0.017	0.002	0.000	0.000
21-Feb-14	0.000	0.000	0.000	0.000	0.238	0.238	0.000	0.000	0.000	0.000	0.000
22-Feb-14	0.000	0.000	0.000	0.000	0.175	0.175	0.000	0.000	0.000	0.000	0.000
23-Feb-14	0.022	0.000	0.032	0.000	0.054	0.054	0.000	0.071	0.000	0.000	0.000
24-Feb-14	0.000	0.000	0.000	0.000	0.019	0.019	0.000	0.000	0.000	0.000	0.000
25-Feb-14	0.000	0.000	0.000	0.000	0.062	0.062	0.000	0.000	0.000	0.000	0.000
26-Feb-14	0.158	0.123	0.392	0.000	0.673	0.673	0.000	0.000	0.000	0.000	0.000
27-Feb-14	0.000	0.000	0.000	0.000	0.138	0.138	0.000	0.005	0.000	0.000	0.000
28-Feb-14	0.040	0.053	0.022	0.000	0.237	0.237	0.000	0.035	0.000	0.000	0.000
TOTAL	0.653	0.514	0.812	0.000	4.485	4.485	0.000	0.145	0.019	0.000	0.000

ALL FIGURES IN MUs


DATE	DUE TO T&D CONSTRAINTS				OTHER AGENCIES LIKE GENCO, BBMB, BTPS ETC.	THEFT PRONE SHEDDING			TOTAL SHEDDING DUE TO T&D CONSTS. & THEFT PRONE	GRAND TOTAL
	DISCOMS									
	BSES		NDPL	NDMC		BSES		NDPL		
	BYPL	BRPL				BYPL	BRPL			
1	23	24	25		26	27	28	29	30=18 to29	31=30+17
01-Feb-14	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.011	0.012	0.012
02-Feb-14	0.005	0.001	0.000	0.000	0.000	0.000	0.000	0.015	0.024	0.024
03-Feb-14	0.001	0.003	0.000	0.000	0.013	0.000	0.000	0.018	0.035	0.064
04-Feb-14	0.000	0.017	0.000	0.000	0.000	0.000	0.000	0.016	0.033	0.034
05-Feb-14	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.012	0.012	0.056
06-Feb-14	0.000	0.007	0.025	0.000	0.000	0.000	0.000	0.028	0.060	0.065
07-Feb-14	0.000	0.000	0.024	0.000	0.000	0.000	0.000	0.068	0.092	0.092
08-Feb-14	0.039	0.000	0.000	0.000	0.000	0.000	0.000	0.069	0.108	0.448
09-Feb-14	0.000	0.009	0.001	0.004	0.002	0.000	0.000	0.052	0.070	0.252
10-Feb-14	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.089	0.091	0.190
11-Feb-14	0.004	0.006	0.000	0.000	0.000	0.000	0.000	0.094	0.104	0.104
12-Feb-14	0.009	0.000	0.003	0.000	0.000	0.000	0.000	0.080	0.092	0.125
13-Feb-14	0.002	0.000	0.006	0.000	0.000	0.000	0.000	0.047	0.055	0.055
14-Feb-14	0.000	0.009	0.003	0.000	0.000	0.000	0.000	0.000	0.027	1.096
15-Feb-14	0.000	0.000	0.088	0.000	0.000	0.000	0.000	0.034	0.122	0.175
16-Feb-14	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.006	0.006
17-Feb-14	0.008	0.004	0.000	0.000	0.000	0.000	0.000	0.019	0.045	0.226
18-Feb-14	0.000	0.015	0.000	0.000	0.000	0.000	0.000	0.010	0.025	0.032
19-Feb-14	0.000	0.006	0.000	0.000	0.000	0.000	0.000	0.010	0.016	0.071
20-Feb-14	0.000	0.001	0.003	0.000	0.000	0.000	0.000	0.014	0.037	0.828
21-Feb-14	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.017	0.026	0.264
22-Feb-14	0.027	0.008	0.001	0.000	0.000	0.000	0.000	0.023	0.059	0.234
23-Feb-14	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.007	0.086	0.140
24-Feb-14	0.006	0.000	0.004	0.000	0.000	0.029	0.000	0.006	0.045	0.064
25-Feb-14	0.003	0.000	0.000	0.000	0.000	0.054	0.000	0.012	0.069	0.131
26-Feb-14	0.000	0.030	0.000	0.000	0.000	0.012	0.000	0.018	0.060	0.733
27-Feb-14	0.000	0.000	0.052	0.000	0.000	0.031	0.000	0.018	0.106	0.244
28-Feb-14	0.003	0.000	0.143	0.000	0.000	0.000	0.000	0.029	0.210	0.447
TOTAL	0.107	0.122	0.373	0.004	0.015	0.126	0.000	0.816	1.727	6.212

DATE	(NET CONS.)	MAXL DEMAND MET DURING THE DAY	TIME OF OCCURRENCE OF MAX DEMAND	SHEDDING AT THIS TIME	UN-RESTRICTED DEMAND	MAXIMUM UN-RESTRICTED DEMAND DURING THE DAY	TIME OF MAX. UN-REST. DEMAND	DEMAND AT THAT TIME	SHEDDING AT THAT TIME
	In Mus.	IN MW	IN HRS.	IN MW	IN MW	IN MW	HRS.	IN MW	IN MW
1	32	33	34	35	36=33+35	37=39+40	38	39	40
01-Feb-14	61.943	3622	10:01:35	0	3622	3622	10:01:35	3622	0
02-Feb-14	60.428	3621	10:30:47	0	3621	3621	10:30:47	3621	0
03-Feb-14	59.990	3484	09:56	0	3484	3484	09:56	3484	0
04-Feb-14	59.444	3475	09:54:45	0	3475	3475	09:54:45	3475	0
05-Feb-14	62.113	3445	09:50:28	0	3445	3445	09:50:28	3445	0
06-Feb-14	60.122	3404	09:52:25	0	3404	3404	09:52:25	3404	0
07-Feb-14	62.289	3514	09:47:09	0	3514	3514	09:47:09	3514	0
08-Feb-14	60.134	3478	09:52:59	0	3478	3478	09:52:59	3478	0
09-Feb-14	58.252	3501	10:21	0	3501	3501	10:21	3501	0
10-Feb-14	61.835	3481	10:13:19	0	3481	3481	10:13:19	3481	0
11-Feb-14	62.190	3446	09:33:29	13	3459	3459	09:33:29	3446	13
12-Feb-14	63.215	3552	10:06:32	10	3562	3562	10:06:32	3552	10
13-Feb-14	62.728	3496	09:35:06	0	3496	3496	09:35:06	3496	0
14-Feb-14	62.531	3597	10:39:51	0	3597	3597	10:39:51	3597	0
15-Feb-14	63.299	3626	10:23:41	5	3631	3631	10:23:41	3626	5
16-Feb-14	60.344	3670	10:36:32	0	3670	3670	10:36:32	3670	0
17-Feb-14	63.025	3642	09:44:10	0	3642	3642	09:44:10	3642	0
18-Feb-14	62.964	3562	10:04:56	0	3562	3562	10:04:56	3562	0
19-Feb-14	62.804	3578	10:04:56	0	3578	3578	10:04:56	3578	0
20-Feb-14	61.045	3527	10:10:17	0	3527	3527	10:10:17	3527	0
21-Feb-14	61.997	3605	09:51:34	0	3605	3605	09:51:34	3605	0
22-Feb-14	58.308	3461	10:21:03	36	3497	3497	10:21:03	3461	36
23-Feb-14	57.219	3410	10:43:20	8	3418	3418	10:43:20	3410	8
24-Feb-14	60.048	3470	10:00:32	0	3470	3470	10:00:32	3470	0
25-Feb-14	60.143	3318	10:04:56	0	3318	3318	10:04:56	3318	0
26-Feb-14	59.378	3377	10:37:46	0	3377	3377	10:37:46	3377	0
27-Feb-14	57.956	3435	09:47:19	13	3448	3477	10:00	3362	115
28-Feb-14	59.340	3393	09:19:33	12	3405	3405	09:19:33	3393	12
TOTAL	1705.084	3670 16.02.14	10:36:32	0	3670 16.02.14	3670	10:36:32	3670	0

10 **LOAD PATTERN OF DELHI ON THE DAY OF PEAK DEMAND MET DURING FEBRUARY 2014 ON 16.02.2014- 3670MW AT 10.36.32HRS.**

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1.00	1640	0	1640
2.00	1510	0	1510
3.00	1466	0	1466
4.00	1462	0	1462
5.00	1571	0	1571
6.00	1884	0	1884
7.00	2426	0	2426
8.00	3004	0	3004
9.00	3289	0	3289
10.00	3559	0	3559
10.36.32	3670	0	3670
11.00	3559	0	3559
12.00	3420	0	3420
13.00	3045	0	3045
14.00	2746	6	2752
15.00	2584	0	2584
16.00	2340	0	2340
17.00	2486	0	2486
18.00	2681	0	2681
19.00	3070	0	3070
20.00	3015	0	3015
21.00	2758	0	2758
22.00	2557	0	2557
23.00	2209	0	2209
24.00	1820	0	1820
TOTAL	60.344	0.006	60.350



11 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UN-RESTRICTED DEMAND DURING FEBRUARY 2014 ON 16.02.2014- 3670MW at 10.36.32HRS.


All figures in MW

Hrs.	Demand	Load Shedding	Un-Restricted Demand
1.00	1640	0	1640
2.00	1510	0	1510
3.00	1466	0	1466
4.00	1462	0	1462
5.00	1571	0	1571
6.00	1884	0	1884
7.00	2426	0	2426
8.00	3004	0	3004
9.00	3289	0	3289
10.00	3559	0	3559
10.36.32	3670	0	3670
11.00	3559	0	3559
12.00	3420	0	3420
13.00	3045	0	3045
14.00	2746	6	2752
15.00	2584	0	2584
16.00	2340	0	2340
17.00	2486	0	2486
18.00	2681	0	2681
19.00	3070	0	3070
20.00	3015	0	3015
21.00	2758	0	2758
22.00	2557	0	2557
23.00	2209	0	2209
24.00	1820	0	1820
TOTAL	60.344	0.006	60.350



12 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM ENERGY CONSUMED DURING FEBRUARY 2014 – 15.02.2014 – 63.299Mus All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1632	0	1632
2:00	1531	0	1531
3:00	1472	0	1472
4:00	1464	0	1464
5:00	1610	0	1610
6:00	2102	0	2102
7:00	2772	12	2784
8:00	3213	0	3213
9:00	3411	5	3416
10:00	3621	5	3626
11:00	3556	5	3561
12:00	3330	5	3335
13:00	3041	5	3046
14:00	2799	5	2804
15:00	2712	5	2717
16:00	2619	5	2624
17:00	2675	5	2680
18:00	2890	16	2906
19:00	3232	38	3270
20:00	3132	0	3132
21:00	2869	0	2869
22:00	2625	0	2625
23:00	2267	0	2267
24:00	1895	0	1895
TOTAL	63.299	0.175	63.474



13 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UNRESTRICTED ENERGY DEMAND DURING FEBRUARY 2014 – 14.02.2014 – 63.627 Mus


All figures in MW

Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1632	0	1632
2:00	1531	0	1531
3:00	1472	0	1472
4:00	1464	0	1464
5:00	1610	0	1610
6:00	2102	0	2102
7:00	2772	12	2784
8:00	3213	0	3213
9:00	3411	5	3416
10:00	3621	5	3626
11:00	3556	5	3561
12:00	3330	5	3335
13:00	3041	5	3046
14:00	2799	5	2804
15:00	2712	5	2717
16:00	2619	5	2624
17:00	2675	5	2680
18:00	2890	16	2906
19:00	3232	38	3270
20:00	3132	0	3132
21:00	2869	0	2869
22:00	2625	0	2625
23:00	2267	0	2267
24:00	1895	0	1895
TOTAL	62.531	1.096	63.627




14 LOAD DURATION CURVE FOR FEBRUARY 2014

Load in MW	Percentage of Time
Above 1100	100 %
Above 1300	99.58 %
Above 1500	87.49 %
Above 1700	79.76 %
Above 1900	75.64 %
Above 2100	72.08 %
Above 2300	68.77 %
Above 2500	63.29 %
Above 2700	48.14 %
Above 2900	34.71 %
Above 3100	24.31 %
Above 3300	11.4 %
Above 3500	1.78 %
Above 3700	0.01 %



FREQUENCY ANALYSIS FOR THE MONTH OF FEBRUARY 2014

Frequency Range in Hz.	Percentage of time
Above 49.25	100 %
Above 49.5	99.99 %
Above 49.75	99.77 %
Above 50	78.43 %
Above 50.25	12.08 %
Above 50.5	0.64 %
Above 50.75	0 %



16 VOLTAGE PROFILE OF 220 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2014

All figures in kV

Date	NARELA		GAZIPUR	
	Max	Min	Max	Min
01-Feb-14	233.82	220.15	233.05	212.41
02-Feb-14	233.95	222.99	233.82	217.70
03-Feb-14	234.08	221.83	232.66	216.41
04-Feb-14	232.79	221.83	220.82	214.09
05-Feb-14	234.34	222.09	231.37	217.09
06-Feb-14	234.34	222.34	230.21	210.09
07-Feb-14	235.11	222.34	232.79	213.44
08-Feb-14	234.34	222.21	232.15	211.25
09-Feb-14	234.98	223.38	233.18	218.60
10-Feb-14	234.98	221.44	233.82	209.96
11-Feb-14	233.95	219.12	234.24	218.60
12-Feb-14	233.95	219.51	234.98	--
13-Feb-14	234.47	221.57	234.60	218.86
14-Feb-14	234.72	224.28	235.11	219.51
15-Feb-14	236.40	224.15	236.40	217.96
16-Feb-14	235.63	222.86	235.24	218.86
17-Feb-14	236.82	221.83	236.27	218.35
18-Feb-14	235.89	219.25	235.37	218.47
19-Feb-14	233.43	218.47	234.60	217.06
20-Feb-14	232.40	219.51	233.82	218.60
21-Feb-14	232.15	217.83	233.82	218.22
22-Feb-14	234.08	220.15	236.01	--
23-Feb-14	234.47	221.18	236.40	221.83
24-Feb-14	233.82	219.51	235.89	219.51
25-Feb-14	234.08	218.47	234.08	215.77
26-Feb-14	233.05	216.67	234.34	213.96
27-Feb-14	233.69	217.57	234.60	--
28-Feb-14	236.01	219.89	238.21	--

17 VOLTAGE PROFILE OF 400 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2014
All figures in kV

Date	400kV Bamnauli Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb-14	424.19	01.18.06	395.12	09.28.04	412.84
02-Feb-14	424.19	04.01.25	404.26	10.16.56	415.24
03-Feb-14	423.72	--	403.09	--	412.33
04-Feb-14	421.38	01.33.43	401.45	10.46.58	412.63
05-Feb-14	423.72	03.33.04	402.15	10.10.17	412.28
06-Feb-14	423.25	02.01.37	400.98	10.12.56	412.32
07-Feb-14	425.36	03.03.04	399.34	08.34.04	412.73
08-Feb-14	423.25	00.53.06	398.40	10.05.40	412.01
09-Feb-14	424.90	03.59.06	404.49	09.08.46	413.75
10-Feb-14	424.43	03.31.51	400.98	09.27.20	412.57
11-Feb-14	423.72	04.33.31	394.41	09.33.29	411.50
12-Feb-14	423.72	03.33.27	394.88	09.57.31	411.15
13-Feb-14	424.19	03.46.56	401.68	10.10.39	413.56
14-Feb-14	426.54	02.27.52	406.37	10.04.49	416.17
15-Feb-14	427.47	03.00.56	405.20	10.48.03	415.48
16-Feb-14	426.07	04.00.51	403.09	09.09.18	416.68
17-Feb-14	427.47	03.12.57	400.98	07.15.42	414.95
18-Feb-14	425.36	03.24.15	401.68	09.46.15	413.41
19-Feb-14	423.25	03.24.15	398.40	09.46.15	411.35
20-Feb-14	420.91	04.01.48	403.32	10.26.58	411.86
21-Feb-14	433.02	04.01.56	400.74	07.25.36	412.84
22-Feb-14	426.30	03.34.01	399.57	18.48.30	413.37
23-Feb-14	423.02	04.01.48	399.57	08.47.54	413.07
24-Feb-14	422.59	00.01.11	397.23	09.57.42	409.72
25-Feb-14	422.79	03.24.15	394.65	09.46.15	409.55
26-Feb-14	423.25	04.00.25	391.13	09.52.34	409.34
27-Feb-14	423.25	01.57.25	393.47	12.41.39	408.78
28-Feb-14	424.43	02.10.11	397.93	18.26.11	409.93

All figures in kV

Date	400kV Bawana Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb-14	427.47	00.29.44	403.79	09.28.14	417.89
02-Feb-14	426.77	04.01.45	410.36	10.16.36	419.36
03-Feb-14	427.24	--	408.95	18.36.25	417.00
04-Feb-14	426.36	01.32.52	408.72	06.49.02	417.27
05-Feb-14	427.47	03.00.42	409.18	06.26.25	417.45
06-Feb-14	427.71	04.00.14	409.18	14.36.27	418.69
07-Feb-14	428.88	03.00.54	407.54	08.33.54	418.77
08-Feb-14	428.65	00.53.46	408.01	09.17.47	418.00
09-Feb-14	428.65	03.59.16	410.36	09.08.46	418.89
10-Feb-14	428.41	03.32.21	407.54	14.42.47	417.56
11-Feb-14	426.77	04.33.21	404.03	10.04.26	415.26
12-Feb-14	426.54	03.31.26	404.03	10.30.05	416.06
13-Feb-14	427.71	23.44.41	407.54	10.10.39	417.61
14-Feb-14	430.99	02.28.42	412.47	06.39.28	420.32
15-Feb-14	431.23	03.04.56	408.18	10.55.15	420.30
16-Feb-14	429.82	04.00.41	410.12	09.46.20	421.48
17-Feb-14	431.93	03.12.18	408.95	18.48.35	420.52
18-Feb-14	430.99	03.02.14	408.95	18.47.01	418.91
19-Feb-14	426.54	03.02.14	405.43	09.46.15	414.26
20-Feb-14	425.36	04.02.18	408.01	18.41.07	416.42
21-Feb-14	426.54	21.59.03	405.20	10.41.47	417.01
22-Feb-14	429.82	03.33.51	408.95	18.43.50	419.59
23-Feb-14	429.82	04.01.38	409.18	09.07.55	420.69
24-Feb-14	429.12	00.01.11	406.84	06.44.51	417.01
25-Feb-14	425.13	23.49.32	405.43	09.46.15	414.54
26-Feb-14	428.41	04.00.35	401.68	09.50.14	416.35
27-Feb-14	428.41	23.34.13	402.62	12.41.19	415.52
28-Feb-14	432.16	02.10.31	409.89	18.53.22	420.33

18 DETAILS OF LUMPED CAPACITORS AT NEAREST 220 KV SUBSTATION

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33KV	11KV	TOTAL
1	IP YARD		30		30
1	Kamla Market			16.35	16.35
2	Minto Road				0
3	GB Pant Hosp			15.88	15.88
4	Delhi Gate			10.9	10.9
5	Tilakmarg			5.04	5.04
7	Cannaught Place			10.08	10.08
8	Kilokri		10.08	10.48	20.56
9	NDSE				0
11	Nizamuddin				0
12	Exhibition-I				0
13	Exhibition-II				0
14	Defence Colony				0
15	IG Stadium		10.08	5.45	15.53
16	Lajpat Nagar				0
17	IP Estate			10.9	10.9
	LT BYPL				5.6
		0	50.16	85.08	140.84
2	Electric Lane				
1	Electric Lane			5.04	5.04
2	Scindia House			5.04	5.04
3	Raisina Road			10.08	10.08
4	Raja Bazar			10.08	10.08
	LT NDMC				12
		0	0	30.24	42.24
3	RPH Station		20		20
1	Lahori Gate			10.49	10.49
2	Jama Masjid			10.48	10.48
4	Kamla Market				0
5	Minto Road			10.9	10.9
6	GB Pant Hosp				0
7	IG Stadium				0
	LT BYPL				3
		0	20	31.87	54.87
4	Parkstreet S/stn	20	20		40
1	Shastri Park		10.896	5.45	16.346
2	Faiz Road			18.05	18.05
3	Motia Khan			16.3	16.3
4	Prasad Nagar			16.25	16.25
5	Anand Parbat			10.8	10.8
6	Shankar Road			5.04	5.04
7	Rama Road			0	0
8	Baird Road			10.08	10.08
9	Hanuman Road			5.04	5.04
10	Pusa			5.44	5.44
11	Ridge Valley			0	0
12	B. D. Marg			0	0
13	Nirman Bhawan			5.04	5.04
	LT BYPL			0	30.1
		20.00	30.90	97.49	178.486
5	Naraina S/stn		20	5.04	25.04
1	DMS			10.85	10.85
2	Mayapuri		10.87	10.4	21.27
3	Inderpuri		10	4.8	14.8
4	Rewari line				0
5	Khyber Lane		10.05		10.05
6	Kirbi Place		10.05		10.05
7	Payal			7.2	7.2
8	Saraswati Garden			10.88	10.88
		0	60.97	49.17	110.14

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
6	Mehrauli S/stn	80		5.04	85.04
1	Adchini			14.61	14.61
2	Andheria Bagh			10.85	10.85
3	IIT			10.9	10.9
4	JNU		10.03	10.03	20.06
5	Bijwasan			15.47	15.47
6	DC Saket			9.98	9.98
7	Malviya Nagar				0
8	C Dot			10.48	10.48
9	Vasant kunj B-Blk	21.79		10.9	32.69
10	Vasant kunj C-Blk	20.16		10.48	30.64
11	Palam				0
12	IGNOU			5.04	5.04
13	R. K. Puram-I			10.07	10.07
14	Vasant Vihar			19.25	19.25
15	Pusp Vihar			10.44	10.44
16	Bhikaji Cama Place		10.08	10.07	20.15
	LT BRPL				25
		121.95	20.11	163.61	330.67
7	Vasantkunj S/stn	40		5.04	45.04
1	R. K. Puram-II			10.08	10.08
2	Vasant kunj C-Blk				0
3	Vasant kunj D-Blk			9.63	9.63
4	Ridge Valley				0
	LT BRPL				33.2
		40	0	24.75	97.95
8	Okhla S/stn	60	10	5.04	75.04
1	Balaji			10.8	10.8
2	East of Kailash			15.89	15.89
3	Alaknanda			16.3	16.3
4	Malviya Nagar	21.79		10.85	32.64
5	Masjid Moth			16.3	16.3
6	Nehru Place			21.34	21.34
7	Okhla Ph-I	21.79		16.3	38.09
8	Okhla Ph-II		20.93	15.47	36.4
9	Shivalik			10.8	10.8
10	Batra			15.9	15.9
11	VSNL			10.9	10.9
12	Siri Fort			10.49	10.49
13	Tuglakabad			10.85	10.85
	LT BRPL				59
		103.58	30.93	187.23	380.74
9	Lodhi Road S/stn		20		20
1	Defence Colony		14.85		14.85
2	Hudco		10.9		10.9
3	Lajpat Nagar		10.9		10.9
4	Nizamuddin		10.44		10.44
5	Vidyut Bhawan				0
6	Ex. Gr. II				0
7	IHC				0
	LT BRPL				42
		0	67.09	0	109.09
10	Sarita Vihar S/stn	20		5.04	25.04
1	Sarita Vihar			10.07	10.07
2	MCIE			10.06	10.06
3	Mathura Road	20.16		11.69	31.85
4	Jamia Millia			10.89	10.89
5	Sarai Julena		10.08	16.29	26.37
6	Jasola			5.44	5.44
	LT BRPL				23.6
		40.16	10.08	69.48	143.32

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
11	Wazirabad				
1	Bhagirathi		14.4	10.9	25.3
2	Ghonda	21.79	22.56	15.94	60.29
3	Seelam Pur		10.08	21.39	31.47
4	Dwarkapuri			15.46	15.46
5	Nandnagri	20.16		16.35	36.51
6	Yamuna Vihar			16.2	16.2
7	East of Loni Road			10.8	10.8
8	Shastri Park			10.9	10.9
9	Karawal Nagar			5.4	5.4
10	Sonia Vihar			7.2	7.2
	LT BYPL				10
		41.95	47.04	130.54	229.53
12	Geeta Colony				
1	Geeta Colony				0
2	Kanti Nagar			10.49	10.49
3	Kailash Nagar			10.9	10.9
4	Seelam Pur			15.48	15.48
5	Shakar Pur				0
	LT BYPL				5.8
		0	0	36.87	42.67
13	Gazipur S/stn	40		5.04	45.04
1	Dallupura	28.8		10.9	39.7
2	Vivek Vihar			9.57	9.57
3	GT Road			10.85	10.85
4	Kondli	20.16		10.85	31.01
5	MVR-I			10.9	10.9
6	MVR-II	20.16		10.9	31.06
7	PPG Ind. Area			10.06	10.06
	LT BYPL				20.6
		109.12	0	79.07	208.79
14	Patparganj S/stn	40	20	5.04	65.04
1	GH-I	19.89		10.45	30.34
2	GH-II	20.09		10.9	30.99
3	CBD		10.03	15.48	25.51
4	Guru Angad Nagar			15.49	15.49
5	Karkadooma		10.8	10.44	21.24
6	Preet Vihar			10.07	10.07
7	CBD-II			10.8	10.8
8	Shakarpur			10.8	10.8
9	Jhilmil			10.8	10.8
10	Dilshad Garden	20.16		16.35	36.51
11	Khichripur	21.79		10.49	32.28
12	Mother Dairy				0
13	Scope Building				0
14	Vivek Vihar				0
15	Akhardham			14.6	14.6
	LT BYPL				23.3
		121.93	40.83	151.71	337.77
15	Najafgarh S/stn	60		5.04	65.04
1	A4 Paschim Vihar			10.8	10.8
2	Nangloi	21.73		15.84	37.57
3	Nangloi W/W	20.89		10.85	31.74
4	Pankha Road			15.88	15.88
5	Jaffarpur			15.43	15.43
7	Inst. Area Janakpuri			17.6	17.6
8	Paschimpuri		10.05	15.47	25.52
9	Paschim Vihar	41.83		15.43	57.26
10	Mukherjee Park			20.83	20.83
11	Udyog Nagar			10.43	10.43
12	Choukhandi			10.07	10.07
	LT BRPL				27
		144.45	10.05	163.67	345.17

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
16	Pappankalan-I S/stn	20		5.04	25.04
1	Bindapur Grid G-3 PPK	21.73		15.85	37.58
2	Bodella-I	20.1		16.24	36.34
3	Bodella-II	21.73		17.64	39.37
4	DC Janakpuri			10.03	10.03
5	G-2 PPK			10.8	10.8
6	G-5 PPK			15.51	15.51
7	G-6 PPK			5.4	5.4
8	G-15 PPK			10.8	10.8
9	Harinagar	21.18		16.25	37.43
10	Rewari line			5.44	5.44
	LT BRPL				13.5
		104.74	0	129	247.24
17	BBMB Rohtak Road				
1	S.B. Mill			10.07	10.07
2	Rama Road			10.88	10.88
3	Ram Pura			10.48	10.48
4	Rohtak Road			8.04	8.04
5	Vishal			10.4	10.4
6	Tri Nagar			5.44	5.44
7	Madipur			10.43	10.43
8	Sudershan Park			10.08	10.08
9	Kirti Nagar			5.44	5.44
		0	0	81.26	81.26
18	Shalimarbagh S/stn		40	6	46
1	S.G.T. Nagar			5.44	5.44
2	Wazirpur-1			17.18	17.18
3	Wazirpur-2			11.39	11.39
4	Ashok Vihar			5.44	5.44
5	Rani Bagh			10.88	10.88
6	Haiderpur			11.39	11.39
7	SMB FC			5.44	5.44
8	SMB KHOSLA			5.44	5.44
	LT TPDDL				30
		0	40	78.6	148.6
19	Subzimandi S/stn			6	6
1	Shakti Nagar			5.94	5.94
2	Gulabibagh			10.88	10.88
3	Shahzadabagh			13.68	13.68
4	DU			5.44	5.44
5	Tripolia			10.88	10.88
	B. G. Road			5.4	5.4
	LT BYPL				0.9
	LT TPDDL				20
		0	0	58.22	79.12
20	Narela S/stn	40		5.04	45.04
1	A-7 Narela			10.88	10.88
2	AlR Kham pur			6	6
3	Ashok vihar			10.48	10.48
4	Azad Pur			5.44	5.44
5	Tri Nagar			5.44	5.44
6	Badli	20		5.95	25.95
7	DSIDC Narela-1			5.95	5.95
8	GTK			5.44	5.44
9	Jahangirpuri	20	10	0	30
10	Bhalswa			3.6	3.6
	LT TPDDL				10
		80	10	64.22	164.22

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
21	Gopalpur S/stn		30	5.04	35.04
1	Azad Pur			10.88	10.88
2	Hudson Lane			5.44	5.44
3	Wazirabad			2.4	2.4
4	Indra Vihar			5.44	5.44
6	GTK Road			5.94	5.94
7	Jahangirpuri		10	5.95	15.95
8	Civil lines			5.44	5.44
9	Pitam Pura-1			5.44	5.44
10	Pitam Pura-3			5.44	5.44
11	Air Khampur			5.95	5.95
12	SGT Nagar			5.95	5.95
13	Tiggipur			10.88	10.88
	LT TPDDL				29
		0	40	80.19	149.19
22	Rohini S/stn	40		6	46
1	Rohini Sec-22			10.88	10.88
2	Rohini Sec-23	20		5.44	25.44
3	Rohini Sec-24			5.44	5.44
4	Rohini-1			5.44	5.44
5	Rohini-3			5.95	5.95
6	Rohini-4			11.39	11.39
7	Rohini-5			11.39	11.39
8	Rohini-6			5.95	5.95
9	Mangolpuri-1			16.83	16.83
10	Mangolpuri-2	20		5.94	25.94
11	Pitam Pura-1	20		5.04	25.04
12	Pitam Pura-2			10.48	10.48
13	Rohini DC-1			14.4	14.4
	LT TPDDL				30
		100	0	120.57	250.57
23	Kanjhawala S/stn	20		5.04	25.04
1	Bawana Clear Water			10.88	10.88
2	Pooth Khoord			5.44	5.44
		20	0	21.36	41.36
24	BAWANA S/stn				
1	Bawana S/stn No. 6			10.88	10.88
2	Bawana S/stn No. 7				0
		0	0	10.88	10.88
25	Kashmeregate S/stn			5.04	5.04
1	Civil lines			5.44	5.44
2	Town Hall			8.64	8.64
3	Fountain			5.45	5.45
	LT BYPL				2.7
		0	0	24.57	27.27
26	Pappankalan-II				
1	DMRC-I				0
2	DMRC-II				0
27	Trauma Center (AIIMS)				
1	AIIMS		13.26	5.04	18.3
2	Trauma Center			10.08	10.08
3	Netaji Nagar			15.12	15.12
4	Sanjay Camp			10.08	10.08
5	Kidwai Nagar			5.04	5.04
6	SJ Airport			5.04	5.04
	Race Course			5.04	5.04
		0	13.26	55.44	68.7

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
28	MUNDKA				
	Rohini-2			11.39	11.39
	LT BRPL				18.5
		0	0	11.39	29.89
29	DSIDC BAWANA				
	DSIDC NRL-1	20			20
	DSIDC NRL-2			10.88	10.88
		20	0	10.88	30.88
30	RIDGE VALLEY				
	Keventry Diary			10.08	10.08
	Nehru Park			5.04	5.04
	Bapu Dham			10.08	10.08
		0	0	25.2	25.2
31	IP EXTN (PRAGATI)				
	Vidyut Bhawan			10.08	10.08
	Dalhousie Road			5.04	5.04
	School Lane			5.04	5.04
	LT NDMC				12.29
		0	0	20.16	32.45
	TOTAL CAPACITY	1067.9	491.4	2092.7	4139

Utility	HT	LT	Total
BYPL	864	102	966
TPDDL	657	119	776
NDMC	180	24	204
DTL	754	0	754
BRPL	1158	242	1400
RPH	20	0	20
MES	20	0	20
TOTAL	3652	487	4139

20 DETAILS OF BREAK-DOWNS DURING THE MONTH OF FEBRUARY 2014

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
1	01-02-14	11:08	GOPALPUR 220/33kV 100MVA Tx-III	01-02-14	12:57	NEUTRAL CT BLAST TR. TRIPPED MANUALLY
2	02-02-14	20:14	220kV SARITA VIHAR - BTPS CKT.-II	03-02-14	12:20	AT BTPS NO TRIPPING AT SARITA VIHAR CKT. TRIPPED ON DIST. PROT, Y PHASE, DIST PROT, DIST. 2KMS.
3	02-02-14	20:14	220kV SARITA VIHAR - BTPS CKT.-I	03-02-14	12:20	AT BTPS END NO TRIPPING, AT SARITA VIHAR CKT. TRIPPED ON DIST. PROT, Y PHASE , 186A, 186B
4	03-02-14	02:30	ROHINI-II 220/66kV 160MVA Tx-I	03-02-14	13:07	TR. TRIPPED ON LOW GAS PRESSURE, 86B, ALONGWITH 66KV I/C-I TRIPPED ON 86B
5	07-02-14	15:17	220kV KANJHAWALA-NAJAFGARH CKT	07-02-14	19:18	CKT. TRIPPED ON Z-1, DIST. RELAY ABC, DIST. 6.1714KM
6	09-02-14	11:05	220kV Maharani Bagh- Electric Lane Ckt-II	09-02-14	15:50	AT MAHARANI BAGH : CKT. TRIPPED ON 186R, 286R, 86AB AT ELECT LANE : CKT. TRIPPED ON 86B
7	09-02-14	17:00	OKHLA 220/33kV 100MVA Tx-IV	09-02-14	21:09	TR. TRIPPED ON CTR, MASTER RELAY, 86, 86, 164LV SIDE, 33KV I/C-IV TRIPPED ON 86 LV SIDE
8	09-02-14	17:22	KANJHAWALA 220/66kV 100MVA Tx-II	09-02-14	17:31	TR. TRIPPED ON 86 RELAY
9	10-02-14	14:43	KANJHAWALA 220/66kV 100MVA Tx-I	10-02-14	15:50	TR. TRIPPED ON BUCHOLZ
10	10-02-14	15:54	KANJHAWALA 220/66kV 100MVA Tx-I	10-02-14	18:20	TR. TRIPPED ON BUCHOLZ
11	11-02-14	16:07	OKHLA 33kV NEHRU PLACE CKT-I	11-02-14	16:30	CKT. TRIPPED DUE TO TRIPPING OF 100MVA PR. TR. - V
12	11-02-14	16:07	OKHLA 33kV ALAKNANDA CKT-II	11-02-14	16:30	CKT. TRIPPED DUE TO TRIPPING OF 100MVA PR. TR. - V
13	11-02-14	16:07	OKHLA 33kV EAST OF KAILASH CKT	11-02-14	16:30	CKT. TRIPPED DUE TO TRIPPING OF 100MVA PR. TR. - V
14	11-02-14	16:07	OKHLA 220/33kV 100MVA Tx-V	12-02-14	14:40	TR. TRIPPED ON DIFFERENTIAL
15	11-02-14	16:28	220kV BAMNAULI-PAPPANKALAN-II CKT-I	11-02-14	16:36	CKT. TRIPPED ON DIST PROT. BUT CVT AVAILABLE
16	11-02-14	18:50	INDRAPRASTHA POWER 220/33kV 100MVA Tx-III	12-02-14	14:10	TR. MADE OFF MANUALLY DUE TO SPARKING OBSERVED IN NCT EARTHING STRIP CLAMP
17	13-02-14	04:59	220kV Maharani Bagh- Electric Lane Ckt-II	13-02-14	10:12	CKT. TRIPPED ON DC FAILURE, 86 RELAY RESET.
18	14-02-14	03:35	220kV PRAGATI - I.P. CKT - I	14-02-14	18:11	AT I.P. CKT. TRIPPED ON DIST. PROT. ZONE-2, RYB PHASE, R PHASE LA DAMAGED & RYB PHASE DISC INSULATOR BROKEN AT PRAGATI CKT. TRIPPED ON DIST PROT, ZONE-2, 1.91KM
19	14-02-14	05:33	ELECTRIC LANE 220/33kV 100MVA Tx-II	14-02-14	17:36	TR. TRIPPED ON OSR, GROUP B, 295AC, 86AB, 33KV I/C-II TRIPPED ON 86A, 86B
20	14-02-14	11:02	220KV WAZIRABAD - MANDOLA CKT-II	14-02-14	11:24	AT MANDOLA CKT. TRIPPED ON POLE DISCREPANCY ON RELAY PANEL CKT. WAS CHARGED FROM WAZIRABAD END
21	14-02-14	15:08	220kV ROHINI-SHALIMARBAGH CKT-I	14-02-14	15:25	CKT. TRIPPED ON 96A, 186A
22	14-02-14	15:08	220KVBAWANA- ROHINI CKT-I	14-02-14	15:27	AT ROHINI CKT. TRIPPED ON 96A, AUTO RECLOSE, 186A, CVT AVAILABLE
23	14-02-14	15:08	ROHINI 220/66kV 100MVA Tx-I	14-02-14	15:25	TR. TRIPPED ON 96
24	14-02-14	15:56	ROHINI 220/66kV 100MVA Tx-I	15-02-14	18:40	TR. TRIPPED ON 96 AUTO RECLOSE
25	14-02-14	15:56	220kV ROHINI-SHALIMARBAGH CKT-I	14-02-14	19:00	AT ROHINI CKT. TRIPPED ON 186 A&B
26	14-02-14	16:19	220KVBAWANA- ROHINI CKT-I	14-02-14	18:40	AT ROHINI CKT TRIPPED ON 96 BUS BAR PROT. RELAY
27	15-02-14	01:31	220kV Maharani Bagh- Electric Lane Ckt-I	15-02-14	01:41	AT MAHARANI BAGH CKT. TRIPPED ON OVER VOLTAGE
28	15-02-14	01:41	220kV Maharani Bagh- Electric Lane Ckt-II	15-02-14	07:32	AT MAHARANIBAGH CKT. TRIPPED ON OVER VOLTAGE AT ELECTRIC LANE CVT DISAPPEAR

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
29	15-02-14	01:41	220kV MAHARANIBAGH-MASJID MOTH CKT-II	15-02-14	07:32	AT MAHARANIBAGH CKT. TRIPPED ON OVER VOLTAGE AT MASJID MOTH CVT DISAPPEAR
30	15-02-14	15:06	WAZIRABAD 66/11kV, 20MVA Tx-III	15-02-14	16:00	TR. TRIPPED ON 86, REF 64, RLV, DIFFERENTIAL
31	15-02-14	15:40	220kV MEHRAULI - BTPS CKT. - I	15-02-14	15:59	AT MEHRAULI CKT. TRIPPED ON ACTIVE GROUP, ABC PHASE, DIST. PROT. ZONE-2, DIST. 15.14KMS. AT BTPS CKT. TRIPPED ON B PHASE, E/F
32	17-02-14	15:16	OKHLA 220/66kV 100MVA Tx-II	17-02-14	15:36	66KV I/C-II TRIPPED ON 51 NX
33	20-02-14	18:01	OKHLA 66/11kV, 20MVA Tx-II	21-02-14	20:00	TR. TRIPPED ON 86, R PHASE CT DAMAGE
34	20-02-14	18:30	NAJAFGARH 66/11kV, 20MVA Tx-II	20-02-14	19:18	TR. TRIPPED ON O/C, 86
35	20-02-14	19:23	MUNDKA 220/66kV 160MVA Tx-II	20-02-14	19:30	TR. TRIPPED ON 86B RELAY
36	20-02-14	20:05	220KV WAZIRABAD - MANDOLA CKT-II	20-02-14	21:47	CKT. TRIPPED ON DIST. PROT, DIST. NO DATA, FUSE FAIL
37	22-02-14	12:25	OKHLA 66kV OKHLA PHASE-I CKT-II	22-02-14	12:35	WHILE ARRANGEING S/D OF 66KV BUS-2 CKT TRIPPED ON D/P,Z-1 DUE TO PT FUSE FAILURE.
38	22-02-14	12:25	OKHLA 66kV OKHLA PHASE-I CKT-I	22-02-14	12:35	WHILE ARRANGEING S/D OF 66KV BUS-2 CKT TRIPPED ON D/P,Z-1 DUE TO PT FUSE FAILURE.
39	23-02-14	06:29	NAJAFGARH 66/11kV, 20MVA Tx-II	23-02-14	19:02	TX TRIPPED ON DIFFERENTIAL PROTECTION(87).
40	23-02-14	23:22	WAZIRABAD 66/11kV, 20MVA Tx-III	24-02-14	09:26	TX TRIPPED ON 86 ALONG WITH I/C-3.
41	24-02-14	17:38	220KV WAZIRABAD - MANDOLA CKT-II	24-02-14	18:05	AT WZB CKT TRIPPED ON D/P,RY&B-PH,Z-1,DIST-1.2KM. AT MDL CKT TRIPPED ON D/P,R&Y-PH,Z-1,DIST-1.2KM.
42	25-02-14	12:20	220KV PRAGATI - SARITA VIHAR CKT	25-02-14	14:59	AT SARITA VIHAR CKT TRIPPED ON D/P, A/R, AB&C-PH, Z-1, DIST-0.966KM. NO TRIPPING AT PRAGATI
43	25-02-14	12:27	220KV MAHARANI BAGH - SARITA VIHAR CKT	25-02-14	14:55	AT MAHARANIBAGH CKT TRIPPED D/P, R,Y&B-PH,Z-2&3, DIST-9.8KM. NO TRIPPING AT SARITA VIHAR.
44	27-02-14	11:39	220kV OKHLA - BTPS CKT.- I	27-02-14	20:16	AT OKHLA CKT TRIPPED ON 67NX,86. NO TRIPPING AT BTPS. JUMPER SNAPPED AT T NO.-20
45	27-02-14	12:06	PRAGATI 220/66kV 160MVA Tx-I	27-02-14	12:45	TX TRIPPED ON 30D(OLTC OSR),SPR,30B(OIL TEMP.HIGH),30C (WINDING TEMP. HIGH),86. 66KV I/C-1 TRIPPED ON 86.
46	27-02-14	12:06	PRAGATI 220/66kV 160MVA Tx-II	27-02-14	13:08	TX TRIPPED ON 30D(OLTC OSR),SPR,30B(OIL TEMP.HIGH),30C (WINDING TEMP. HIGH),86. 66KV I/C-1 TRIPPED ON 86.
47	28-02-14	01:58	220kV Maharani Bagh- Electric Lane Ckt-I	28-02-14	02:23	CKT TRIPPED WITHOUT INDICATION.
48	28-02-14	02:10	220kV Maharani Bagh- Electric Lane Ckt-I	28-02-14	03:04	CKT TRIPPED ON GENERAL TRIP.
49	28-02-14	02:10	220kV MAHARANIBAGH-MASJID MOTH CKT-I	28-02-14	10:15	CKT TRIPPED ON TC-1,Y&B-PH FAULTY,TC-2,Y&B-PH FAULTY
50	28-02-14	03:07	220kV MAHARANIBAGH-MASJID MOTH CKT-II	28-02-14	07:28	AT M BAGH CKT TRIPPED ON RY&B-PH GENERAL TRIP.
51	28-02-14	03:27	ROHINI-II 220/66kV 160MVA Tx-I	28-02-14	16:00	TX TRIPPED ON 86.
52	28-02-14	19:04	220kV BAMNAULI-PAPPANKALAN-I CKT-II	28-02-14	23:57	CKT TRIPPED WITHOUT INDICATION. CB PRESSURE LOW.

20 DETAILS OF UNDER FREQUENCY RELAY OPERATIONS IN DELHI POWER SYSTEM DURING THE MONTH OF FEBRUARY 2014

DATE	S. N.	TIME		Name of Grid	NAME OF AFFECTED FEEDERS	MODE	LOAD RELIEF IN MW
		OUT	IN				
				NIL			