

# **DELHI TRANSCO LTD.**

STATE LOAD DISPATCH CENTER

## **PROGRESS REPORT**

\*\*\*\*\*

**FEBRUARY 2015**

<b>S. No.</b>	<b>CONTENTS</b>	<b>Page No.</b>
<b>1.</b>	<b>Salient Features of Delhi Power System</b>	<b>3</b>
<b>2.</b>	<b>Performance of Generating Stations within Delhi</b>	<b>4</b>
<b>3.</b>	<b>Details of Outage of Generating Stations within Delhi</b>	<b>5-21</b>
<b>4.</b>	<b>Allocation of Power to Delhi from unallocated quota of central sector</b>	<b>22-26</b>
<b>5.</b>	<b>Allocation of Power to Discoms</b>	<b>27</b>
<b>6.</b>	<b>Power Availability Demand Position of Delhi at the time of occurrence of Peak Demand</b>	<b>28</b>
<b>7.</b>	<b>Power Availability Demand Position of Delhi at the time of occurrence of Maximum Un-Restricted Demand</b>	<b>29</b>
<b>8.</b>	<b>Source wise scheduled drawl from grid and Availability within Delhi</b>	<b>30-32</b>
<b>9.</b>	<b>Shedding Details</b>	<b>33-36</b>
<b>10.</b>	<b>Load Curve for the Day of Peak Demand</b>	<b>37</b>
<b>11.</b>	<b>Load Curve for the day of occurrence of Maximum Un-Restricted Demand</b>	<b>38</b>
<b>12.</b>	<b>Load Curve for the day of Maximum Energy Consumed</b>	<b>39</b>
<b>13.</b>	<b>Load Curve for the day of Maximum Un-Restricted Energy Demand</b>	<b>40</b>
<b>14.</b>	<b>Load Duration Curve</b>	<b>41</b>
<b>15.</b>	<b>Frequency Analysis</b>	<b>42</b>
<b>16.</b>	<b>Voltage Profile for significant 220kV Sub-Stations</b>	<b>43</b>
<b>17.</b>	<b>Voltage Profile for significant 400kV Sub-Stations</b>	<b>44-45</b>
<b>18.</b>	<b>Details of Capacitors Installations in Delhi</b>	<b>46-51</b>
<b>19.</b>	<b>Tripping Details of 400/220 KV System in Delhi Power System</b>	<b>52-53</b>
<b>20.</b>	<b>Details of Under frequency Relay operations in Delhi Power System</b>	<b>54</b>

**SALIENT FEATURES OF DELHI POWER SYSTEM**

<b>Sr. No.</b>	<b>Features</b>	<b>FEBRUARY 2014</b>	<b>FEBRUARY 2015</b>
<b>1</b>	<b>Effective Generation Capacity within Delhi in MW</b>		
	Rajghat Power House	135	135
	Gas Turbine	270	270
	Pragati Power Corporation Ltd.	330	330
	Badapur Thermal Power Station	705	705
	Rithala GT	108	108
	Bawana	1118	1372
	TOWMCL	16	16
	Total	2682	2936
<b>2</b>	<b>Maximum Unrestricted Demand (MW)</b>	<b>3670</b>	<b>3847</b>
	Date	16.02.2014	06.02.2015
	Time	10.36.32	10.09.58
<b>3</b>	<b>Peak Demand met (MW)</b>	<b>3670</b>	<b>3847</b>
	Date	16.02.2014	06.02.2015
	Time	10.36.32	10.09.58
4	Peak Availability (MW)	3489	3783
5	Shortage (-) / Surplus (+) in MW	(-) 181	(-) 64
6	Percentage Shortage (-) / Surplus (+)	(-) 4.93	(-) 1.66
7	Maximum Energy Consume in a day (Mus)	63.299	65.588
8	Energy Consumed during the month	<b>1705.084</b>	<b>04.02.2015</b>
<b>9</b>	<b>Load Shedding in Mus</b>		
A)	Due to Grid Restrictions		
i)	Under Frequency Relay Operations	0.000	0.007
ii)	Manual Load shedding from DTL S/Stns.	0.000	0.000
iii)	Load Shedding due to low frequency / Low Voltage / TTC/ATC Violation		
	NDPL	1.246	0.047
	BRPL	1.376	0.099
	BYPL	1.426	0.011
	NDMC	0.000	0.000
	MES	0.000	0.000
iv)	Due to transmission Constraints in Central Sector	0.437	0.050
	<b>Total due to Grid Restriction</b>	<b>4.485</b>	<b>0.214</b>
B)	Due to Constraints in System in Mus		
	DTL	0.164	0.018
	NDPL	1.189	0.267
	BRPL	0.122	0.160
	BYPL	0.233	0.106
	NDMC	0.004	0.000
	MES	0.000	0.000
	Other Agencies	0.015	0.002
	<b>Total</b>	<b>1.727</b>	<b>0.553</b>
<b>11</b>	<b>Grand Total in Mus</b>	<b>6.212</b>	<b>0.767</b>

2. PERFORMANCE OF GENERATING STATIONS WITHIN DELHI DURING FEBRUARY 2015

A) For the month of February 2015

All Figures in MUs

S. No	Stations	Gross Generation	Aux. Consumption	Net Generation	Availability (%)	Backing Down
1.	RPH	27.634	4.882	22.752	26.81	0.694
2.	GT	59.419	1.806	57.613	74.41	78.566
3.	PPCL	113.669	2.741	110.928	105.26	123.884
4.	BTPS	119.208	11.22	107.988	99.25	325.920
5.	Rithala	0.000	0.056	-0.056	<b>86.10</b>	55.104
6.	Bawana	198.970	6.267	192.703	--	486.797
7.	Towmcl	10.968	1.599	9.409	--	--
	<b>TOTAL</b>	<b>529.868</b>	<b>28.571</b>	<b>501.337</b>	--	<b>1070.965</b>

B) For the Year 2013-14 (Upto February 2015)

Power Station	Effective Capacity (MW)	Net Generation in MUs for Feb. 2015	Availability (%) for Feb 2015	PLF (%) for Feb 2015	Cumulative Generation in MUs upto Feb 2015 for the year 2014-15	Cumulative Availability in % upto Feb 2015 for the year 2014-15	Cumulative PLF in % upto Feb 2015 for the year 2014-15
RPH	135	22.752	26.81	26.78	337.039	58.87	34.71
GT	270	57.613	74.41	31.31	848.063	67.89	40.10
PPCL	330	110.928	105.26	49.65	1675.284	83.64	64.99
BTPS	705	107.988	99.25	24.62	2813.301	86.88	55.30
Rithala	108	-0.056	<b>86.10</b>	0.00	-0.657	<b>87.91</b>	<b>0.00</b>
Bawana	1372	192.703	--	21.60	1961.302	--	--
Towmcl	16	9.409	--	102.01	104.842	--	--
<b>TOTAL</b>	<b>2936</b>	<b>501.337</b>	--	--	<b>7739.174</b>	--	--

## 1. RPH

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	67.5	04.11.13	12.00	16.04.14	10.50	Stopped due to low demand and high frequency
		04.05.14	10.35	07.05.14	03.10	Boiler tube leakage
		07.05.14	15.35	07.05.14	16.20	Loss of fuel
		07.05.14	16.40	07.05.14	19.25	Loss of fuel
		10.05.14	22.30	10.05.14	23.20	Flame failure
		13.05.14	10.45	14.05.14	15.10	Stopped due to low demand and high frequency
		14.05.14	15.40	14.05.14	16.25	Drum level low
		14.05.14	17.30	14.05.14	17.55	Excitation failure
		22.05.14	09.20	22.05.14	10.45	Turbine trip
		22.05.14	22.25	23.05.14	00.50	Flame failure
		23.05.14	22.30	24.05.14	00.00	Turbine trip
		24.05.14	00.50	24.05.14	01.20	Furnance pressure very high
		30.05.14	16.55	31.05.14	00.00	Unit tripped due to grid disturbance
		31.05.14	00.15	31.05.14	02.30	Drum level low
		09.06.14	13.15	09.06.14	19.25	Unit tripped due to 220kV supply fail
		21.06.14	18.00	21.06.14	20.05	Unit tripped due to 220kV supply fail
		23.06.14	01.40	23.06.14	04.05	Unit tripped due to 220kV supply fail
		25.06.14	05.00	25.06.14	09.25	Unit tripped due to 220kV supply fail
		02.07.14	14.05	02.07.14	16.10	Unit tripped due to 220kV supply failure
		03.07.14	12.05	05.07.14	17.15	Boiler tube leakage
		18.07.14	03.20	18.07.14	06.20	Tripped due to turbine trip
		12.08.14	01.20	16.08.14	20.30	Stopped due to low demand and high frequency
		17.08.14	11.30	19.08.14	23.00	Stopped to attend boiler tube leakage
		22.08.14	10.05	22.08.14	12.20	Unit tripped due to flame failure
		23.08.14	12.20	23.08.14	22.20	Desynchronised due to heavy water leakage from spary line.
		16.09.14	04.45	16.09.14	17.25	Unit tripped due to furnance pr high
		20.09.14	03.10	20.09.14	04.10	
		20.09.14	22.45	22.09.14	23.05	Boiler tube leakage
		26.09.14	10.15	02.01.15	14.40	Tripped due to flame failure , later on Stopped due to low demand and high frequency from 01.10.2014
		02.01.15	17.20	02.01.15	18.05	Unit tripped due to loss of fuel
		03.01.15	06.40	03.01.15	07.10	Unit tripped due to turbine trip
		03.01.15	14.55	03.01.15	19.55	Unit tripped due to loss of fuel
		04.01.15	11.30	04.01.15	11.55	Unit tripped due to loss of fuel
		05.01.15	01.50	05.01.15	03.10	Unit tripped due to furnance preseure very high
		09.01.15	12.30	09.01.15	15.35	Unit tripped due to loss of fuel
		16.01.15	23.35	17.01.15	00.05	Unit tripped due to loss of fuel
		21.01.15	12.30	21.01.15	13.05	Unit tripped due to drum level low
		23.01.15	17.50	24.01.15	06.40	Unit desynchronized due to boiler spary line burst
		25.01.15	09.40	27.01.15	10.15	Unit tripped due to leakage in CW line
		10.02.15	06.25	10.02.15	07.15	Unit tripped due to flame failure
		10.02.15	07.45	10.02.15	08.10	
		11.02.15	11.20	11.02.15	12.05	Unit tripped due to loss of fuel
		20.02.15	18.05	20.02.15	19.50	Unit tripped due to drum level low
		22.05.15	10.50	22.05.15	13.25	Unit tripped due to furnance preseure very high
		22.02.15	13.55	22.02.15	14.20	Unit tripped due to both FD fan tripped
		22.02.15	15.00	22.02.15	15.30	Unit tripped due to drum level very high
22.05.15	16.30	22.05.15	16.55	Unit tripped due to furnance preseure very high		
24.02.15	08.15	24.02.15	09.40	Unit tripped due to furnance preseure high		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	67.5	15.03.14	18.00	16.04.14	04.40	Stopped due to low demand and high frequency
		27.04.14	19.30	05.05.14	01.25	Desynchronized on ETD due to fire hazard at boiler corder no. 4
		14.05.14	18.45	17.05.14	17.50	Stopped due to low demand and high frequency
		30.05.14	16.55	30.05.14	23.30	Unit tripped due to grid disturbance
		04.06.14	00.20	05.06.14	00.45	Boiler tube leakage
		07.06.14	11.00	07.06.14	12.05	Turbine trip
		09.06.14	13.15	09.06.14	15.50	Unit tripped due to 220kV supply fail
		21.06.14	18.00	21.06.14	22.50	
		23.06.14	01.40	23.06.14	08.30	
		25.06.14	05.05	25.06.14	07.50	
		02.07.14	14.05	02.07.14	15.50	
		05.07.14	10.10	06.07.14	00.25	Tripped due to condenser vaccum low
		06.07.14	12.15	13.07.14	00.10	Boiler tube leakage
		16.07.14	10.30	16.07.14	11.05	Unit tripped due to UAT oil level low
		18.07.14	08.00	21.07.14	11.10	Boiler tube leakage
		06.08.14	18.10	08.08.14	24.00	Boiler tube leakage
		09.08.14	00.00	12.08.14	23.40	Stopped due to low demand and high frequency
		22.08.14	18.00	30.08.14	00.50	Boiler tube leakage
		10.09.14	04.45	10.09.14	05.45	Unit tripped due to furnance pr high
		11.09.14	20.10	16.09.14	20.40	Boiler tube leakage
		25.09.14	12.45	25.09.14	14.10	Unit tripped due to DC control supply failure
		27.09.14	00.45	27.09.14	01.25	Tripped due to turbine trip
		27.09.14	06.40	27.09.14	07.15	Unit tripped due to condansor vaccume low
		28.09.14	01.00	28.09.14	04.35	Unit tripped due to drum level high
		28.09.14	13.40	28.09.14	14.55	Unit tripped due to 220kv supply failure
		01.10.14	00.15	29.12.14	23.59	Stopped due to low demand and high frequency
		30.12.14	00.00	28.02.15	23.59	Major overhauling

## (B) Gas Turbine

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	27.03.14	13.10	15.04.14	18.28	Stopped due to low demand and high frequency
		15.04.14	18.38	15.04.14	19.45	Machine tripped due to grid disturbance
		14.06.14	02.02	16.04.14	08.01	Stopped due to low demand and high frequency
		16.04.14	18.15	23.04.14	19.45	
		04.05.14	10.05	04.05.14	13.45	Stopped due to LTTH High
		25.05.14	03.31	26.05.14	18.02	Stopped due to low demand and high frequency
		27.05.14	12.16	28.05.14	20.11	
		30.05.14	16.55	30.05.14	17.30	Machine came on FSNL due to grid disturbance.
		02.06.14	03.27	02.06.14	05.55	Due to tripping of 20 MVA Tr. Machine tripped
		03.06.14	19.02	03.06.14	20.21	Due to tripping of 6.6 KV Bus Coupler machine came on FSNL
		09.06.14	13.12	09.06.14	13.42	Machine came on FSNL as the 220 KV Bus became dead at IP Ext end.
		13.06.14	23.10	14.06.14	01.45	Tripped on loss of excitation
		14.06.14	01.45	16.06.14	12.49	Stopped due to low demand and high frequency
		18.06.14	09.10	18.06.14	11.20	Tripped on loss of excitation
		21.06.14	17.56	21.06.14	18.48	Due to Heavy Jerk (Due to 220 KV Pragati-Sarita Vihar line tripped)
		25.06.14	05.00	25.06.14	06.10	Machine tripped due to failure of Grid
		25.06.14	14.55	25.06.14	15.10	Due to Jerk both 160 MVA Tx. Tripped
		30.06.14	05.02	30.06.14	06.05	machine tripped due to failure of auxiliary Supply
		30.06.14	13.32	30.06.14	17.06	Stopped as per SLDC as generation not required in OC mode
		02.07.14	14.02	02.07.14	14.58	Machine tripped due to both 160MVA Trfs. tripped from 220 KVA side.
		06.07.14	14.15	07.07.14	12.15	Stopped due to low demand and high frequency
		07.07.14	12.15	07.07.14	17.08	Machine could not be taken on load due to leakage of oil.
		09.07.14	17.20	10.07.14	17.10	Machine tripped due to tripping of AOP.
		10.07.14	17.35	10.07.14	18.34	Machine tripped due to loss of excitation.
		17.07.14	21.16	18.07.14	03.45	Stopped due to low demand and high frequency
		18.07.14	03.45	18.07.14	12.45	Due to failure of auxillary supply
		18.07.14	12.45	19.07.14	18.32	Stopped due to low demand and high frequency
		25.07.14	08.01	31.07.14	07.58	
		04.08.14	19:18	06.08.14	13:51	
		06-08-14	15:20	06-08-14	17:40	
		07-08-14	09:46	19-08-14	11:40	
		28-08-14	17:54	20-09-14	17.12	
04-10-14	17:45	08-11-14	11.22			
08.11.14	22.30	14.11.14	10.28			
14.11.14	19.25	17.11.14	08.18			
17.11.14	17.20	19.11.14	09.07			
19.11.14	21.35	27.12.14	12.55			
27.12.14	17.40	28.02.15	23.59			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	30	01.02.14	17.00	28.02.15	23.59	Machine stopped due to high vibration

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	27.03.14	16.38	15.04.14	17.50	Stopped due to low demand and high frequency
		15.04.14	18.38	15.04.14	19.05	Machine tripped due to grid disturbance
		18.04.14	17.47	18.04.14	18.55	Tripped on electrical trouble normal shutdown
		06.05.14	11.00	06.05.14	15.05	Stopped due to LTTH High
		06.05.14	15.15	06.05.14	17.30	
		07.05.14	10.46	07.05.14	19.31	
		12.05.14	17.21	12.05.14	18.05	Tripped on loss of flame
		13.05.14	00.22	13.05.14	00.54	Stopped due to low demand and high frequency
		13.05.14	20.25	22.05.14	12.10	
		25.05.14	00.58	25.05.14	01.26	
		30.05.14	16.55	30.05.14	17.25	Due to trid disturbance machine came on FSNL
		04.06.14	14.47	04.06.14	16.10	Machine tripped due to Middle section of Base radiator punctured due to falling of angle from APRDS Floor
		09.06.14	13.12	09.06.14	13.36	Machine came on FSNL as the 220 KV Bus became dead at IP Ext end.
		20.06.14	21.02	30.06.14	12.50	Machine started but could not be taken on load due to failure of diesel Engine
		02.07.14	14.02	02.07.14	14.58	Machine came on FSNL both 160MVA Trfs. tripped from 220 KVA side.
		17.07.14	21.14	18.07.14	03.45	Stopped due to low demand and high frequency
		18.07.14	03.45	19.07.14	17.22	Due to failure of auxillary supply
		31.07.14	00.12	31.07.14	15.24	Machine tripped as both 160 MVA Tr-I & II tripped
		04-08-14	14:05	06-08-14	10:22	Stopped due to low demand and high frequency
		06-08-14	15:22	16-08-14	14:45	
		16-08-14	21:31	28-08-14	17:10	
		11-10-14	16:44	14-10-14	12:10	
		14-10-14	14:33	12.11-14	14.54	
		13.11.14	12.55	21.11.14	12.44	
		14.12.14	01.52	14.12.14	02.50	Machine tripped due to high TAD
		15.12.14	18.50	11.01.15	16.25	Stopped due to low demand and high frequency
		12.01.15	13.51	12.01.15	16.12	Machine tripped due to C&I problem
		27.01.15	00.55	27.01.15	10.35	Machine on FSNL due to exhaust temp high at 01.15hrs. machine tripped during fault rectification by C&I Deptt.
		07.02.15	05.17	07.02.15	12.30	Machine tripped due to heavy jerk
		07.02.15	12.30	17.02.15	10.45	Stopped due to low demand and high frequency



Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	30	27.03.14	18.30	06.06.14	12.30	Machine is under shutdown for HGPI
		09.06.14	13.12	09.06.14	13.34	Machine came on FSNL as the 220 KV Bus became dead at IP Ext end.
		21.06.14	17.56	21.06.14	19.05	Came on FSNL due to tripping of 160 MVA Tr-1 & II.
		25.06.14	05.01	25.06.14	06.45	Came on FSNL due to tripping of 160 MVA Tr-1 & II.
		25.06.14	08.45	25.06.14	17.26	Machine could not be taken on load due Diode Rotating diode fault fault on protection panel.
		30.06.14	05.30	30.06.14	06.10	machine tripped due to failure of auxiliary Supply
		02.07.14	14.02	02.07.14	14.47	Machine came on FSNL both 160MVA Trfs. tripped from 220 KVA side.
		17.07.14	23.46	18.07.14	03.45	Machine tripped due to both 160MVA Trfs. tripped .
		18.07.14	03.45	18.07.14	12.42	Due to failure of auxiliary supply
		29.07.14	09.45	31.07.14	03.14	Stopped due to low demand and high frequency
		31.07.14	04.50	31.07.14	06.35	Machine tripped as both 160 MVA Tr-I & II tripped
		04-08-14	19:09	06-08-14	10:28	Stopped due to low demand and high frequency
		06-08-14	13:01	16-08-14	14:47	
		16-08-14	21:32	27-08-14	11:08	
		05-10-14	17:20	11-10-14	15:58	
		14-10-14	18:50	30-11-14	18.40	
		13.11.14	12.30	15.11.14	11.20	
		15.11.14	11.50	21.11.14	16.50	
		28.11.14	18.31	28.11.14	20.03	Machine stopped due to LLVT high
		15.12.14	15.28	11.01.15	14.52	Stopped due to low demand and high frequency
04.02.15	12.05	17.02.15	15.32			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	12.04.14	09.50	12.04.14	10.41	Machine tripped due to grid disturbance
		15.04.14	18.38	15.04.14	18.48	
		07.05.14	13.30	13.05.14	18.50	Machine tripped due to LTTH High . After that it is not available due to problem in Diesel engine.
		25.05.14	00.58	25.05.14	01.30	Due to trid disturbance machine came on FSNL
		30.05.14	16.55	30.05.14	19.15	
		06.06.14	02.35	06.06.14	11.30	Stopped due to low demand and high frequency
		06.06.14	11.30	06.06.14	17.15	Machine tripped on high Exhaust temperature.
		09.06.14	13.12	09.06.14	13.20	Machine came on FSNL as the 220 KV Bus became dea at IP Ext end.
		20.06.14	10.50	20.06.14	10.56	machine came on FSNL due to tripping of 7.5 MVA Auxiliary Transformer due to jerk.
		21.06.14	17.56	21.06.14	18.31	Machine came on FSNL as the 220 KV Bus became dea at IP Ext end.
		25.06.14	05.01	25.06.14	08.45	Machine came on FSNL as the 220 KV Bus became dea at IP Ext end.
		25.06.14	08.45	25.06.14	11.02	machine could not be taken on load due to starting device trip.
		25.06.14	14.45	25.06.14	18.09	Machine tripped as the 220 KV Bus became dea at IP Ext end.
		26.06.14	02.46	26.06.14	15.13	Stopped due to low demand and high frequency
		29.06.14	00.05	30.06.14	17.10	
		01.07.14	01.45	02.07.14	17.08	
		03.07.14	02.45	03.07.14	15.40	
		17.07.14	23.46	18.07.14	03.45	Machine tripped due to both 160MVA Trfs. tripped .
		18.07.14	03.45	18.07.14	12.52	Due to failure of auxillary supply
		31.07.14	00.12	31.07.14	00.46	Machine tripped as both 160 MVA Tr-I & II tripped
		31.07.14	04.50	01-08-14	14:44	Machine tripped as both 160 MVA Tr-I & II tripped and not taken on load due to no demand from SLDC
		01-08-14	16:48	07-08-14	14:50	Stopped due to low demand and high frequency
		31-08-14	13:45	09-09-14	19:18	
		20-09-14	12:15	04.10.14	13.25	
		12.11.14	18.18	28.11.14	20.03	
		19.11.14	14.49	19.11.14	21.50	
		21.11.14	16.20	15.12.14	10.32	
		16.12.14	02.03	17.12.14	16.22	
		20.12.14	14.33	20.12.14	14.46	Machine came on FSNL due to working of DTL personnel in llanding pannel in GTPS resulting both 160MVA TxS tripped.
		27.12.14	13.05	27.12.14	17.35	machine stopped as no schedule on OC mode
		30.12.14	18.40	30.12.14	19.38	Tripped due to failure of Mark-IV supply and machine tripped on exhaust thermocouple open trip alarm.
		13.01.15	14.45	13.01.15	17.35	Machine tripped due to malfunctioning of C&I message
07.02.15	05.17	07.02.15	07.48	Machine tripped due to heavy jerk		
17.02.15	15.00	28.02.15	23.59	Stopped due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	12.04.14	09.50	12.04.14	09.55	Machine tripped due to grid disturbance
		15.04.14	18.38	15.04.14	18.50	
		30.05.14	16.55	30.05.14	17.23	Due to trid disturbance machine came on FSNL
		02.06.14	03.27	02.06.14	04.10	Due to tripping of 20 MVA Tr. Machine came on FSNL
		03.06.14	19.02	03.06.14	20.07	Due to tripping of 6.6 Bus Coupler machine came on FSNL
		06.06.14	02.32	06.06.14	11.30	Stopped due to low demand and high frequency
		06.06.14	11.30	06.06.14	18.00	machine not taken on load due to problem in Diesel Engine
		06.06.14	18.00	11.06.14	11.45	Stopped due to low demand and high frequency
		21.06.14	17.56	21.06.14	18.42	Machine came on FSNL as the 220 KV Bus became dea at IP Ext end.
		25.06.14	05.01	25.06.14	05.28	Machine came on FSNL as the 220 KV Bus became dea at IP Ext end.
		25.06.14	14.45	25.06.14	15.10	Came on FSNL due to tripping of 160 MVA Tr-1& II.
		26.06.14	02.47	26.06.14	18.02	
		29.06.14	00.02	30.06.14	17.41	
		01.07.14	01.50	02.07.14	17.01	Stopped due to low demand and high frequency
		03.07.14	02.45	03.07.14	11.25	
		03.07.14	15.52	04.07.14	17.10	
		17.07.14	23.46	18.07.14	01.56	Machine came on FSNL both 160MVA Trfs. Tripped.
		18.07.14	02.10	18.07.14	13.29	Due to failure of auxillary supply
		20.07.14	08.16	22.07.14	11.14	
		29.07.14	09.45	04-08-14	11:14	
		05-08-14	03:07	05-08-14	09:43	
		30-08-14	09:15	09-09-14	19:22	
		20-09-14	12:17	05-10-14	16:09	Stopped due to low demand and high frequency
		14-10-14	12:50	14-10-14	18:04	
		12.11.14	19.38	13.11.14	13.59	
		21.11.14	18.06	15.12.14	15.50	
		20.12.14	14.33	20.12.14	14.46	Machine came on FSNL due to working of DTL personnel in llanding pannel in GTPS resulting both 160MVA Txs tripped.
		16.01.15	08.35	16.01.15	08.56	Machine tripped on generator breakes tripped and combustion troublealarm appeared
		27.01.15	23.32	04.02.15	11.04	Stopped due to low demand and high frequency
		07.02.15	05.17	07.02.15	07.20	Machine tripped due to heavy jerk
17.02.15	17.15	28.02.15	23.59	Stopped due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-1	30	27.03.14	13.20	15.04.14	23.36	Stopped due to low demand and high frequency
		15.04.14	23.39	16.04.14	00.38	Gen. class A trip
		16.04.14	00.52	16.04.14	12.20	
		16.04.14	16.20	16.04.14	22.00	Turbine shaft vibration very high
		16.04.14	22.00	23.04.14	22.54	Stopped due to low demand and high frequency
		24.04.14	02.30	24.04.14	04.02	Turbine shaft vibration very high at bearing no 3
		24.04.14	05.30	24.04.14	11.35	
		26.04.14	14.40	26.04.14	15.22	
		01.05.14	20.40	02.05.14	05.45	Machine manually tripped due to heavy abnormal sound in CEP
		04.05.14	10.10	04.05.14	15.30	G.T. stopped due to LTTH High, so STG stopped
		06.05.14	17.20	06.05.14	21.30	Machine tripped due to Oil pressure problem
		12.05.14	22.18	12.05.14	23.10	Tripped on Trip oil pressure very low
		14.05.14	12.05	14.05.14	14.58	Tripped on Class A relay and 40G relay operated
		25.05.14	00.58	25.05.14	03.30	Tripped due to grid disturbance
		25.05.14	03.30	25.05.14	21.30	machine under shutdown due to truning gear problem
		25.05.14	21.30	26.05.14	21.05	Stopped due to low demand and high frequency
		27.05.14	08.46	27.05.14	17.30	Machine tripped due to low vacuum
		27.05.14	17.30	28.05.14	23.52	Stopped due to low demand and high frequency
		29.05.14	09.20	29.05.14	10.07	Tripped on trip oil pressure very low
		29.05.14	12.38	29.05.14	14.04	
		30.05.14	16.55	30.05.14	19.05	Tripped due to grid disturbance
		02.06.14	03.27	02.06.14	07.03	Due to tripping of 20 MVA Tr. Machine tripped
		03.06.14	19.02	03.06.14	22.07	Due to tripping of 6.6 Bus Coupler machine tripped
		09.06.14	13.12	09.06.14	14.40	Machine came on FSNL as the 220 KV Bus became dead at IP Ext end.
		13.06.14	23.10	14.06.14	02.15	Machine tripped due to tripping of GT#1 on loss of Excitation.
		14.06.14	02.15	16.06.14	15.18	Stopped due to low demand and high frequency
		18.06.14	09.10	18.06.14	12.50	Machine tripped due to tripping of GT#1 on loss of Excitation.
		20.06.14	10.50	20.06.14	17.20	machine tripped due to tripping of 7.5 MVA Auxiliary Trr due to jerk.
		21.06.14	17.56	21.06.14	20.28	Due to Heavy Jerk,GT and STG tripped
		25.06.14	05.01	25.06.14	07.40	Due to Jerk machine tripped
		25.06.14	14.45	25.06.14	16.13	Due to Jerk both 160 MVA Tx. Tripped
		30.06.14	05.02	30.06.14	23.56	Machine tripped due to tripping of Auxilairy Transformer.
		01.07.14	12.13	01.07.14	13.10	Machine tripped due to jerk,bus coupler of 6.6KV bus bar tripped
		02.07.14	14.02	02.07.14	16.00	Machine tripped due to both 160MVA Trs. tripped
		06.07.14	14.15	07.07.14	12.15	Stopped due to low demand and high frequency
		07.07.14	12.15	07.07.14	19.30	Machine could not be taken on load due to non availability of GT#1.
		09.07.14	17.20	10.07.14	20.08	Machine tripped due to tripping of AOP of GT#1..
		12.07.14	21.40	12.07.14	22.30	Machine tripped due to failure of Auxiliary supply
		17.07.14	21.16	18.07.14	03.45	Stopped due to low demand and high frequency
		18.07.14	03.45	18.07.14	12.45	Due to failure of auxillary supply
		18.07.14	12.45	19.07.14	20.35	Stopped due to low demand and high frequency
		25.07.14	08.01	31.07.14	14.10	
04-08-14	19:11	06-08-14	19:33			
06-08-14	19:44	06-08-14	23:26	Stopped due to oil leakage in servo motor.		

<b>STG-1</b>	<b>30</b>	06-08-14	23:32	12-08-14	12:00	Stopped due to oil leakage in servo motor.
		12-08-14	12:00	16-08-14	20:15	Stopped due to low demand and high frequency
		16-08-14	20:15	16-08-14	22:15	Problem in DC EOP
		16-08-14	22:15	19-08-14	14:55	Stopped due to low demand and high frequency
		28-08-14	17:54	20-09-14	12:15	
		20-09-14	12:15	20-09-14	20:15	Machine could not be taken due to water leakage in HRSG#1
		24-09-14	04:17	24-09-14	05:18	Tripped due to Trip oil pressure very low
		04-10-14	17:45	11-10-14	13:00	Stopped due to low demand and high frequency
		11-10-14	13:00	08-11-14	19.10	Machine stopped due to bearing inspection.
		08.11.14	19.35	14.11.14	15.35	Stopped due to low demand and high frequency
		14.11.14	16.46	17.11.14	16.29	
		17.11.14	17.05	19.11.14	13.52	
		19.11.14	16.05	19.11.14	19.30	Machine tripped due to exhaust steam temp. Very high
		19.11.14	21.35	28.02.15	23.59	Stopped due to low demand and high frequency

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG -2	30	27.03.14	16.45	16.04.14	01.50	Stopped due to low demand and high frequency
		18.04.14	17.47	18.04.14	20.40	Machine tripped due to tripping of G.T.
		06.05.14	11.05	06.05.14	23.59	G.T. stopped due to LTTH high, so STG stopped
		07.05.14	10.46	07.05.14	23.10	
		12.05.14	17.22	12.05.14	19.05	Tripped due to tripping of G.T. (machine running on single G.T.)
		13.05.14	00.22	13.05.14	01.40	
		13.05.14	20.25	22.05.14	15.50	Stopped due to low demand and high frequency
		25.05.14	00.58	25.05.14	02.05	Tripped due to grid disturbance
		30.05.14	00.01	30.05.14	23.56	Machine not available due to non availability of DC EOP
		02.06.14	03.27	02.06.14	06.12	Due to tripping of 20 MVA Tr. Machine tripped
		04.06.14	10.20	04.06.14	10.38	Machine tripped due to malfunction of MS-14 valve
		04.06.14	14.47	04.06.14	16.48	STG tripped due to tripping of GT#3 .
		09.06.14	13.12	09.06.14	14.25	Machine tripped due to Grid disturbance
		17.06.14	18.43	17.06.14	19.28	Machine tripped on low vacuum as drum pr could not be maintained due to tripping of BFP-2A.
		20.06.14	10.50	20.06.14	11.50	Machine tripped due to tripping of Auxilairy Transformer.
		21.06.14	17.56	21.06.14	20.35	Due to Heavy Jerk,GT and STG tripped
		22.06.14	02.00	22.06.14	03.09	Machine tripped on Turbine RJB shaft vibration very high.
		25.06.14	05.01	25.06.14	08.45	Machine tripped due to failure of Grid
		25.06.14	08.45	25.06.14	19.28	machine could not be taken as both GT 3 & 4 were not available
		30.06.14	05.30	30.06.14	07.06	Machine tripped due to tripping of Auxilairy Transformer.
		01.07.14	12.13	01.07.14	14.01	Machine tripped due to jerk,bus coupler of 6.6KV bus bar tripped
		02.07.14	13.58	02.07.14	15.10	Machine tripped due to heavy jerk occurred in control room.
		12.07.14	11.24	12.07.14	12.45	Machine tripped on low vacuum as Auxiliary supply failed to CEP & BFP due to tripping of 6.6 KV Bus Coupler
		17.07.14	23.46	18.07.14	03.45	Machine tripped due to both 160MVA Trfs. tripped .
		18.07.14	03.45	18.07.14	15.53	Due to failure of auxillary supply
		23.07.14	09.19	23.07.14	11.38	Machine tripped due to malfunctioning of relay.
		31.07.14	00.12	31.07.14	08.40	Machine tripped as both 160 MVA Tr-I & II tripped
		04-08-14	19:11	06-08-14	15:00	Stopped due to low demand and high frequency
		06-08-14	15:00	08-08-14	10:45	Machine not taken due to problem in ESV
		08-08-14	10:45	16-08-14	19:15	Stopped due to low demand and high frequency
		16-08-14	19:15	26-08-14	21:45	Not available due to problem in ESV
		26-08-14	21:45	27-08-14	13:48	Stopped due to low demand and high frequency
		27-08-14	13:53	27-08-14	14:48	Tripped due to false alarm of housing vibration.
		14-10-14	18:50	12.11.14	17.58	Stopped due to low demand and high frequency
		13.11.14	04.02	13.11.14	04.29	Machine tripped due to exhaust steam pr. Very high (Low vacuum)
		13.11.14	12.20	13.11.14	13.29	Machine tripped on low vacuum. CEP 2A tripped and other CEP-2B was under PTW.
		14.11.14	07.25	14.11.14	08.56	Machine tripped on low vacuum. CEP 2A tripped and other CEP-2B was under PTW.
		14.11.14	11.36	14.11.14	12.55	Machine tripped on hot well level very high.
		14.11.14	12.55	21.11.14	16.18	Stopped due to low demand and high frequency
		28.11.14	18.31	28.11.14	20.03	Machine tripped due to LLVT high
		15.12.14	18.50	11.01.15	17.30	Stopped due to low demand and high frequency
		11.01.15	20.42	11.01.15	22.58	Machine tripped due to C&I Problem
		15.01.15	15.22	15.01.15	15.50	Machine tripped due to trip oil pressure very low alarm, axial shift pre trip alarm shown in BCD.
22.01.15	09.55	22.01.15	10.37	Machine tripped due to RJB shaft vibration.		
07.02.15	05.17	07.02.15	12.30	Stopped due to low demand and high frequency		
07.02.15	12.30	07.02.15	14.50	Machine tripped due to exhaust steam temp. Very high		
17.02.15	16.22	17.02.15	17.12	Stopped due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-3	30	12.04.14	09.50	12.04.14	11.34	Machine tripped due to grid disturbance
		15.04.14	18.38	15.04.14	21.15	
		10.05.14	17.45	10.05.14	19.08	Machine tripped due to card malfunction
		25.05.14	00.58	25.05.14	02.15	Machine tripped due to grid disturbance
		30.05.14	16.55	30.05.14	18.25	
		02.06.14	03.27	02.06.14	05.07	Due to tripping of 20 MVA Tr. Machine tripped
		03.06.14	09.12	11.06.14	10.59	Machine stopped due to Fire at Bearing No.#1
		21.06.14	17.56	21.06.14	21.30	Due to Heavy Jerk,GT and STG tripped
		25.06.14	05.01	25.06.14	08.05	Machine tripped due to failure of Grid
		25.06.14	14.05	25.06.14	22.27	Machine tripped manually due to fire observed at bearing #1.
		26.06.14	01.51	26.06.14	21.43	
		27.06.14	02.50	27.06.14	11.45	
		27.06.14	12.56	28.06.14	12.00	
		28.06.14	13.10	05.07.14	21.43	Machine not available due to leakage of oil from bearing#1
		09.07.14	22.15	09.07.14	23.10	Machine tripped due to class-A relay tripped.Relays 86X
		12.07.14	11.24	12.07.14	12.03	Machine tripped on low vaccum as Auxilliary supply failed to CEP & BFP due to tripping of 6.6 KV Bus Coupler
		17.07.14	23.46	18.07.14	03.45	Machine tripped due to both 160MVA Trs. tripped .
		18.07.14	03.45	18.07.14	14.42	Due to failure of auxillary supply
		31.07.14	00.12	31.07.14	03.52	Machine tripped as both 160 MVA Tr-I & II tripped
		31.07.14	04.50	31.07.14	23.59	Machine tripped as both 160 MVA Tr-I & II tripped and not taken on load due to no demand from SLDC
		01-08-14	00:00	04-08-14	13:58	Stopped due to low demand and high frequency
		04-08-14	15:38	04-08-14	16:20	Machine tripped due to following relays operation-86GA1,86GB1 & Aux. relay-60AX
		04-08-14	16:35	04-08-14	19:03	Stopped due non availability of both BFPs.
		31-08-14	13:45	10-09-14	00:58	Stopped due to low demand and high frequency
		20-09-14	12:17	26-09-14	15:30	Machine stopped due to condenser cleaning
		26-09-14	15:30	04-10-14	17:32	Stopped due to low demand and high frequency
		08-10-14	15:38	08-10-14	18:16	Machine tripped suddenly when all parameters were normal. Its vaccum fell suddenly from 0.86 at 15:37 hrs to 0.74 at 15:38 hrs. on checking at site it was found that vaccum breake valve opened up. Two numbers fuses were found burnt in vaccum breaker MCC.
		20-10-14	15:40	20-10-14	16:21	Machine tripped on vacuum tank level high false alm due to malfunctioning of switch.
		03.11.14	12.20	03.11.14	13.25	Machine tripped suddenly due to LLVT tank very high alarm in CCT monitor but alarm not appeared on BCD.
		05.11.14	10.05	05.11.14	12.20	Machine tripped due to ESV closed alarm in CRT,found oil leakage at turbine floor on secondary oil line.
		12.11.14	19.38	13.11.14	16.12	Stopped due to low demand and high frequency
		21.11.14	18.10	15.12.14	23.59	
		15.12.14	15.59	15.12.14	18.10	Machine tripped due to drum level high
20.12.14	14.33	20.12.14	15.30	Machine tripped due to working of DTL personnel in llanding pannel in GTPS resulting both 160MVA TxS tripped.		
07.02.15	05.17	07.02.15	11.58	Machine tripped due to heavy jerk		
17.02.15	17.15	28.02.15	23.59	Stopped due to low demand and high frequency		

## (C) PRAGATI

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	104	24.04.14	17.21	24.04.14	21.14	Tripped On internal fault
		24.04.14	21.35	24.04.14	23.26	Tripped on internal fault
		28.04.14	00.00	28.04.14	10.00	Stopped due to less demand and high frequency
		28.04.14	10.00	18.06.14	15.06	Stopped for MI
		21.06.14	11.11	22.06.14	22.11	To attend leakage after planned shutdown of MI
		25.06.14	05.01	25.06.14	06.00	Tripped due to grid disturbance
		02.07.14	14.05	02.07.14	15.34	Tripped due to grid disturbance
		11.07.14	14.15	11.07.14	14.45	Tripped on internal fault
		21.07.14	20.13	21.07.14	21.50	
		22.07.14	15.26	22.07.14	16.11	
		23.07.14	00.00	23.07.14	04.24	Stopped to attend internal fault
		14.11.14	20.05	12.12.14	16.59	Stopped due to less demand and high frequency
		12.01.15	21.00	20.01.15	12.26	
		02.02.15	12.10	04.02.15	12.02	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	104	08.04.14	08.58	27.04.14	22.31	Stopped for CI
		02.05.14	15.29	02.05.14	16.59	Tripped on internal fault
		04.05.14	15.37	04.05.14	16.39	
		25.05.14	00.58	25.05.14	02.50	Tripped due to grid disturbance
		14.06.14	13.35	14.06.14	14.06	Tripped on internal fault
		06.07.14	17.14	06.07.14	18.04	Tripped due to grid disturbance
		10.11.14	20.00	14.11.14	10.48	Stopped due to shutdown desired by DTL
		02.12.14	00.20	02.12.14	01.09	Tripped on internal fault
		02.12.14	08.53	02.12.14	11.10	Tripped on internal fault
		12.12.14	08.18	12.12.14	09.40	Tripped on internal fault
		12.12.14	18.54	23.12.14	05.47	Stopped due to less demand and high frequency
		29.12.14	21.18	29.12.14	23.46	Tripped on internal fault
		11.01.15	16.00	19.01.15	06.00	Stopped due to less demand and high frequency
		20.01.15	14.05	27.01.15	06.03	Unit stopped as desired by DTL to attend hot spot and further Stopped due to less demand and high frequency
		04.02.15	13.53	28.02.15	23.59	Stopped due to less demand and high frequency



Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	122	11.04.14	11.04	11.04.14	11.57	STG tripped on internal fault
		16.04.14	00.00	19.05.14	02.43	STG stopped for bearing inspection and condenser chemical cleaning.
		25.05.14	00.58	25.05.14	03.53	Tripped due to grid disturbance
		27.05.14	10.00	27.05.14	11.18	Tripped on internal fault
		30.05.14	16.56	30.05.14	18.12	Tripped due to grid disturbance
		09.06.14	13.12	09.06.14	13.57	
		13.06.14	02.36	13.06.14	03.41	
		16.06.14	11.41	16.06.14	12.23	Tripped on internal fault
		21.06.14	17.55	21.06.14	18.40	Tripped due to grid disturbance
		25.06.14	05.01	25.06.14	06.58	
		02.07.14	14.05	02.07.14	14.14	
		06.07.14	17.14	06.07.14	18.29	
		29.07.14	04.44	29.07.14	05.38	STG tripped on internal fault
		23.11.14	17.06	23.11.14	18.00	STG unloaded and tripped due to continuous fluctuation in the system
		02.12.14	00.20	12.12.14	01.56	Tripped on internal fault
		02.12.14	08.53	12.12.14	11.53	Tripped on internal fault
		12.12.14	08.18	12.12.14	10.27	Tripped on internal fault
		14.12.14	10.48	14.12.14	11.38	STG tripped due to grid disturbance
		19.12.14	11.14	19.12.14	12.50	Tripped on internal fault
		11.01.15	09.53	18.01.15	24.00	Tripped on internal fault
19.01.15	00.00	19.01.15	16.37	Stopped due to less demand and high frequency		
19.01.15	17.14	19.01.15	18.55	Tripped on internal fault		
20.01.15	13.57	20.01.15	21.08			
25.01.15	05.12	25.01.15	08.44			
		12.02.15	17.00	12.02.15	17.58	

## (D) BADARPUR THERMAL POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	95	14.05.14	17.37	19.05.14	09.36	Stopped due to low demand and high frequency
		30.05.14	17.08	30.05.14	19.17	Tripped due to grid disturbance
		20.06.14	12.15	21.05.14	06.25	Water wall leakage
		17.07.14	23.22	18.07.14	05.33	Battery / DC System problem
		18.07.14	05.45	18.07.14	07.00	Bus dead, PA Fan rotating reverse direction
		18.07.14	16.19	28.07.14	08.09	Stopped due to low demand and high frequency
		22.08.14	02.30	26.08.14	00.00	Coal supply to bunkers
		26.08.14	00.00	02.10.14	06.31	Coal shortage
		17.10.14	18.16	22.10.14	15.35	Stopped due to low demand and high frequency
		22.10.14	15.35	29.10.14	15.15	Stopped due to coal shortage
		29.10.14	15.15	28.02.15	23.59	Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	95	25.04.14	12.17	30.04.14	21.27	Stopped due to low demand and high frequency
		03.05.14	17.41	03.05.14	18.58	Tripped due to grid disturbance
		04.05.14	20.51	05.05.14	00.16	AVR & Excitation system
		22.05.14	09.27	31.05.14	12.13	CW Pum pit cleaning
		06.07.14	01.50	06.07.14	09.50	LT Bus problem
		06.07.14	09.50	08.07.14	06.25	ID Fan bearing problem
		24.07.14	02.48	24.07.14	04.34	Furnance disturbance
		30.07.14	20.12	31.07.14	23.59	Stopped due to low demand and high frequency
		01.08.14	22.00	26.08.14	00.00	Planned shutdown
		26.08.14	00.00	27.09.14	13.30	Coal shortage
		27.09.14	13.30	30.09.14	23.59	Stopped due to low demand and high frequency
		05.10.14	11.13	31.10.14	15.30	Stopped due to coal shortage
		31.10.14	15.30	28.02.15	23.59	Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	95	11.03.14	21.15	01.05.14	13.55	Stopped due to low demand and high frequency
		03.05.14	17.41	03.05.14	19.43	Tripped due to grid disturbance
		10.05.14	15.55	11.05.14	17.22	Water wall leakage (Screentube LHS)
		30.05.14	17.08	30.05.14	20.05	Tripped due to grid disturbance
		30.05.14	21.22	30.05.14	22.41	AVR & Excitation system problem
		30.05.14	23.53	30.05.14	23.59	
		14.06.14	15.18	14.06.14	19.44	Generator Protection
		21.06.14	14.14	22.06.14	14.34	Water wall leakage
		26.06.14	20.20	28.06.14	01.18	Economizer tube leakage
		08.07.14	08.58	08.07.14	10.16	Furnance disturbance
		11.07.14	10.37	11.07.14	11.57	C&I induced (Axial shift)
		24.07.14	00.46	31.07.14	23.59	Stopped due to low demand and high frequency
		20.08.14	00.00	26.08.14	00.00	Coal supply to bunkars
		26.08.14	00.00	30.09.14	23.59	Major planned shutdown
		10.10.14	17.08	10.10.14	19.08	Stopped for Electrical testing
		10.10.14	19.08	12.10.14	15.40	Coal shortage
		12.10.14	21.42	22.10.14	19.34	Coal shortage
		25.10.14	22.04	01.11.14	15.48	Stopped due to low demand and high frequency
		02.11.14	20.49	27.11.14	08.32	
12.12.14	21.56	13.12.14	13.14	Control cable fault / fuse blown		
26.12.14	18.56	28.02.15	23.59	Stopped due to low demand and high frequency		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	210	05.03.14	02.11	21.04.14	15.16	Planned shutdown
		30.04.14	14.18	01.05.14	21.00	Economizer Tube leakage
		01.05.14	21.00	05.05.14	11.13	Tripped due to grid disturbance
		25.05.14	20.26	28.05.14	07.55	Reheater tube leakage
		30.05.14	17.08	30.05.14	22.08	Tripped due to grid disturbance
		04.08.14	11.49	04.08.14	17.52	Furnance disturbance
		22.08.14	09.42	22.08.14	13.02	Differential relay malfunction
		29.08.14	00.28	01.09.14	10.35	Coal shortage
		01.09.14	13.35	01.09.14	22.52	UAT Differential protection
		09.09.14	13.33	14.09.14	16.32	Coal shortage
		26.09.14	08.35	26.09.14	10.57	Transformer winding temp high
		01.11.14	05.12	02.11.14	04.14	C&I Induced (Axial shift)
		27.11.14	10.56	30.11.14	08.33	Stopped due to low demand and high frequency
		11.12.14	13.44	11.12.14	15.58	Furnance disturbance
		05.01.15	18.32	06.01.15	05.15	
		20.01.15	13.00	20.01.15	18.26	UAT faulty
24.01.15	03.31	24.01.15	18.03	Water wall leakage		
24.01.15	18.03	28.02.15	23.59	Stopped due to less demand and high frequency		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	210	23.04.14	00.02	25.04.14	05.05	APH outlet Baffles found broken
		12.05.14	04.02	14.05.14	08.27	APH Outlet deflectors broken
		07.06.14	22.47	08.06.14	23.22	CW Pump trip
		13.06.14	11.01	13.06.14	15.51	AVR & Excitation system problem
		17.06.14	23.06	19.06.14	04.00	Economizer tube leakage
		19.06.14	04.00	20.06.14	16.45	PA Fan lub oil system problem
		07.07.14	20.01	09.07.14	03.03	Water wall leakage
		27.07.14	16.38	30.07.14	02.50	Water wall leakage
		11.11.14	22.07	12.11.14	20.08	Economizer tube leakage
		30.11.14	11.10	26.12.14	05.40	Stopped due to low demand and high frequency

(E) BAWANA CCGT POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	216	25.09.13	12.05	10.06.14	18.34	Stopped due to low demand and high frequency
		13.06.14	09.20	16.06.14	16.48	
		21.06.14	01.25	23.06.14	08.34	
		28.06.14	06.42	11.07.14	11.29	
		12.07.14	09.50	21.07.14	08.20	
		09.08.14	00.19	09.08.14	02.21	Failure of compressor bleed solenoid valve
		09.08.14	18.59	09.08.14	21.24	
		10.08.14	10.30	11.08.14	05.57	
		03.09.14	17.32	03.09.14	19.14	Tripped with alarm on MARK #6 & simultaneously STG #1
		11.11.14	06.01	11.11.14	07.23	Unit tripped due to loss of flame & STG #1 simultaneously tripped
		18.12.14	12.35	19.12.14	13.32	Unit tripped on high exhaust temp.
		28.12.14	01.34	28.12.14	05.22	Unit tripped on high exhaust temp spread high
19.01.15	14.26	28.02.15	23.59	Compressor stalled detected. STG-I Simultaneously tripped.		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	216	11.10.13	10.40	29.04.14	16.10	Stopped due to low demand and high frequency
		29.04.14	16.37	29.04.14	17.52	Closure of gas valve
		08.05.14	18.55	22.05.14	15.59	Stopped due to low demand and high frequency
		23.05.14	18.26	04.06.14	14.18	
		12.06.14	16.56	18.06.14	18.34	Turbine compartment vent fan pressure switch malfunctioned backing down after wards due to low demand
		23.06.14	05.11	27.06.14	18.58	Purge valve 20 PG-2 misbehaviour, I-P Converter found misbehaving trip, thereafter shutdown due to low demand and high frequency
		11.07.14	17.05	12.07.14	06.50	Stopped due to low demand and high frequency
		17.07.14	22.16	19.08.14	14.10	
		23.08.14	12.45	23.08.14	14.48	HGTMCC Supply failure
		31.08.14	14.55	31.08.14	23.59	Stopped due to low demand and high frequency
		15.09.14	14.40	15.09.14	15.42	Tripped due to surge capacitor failure.
		19.12.14	11.55	19.12.14	14.40	Unit tripped on group protection relay and simultaneously STG #1 tripped
		28.12.14	05.49	31.12.14	23.59	Unit tripped on air diff. Pr. High and simultaneously STG #1 tripped
19.01.15	16.51	19.01.15	18.34	Unit tripped on high exhaust temp. spread.		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	216	28.10.13	00.00	31.01.15	23:59	Commissioned on 28.10.13 and Stopped due to low demand and high frequency
		07.02.15	14.21	07.02.15	16.16	Unit tripped due to heavy electrical jerk and STG -2 also tripped
		19.02.15	01.49	19.02.15	05.35	Unit tripped on group / fire protection relay zone-I simultaneously STG also tripped

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	216	27.02.14	00.00	28.02.14	23:59	Commissioned on 27.02.14 and Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-1	254	11.10.13	10.50	23.05.14	00.30	Stopped due to low demand and high frequency
		23.05.14	18.28	04.06.14	14.18	
		12.06.14	17.13	12.06.14	18.03	LP drum level high
		13.06.14	09.20	16.06.14	21.21	Stopped due to low demand and high frequency
		23.06.14	05.11	23.6.14	12.18	
		12.07.14	15.00	15.07.14	23.59	
		17.07.14	22.18	21.07.14	08.43	
		06.08.14	12.49	06.08.14	14.25	HRSg trip due to BFP Trip
		09.08.14	00.19	09.08.14	05.05	G.T. Trip
		09.08.14	18.59	10.08.14	00.08	
		10.08.14	10.30	11.08.14	09.03	
		03.09.14	17.32	04.09.14	03.51	STG tripped consequent to GT#1
		11.11.14	06.01	11.11.14	08.54	Machine tripped consequent to tripping of GT #1
		19.12.14	11.55	19.12.14	17.15	STG tripped consequent to GT #2
		28.12.14	05.51	28.12.14	11.14	STG tripped consequent to tripping of GT. -2
19.01.15	14.27	19.01.15	22.05	Unit tripped alongwith tripping of G.T. Unit 6I		

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG-2	254	27.03.14	00.00	31.12.14	23:59	Commissioned on 27.03.14 and Stopped due to low demand and high frequency
		27.01.15	16.27	27.01.15	18.05	Unit tripped on Generator electrical fault
		07.02.15	14.22	07.02.15	20.37	STG tripped alongwith G.T. 3
		19.02.15	01.49	19.02.15	12.25	

(F) RITHALA POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	31.8	19.03.13	17:32	28.02.15	23:59	Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	31.8	07.06.13	22:41	28.02.15	23:59	Stopped due to low demand and high frequency

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	31.8	07.06.13	22:38	28.02.15	23:59	Stopped due to low demand and high frequency

**ALLOCATION OF POWER TO DELHI**

A)

**Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 27.03.2014****Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocation Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<b><u>NTPC STATIONS</u></b>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	1000	150	132	115	0	0	115
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
<b>TOTAL</b>	<b>9782</b>	<b>1302</b>	<b>2306</b>	<b>2016</b>	<b>0</b>	<b>0</b>	<b>2016</b>
<b><u>NHPC</u></b>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI-I HEP	480	0	53	50	0	0	50
URI-II HEP	180	0	24	23	0	0	23
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
Parbati-III HEP	390	50	50	47	0	0	47
<b>TOTAL</b>	<b>3875</b>	<b>256</b>	<b>454</b>	<b>431</b>	<b>0</b>	<b>0</b>	<b>431</b>
<b><u>NPC</u></b>							
Narora APS	440	64	47	41	0	0	41
RAPP (C )	440	64	56	49	0	0	49
<b>TOTAL</b>	<b>880</b>	<b>128</b>	<b>103</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>89</b>
<b><u>SVJNL</u></b>							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
<b><u>THDC</u></b>							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
<b>TOTAL</b>	<b>1400</b>	<b>139</b>	<b>142</b>	<b>135</b>	<b>0</b>	<b>0</b>	<b>135</b>
<b>Total</b>	<b>17437</b>	<b>1974</b>	<b>3147</b>	<b>2807</b>	<b>0</b>	<b>0</b>	<b>2807</b>
<b><u>Allocation from ER and Tala HEP</u></b>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
<b>Total ER</b>	<b>5960</b>	<b>153</b>	<b>261</b>	<b>217</b>	<b>0</b>	<b>0</b>	<b>217</b>
<b><u>Joint Venture</u></b>							
Jhajjar TPS	1500	114	377	338	0	0	338
Ultra Mega Projects							
Sasan	1320	0	149	128	0	0	128
<b>Grand Total</b>	<b>26217</b>	<b>2241</b>	<b>3933</b>	<b>3491</b>	<b>0</b>	<b>0</b>	<b>3491</b>

**B) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 18.06.2014**

**Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocation Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<b><u>NTPC STATIONS</u></b>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	1000	150	132	115	0	0	115
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
<b>TOTAL</b>	<b>9782</b>	<b>1302</b>	<b>2306</b>	<b>2016</b>	<b>0</b>	<b>0</b>	<b>2016</b>
<b><u>NHPC</u></b>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI-I HEP	480	0	53	50	0	0	50
URI-II HEP	180	0	24	23	0	0	23
Sewa HEP	120	18	16	15	0	0	15
Dhuli Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
Parbati-III HEP	520	66	66	63	0	0	63
<b>TOTAL</b>	<b>4005</b>	<b>272</b>	<b>471</b>	<b>447</b>	<b>0</b>	<b>0</b>	<b>447</b>
<b><u>NPC</u></b>							
Narora APS	440	64	47	41	0	0	41
RAPP (C )	440	64	56	49	0	0	49
<b>TOTAL</b>	<b>880</b>	<b>128</b>	<b>103</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>89</b>
<b><u>SVJNL</u></b>							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
<b><u>THDC</u></b>							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
<b>TOTAL</b>	<b>1400</b>	<b>139</b>	<b>142</b>	<b>135</b>	<b>0</b>	<b>0</b>	<b>135</b>
<b>Total</b>	<b>17567</b>	<b>1990</b>	<b>3164</b>	<b>2823</b>	<b>0</b>	<b>0</b>	<b>2823</b>
<b><u>Allocation from ER and Tala HEP</u></b>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
<b>Total ER</b>	<b>5960</b>	<b>153</b>	<b>261</b>	<b>217</b>	<b>0</b>	<b>0</b>	<b>217</b>
<b><u>Joint Venture</u></b>							
Jhajjar TPS	1500	114	52	47	0	0	47
<b><u>Ultra Mega Projects</u></b>							
Sasan	1320	0	149	128	0	0	128
<b>Grand Total</b>	<b>26347</b>	<b>2257</b>	<b>3625</b>	<b>3215</b>	<b>0</b>	<b>0</b>	<b>3215</b>

**C) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 21.06.2014**

**Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocation Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<b><u>NTPC STATIONS</u></b>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	1000	150	132	115	0	0	115
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
<b>TOTAL</b>	<b>9782</b>	<b>1302</b>	<b>2306</b>	<b>2016</b>	<b>0</b>	<b>0</b>	<b>2016</b>
<b><u>NHPC</u></b>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI-I HEP	480	0	53	50	0	0	50
URI-II HEP	180	0	24	23	0	0	23
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
Parbati-III HEP	520	66	66	63	0	0	63
<b>TOTAL</b>	<b>4005</b>	<b>272</b>	<b>471</b>	<b>447</b>	<b>0</b>	<b>0</b>	<b>447</b>
<b><u>NPC</u></b>							
Narora APS	440	64	47	41	0	0	41
RAPP (C)	440	64	56	49	0	0	49
<b>TOTAL</b>	<b>880</b>	<b>128</b>	<b>103</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>89</b>
<b><u>SVJNL</u></b>							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
<b><u>THDC</u></b>							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
<b>TOTAL</b>	<b>1400</b>	<b>139</b>	<b>142</b>	<b>135</b>	<b>0</b>	<b>0</b>	<b>135</b>
<b>Total</b>	<b>17567</b>	<b>1990</b>	<b>3164</b>	<b>2823</b>	<b>0</b>	<b>0</b>	<b>2823</b>
<b><u>Allocation from ER and Tala HEP</u></b>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
<b>Total ER</b>	<b>5960</b>	<b>153</b>	<b>261</b>	<b>217</b>	<b>0</b>	<b>0</b>	<b>217</b>
<b><u>Joint Venture</u></b>							
Jhajjar TPS	1500	114	0	0	0	0	0
Ultra Mega Projects							
Sasan	2640	0	297	255	0	0	255
<b>Grand Total</b>	<b>27667</b>	<b>2257</b>	<b>3721</b>	<b>3296</b>	<b>0</b>	<b>0</b>	<b>3296</b>



**D) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 10.09.2014**

**Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocation Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<b><u>NTPC STATIONS</u></b>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	1000	150	132	115	0	0	115
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	576	500	0	0	500
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
<b>TOTAL</b>	<b>9782</b>	<b>1302</b>	<b>2126</b>	<b>1860</b>	<b>0</b>	<b>0</b>	<b>1860</b>
<b><u>NHPC</u></b>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI-I HEP	480	0	53	50	0	0	50
URI-II HEP	180	0	24	23	0	0	23
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
Parbati-III HEP	520	66	66	63	0	0	63
<b>TOTAL</b>	<b>4005</b>	<b>272</b>	<b>471</b>	<b>447</b>	<b>0</b>	<b>0</b>	<b>447</b>
<b><u>NPC</u></b>							
Narora APS	440	64	47	41	0	0	41
RAPP (C)	440	64	56	49	0	0	49
<b>TOTAL</b>	<b>880</b>	<b>128</b>	<b>103</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>89</b>
<b><u>SVJNL</u></b>							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
<b><u>THDC</u></b>							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
<b>TOTAL</b>	<b>1400</b>	<b>139</b>	<b>142</b>	<b>135</b>	<b>0</b>	<b>0</b>	<b>135</b>
<b>Total</b>	<b>17567</b>	<b>1990</b>	<b>2984</b>	<b>2667</b>	<b>0</b>	<b>0</b>	<b>2667</b>
<b><u>Allocation from ER and Tala HEP</u></b>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
<b>Total ER</b>	<b>5960</b>	<b>153</b>	<b>261</b>	<b>217</b>	<b>0</b>	<b>0</b>	<b>217</b>
<b><u>Joint Venture</u></b>							
Jhajjar TPS	1500	114	0	0	0	0	0
Ultra Mega Projects							
Sasan	2640	0	297	255	0	0	255
<b>Grand Total</b>	<b>27667</b>	<b>2257</b>	<b>3541</b>	<b>3140</b>	<b>0</b>	<b>0</b>	<b>3140</b>

**E) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 14.11.2014**

**Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocation Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<b><u>NTPC STATIONS</u></b>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand-I	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
Rihand Stage -III	1000	150	132	115	0	0	115
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	576	500	0	0	500
Dadri NCTPS (Th) Stage-II	980	147	474	412	0	0	412
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
<b>TOTAL</b>	<b>9782</b>	<b>1302</b>	<b>1865</b>	<b>1633</b>	<b>0</b>	<b>0</b>	<b>1633</b>
<b><u>NHPC</u></b>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
Chamera-III HEP	231	35	29	28	0	0	28
URI-I HEP	480	0	53	50	0	0	50
URI-II HEP	240	0	32	31	0	0	31
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
Parbati-III HEP	520	66	66	63	0	0	63
<b>TOTAL</b>	<b>4065</b>	<b>272</b>	<b>479</b>	<b>455</b>	<b>0</b>	<b>0</b>	<b>455</b>
<b><u>NPC</u></b>							
Narora APS	440	64	47	41	0	0	41
RAPP (C)	440	64	56	49	0	0	49
<b>TOTAL</b>	<b>880</b>	<b>128</b>	<b>103</b>	<b>89</b>	<b>0</b>	<b>0</b>	<b>89</b>
<b><u>SVJNL</u></b>							
Nathpa Jhakri HEP	1500	149	142	135	0	0	135
<b><u>THDC</u></b>							
Tehri Hydro	1000	99	103	98	0	0	98
Koteshwar HEP	400	40	39	37	0	0	37
<b>TOTAL</b>	<b>1400</b>	<b>139</b>	<b>142</b>	<b>135</b>	<b>0</b>	<b>0</b>	<b>135</b>
<b>Total</b>	<b>17627</b>	<b>1990</b>	<b>2731</b>	<b>2448</b>	<b>0</b>	<b>0</b>	<b>2448</b>
<b><u>Allocation from ER and Tala HEP</u></b>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
<b>Total ER</b>	<b>5960</b>	<b>153</b>	<b>261</b>	<b>217</b>	<b>0</b>	<b>0</b>	<b>217</b>
<b><u>Joint Venture</u></b>							
Jhajjar TPS	1500	114	0	0	0	0	0
Ultra Mega Projects							
Sasan	2640	0	297	255	0	0	255
<b>Grand Total</b>	<b>27727</b>	<b>2257</b>	<b>3288</b>	<b>2921</b>	<b>0</b>	<b>0</b>	<b>2921</b>

**5 ALLOCATION OF POWER TO DISCOMS**

**A) ALLOCATION OF POWER TO VARIOUS LICENCEES AS PER ORDER OF DERC AND DECISION OF GNCTD FOR ALLOCATION OF CENTRAL SECTOR STATIONS (DADRI THERMAL & BTPS) AND STATE SECTOR GENERATING STATIONS w.e.f. 06.08.2013.**

**(Allocation In % )**

**(A) 10.00hrs. to 17.00hrs.**

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0	0	29.18	43.58	27.24	100.00
2. Dadri (Th)	16.63	0	24.22	36.86	22.39	100.00
3. BTPS	17.73	7.09	21.81	33.2	20.17	100.00
4. RPH	0	0	29.025	44.133	26.842	100.00
5. GT	0	0	29.02	44.16	26.82	100.00
6. Pragati	30.3	0	20.22	30.78	18.7	100.00
7. DVC	0	0	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

**(B) 00.00hrs. to 10.00hrs. and 17.00hrs. to 24.00hrs.**

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0	0	29.18	43.58	27.24	100.00
2. Dadri (Th)	16.53	0	24.22	36.86	22.39	100.00
3. BTPS	17.73	7.09	21.81	33.2	20.17	100.00
4. RPH	0	0	29.025	44.133	26.842	100.00
5. GT	0	0	29.02	44.16	26.82	100.00
6. Pragati	30.3	0	20.22	30.78	18.7	100.00
7. DVC	0	0	29.18	43.58	27.24	100.00
8. BAWANA CCGT*	7.30	1.82	20.688	30.888	19.304	80.00

\* 20% POWER OF BAWANA CCGT ALLOCATED TO HARYANA (10%) & PUNJAB (10%)

**6 POWER AVAILABILITY-DEMAND POSITION AT THE TIME OF PEAK DEMAND MET DURING FEBRUARY 2015**

All figures in MW

Date	Time of peak demand	Generation within Delhi								Import from the Grid	Schedule from the Grid	OD(-) / UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	Rithala	Bawana	Towmel	BTPS	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)		(9)=(3) to (8)	(10)	(11)	(12)=(11) - (10)	(13)=(11)+ (12)	(14)	(15)=(13)+ (14)
1	09.55.14	38	120	280	0	289	16	162	905	2865	2767	98	3770	0	3770
2	10.16.04	35	118	273	0	314	14	163	917	2847	3021	-174	3764	0	3764
3	10.05.46	38	120	157	0	317	16	167	815	2478	2889	-411	3293	0	3293
4	09.36.28	39	121	161	0	335	16	160	832	2953	3007	-54	3785	0	3785
5	10.02.29	35	121	163	0	309	16	166	810	2921	2724	197	3731	0	3731
6	10.09.58	41	119	160	0	324	14	162	820	3023	2959	64	3843	0	3843
7	10.02.32	37	58	162	0	299	16	160	732	2439	2531	-92	3171	0	3171
8	10.03.17	31	76	161	0	324	14	164	770	2724	2660	64	3494	0	3494
9	10.01.44	30	77	162	0	323	16	164	772	2708	2840	-132	3480	4	3484
10	09.56.56	35	77	162	0	304	13	162	753	2774	2730	44	3527	0	3527
11	10.03.42	30	77	162	0	317	16	160	762	2744	2768	-24	3506	0	3506
12	09.57.14	34	79	161	0	314	16	156	760	2700	2670	30	3460	0	3460
13	10.01.30	30	78	162	0	316	16	159	761	2807	2802	5	3568	0	3568
14	10.02.38	31	74	158	0	307	16	164	750	2666	2517	149	3416	0	3416
15	10.09.58	31	74	158	0	319	16	163	761	2564	2438	126	3325	0	3325
16	10.16.17	31	72	157	0	322	16	165	763	2479	2379	100	3242	0	3242
17	0:00:00	31	74	158	0	322	16	162	763	2673	2618	55	3436	0	3436
18	10.40.18	30	96	156	0	314	16	156	768	2443	2490	-47	3211	0	3211
19	11.00.00	34	77	155	0	27	12	159	464	2693	2486	207	3157	19	3176
20	10.47.16	30	76	155	0	304	14	156	735	2640	2485	155	3375	0	3375
21	10.30.00	36	78	156	0	282	9	157	718	2352	2415	-63	3070	0	3070
22	10.03.49	33	78	158	0	290	9	163	731	2361	2289	72	3092	0	3092
23	18.56.34	40	78	155	0	314	16	164	767	2367	2262	105	3134	2	3136
24	10.13.07	29	79	157	0	298	16	160	739	2548	2520	28	3287	0	3287
25	10.26.53	35	75	155	0	311	16	162	754	2567	2587	-20	3321	0	3321
26	09.53.38	36	75	159	0	289	16	162	737	2481	2623	-142	3218	0	3218
27	10.30.00	33	77	158	0	308	16	162	754	2481	2455	26	3235	0	3235
28	10.35.36	36	80	158	0	311	16	161	762	2422	2246	176	3184	0	3184

**POWER AVAILABILITY- DEMAND POSITION AT THE TIME OF MAXIMUM UNRESTRICTED DEMAND DURING FEBRUARY 2015**

Date	Time of peak demand	Generation within Delhi								Import from the Grid	Schedule from the Grid	OD(-)/UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	Rithala	Bawana	Towmcl	BTPS	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)		(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)
1	09.55.14	38	120	280	0	289	16	162	905	2865	2767	98	3770	0	3770
2	10.16.04	35	118	273	0	314	14	163	917	2847	3021	-174	3764	0	3764
3	10.05.46	38	120	157	0	317	16	167	815	2478	2889	-411	3293	0	3293
4	09.36.28	39	121	161	0	335	16	160	832	2953	3007	-54	3785	0	3785
5	10.02.29	35	121	163	0	309	16	166	810	2921	2724	197	3731	0	3731
6	10.09.58	41	119	160	0	324	14	162	820	3023	2959	64	3843	0	3843
7	10.02.32	37	58	162	0	299	16	160	732	2439	2531	-92	3171	0	3171
8	10.03.17	31	76	161	0	324	14	164	770	2724	2660	64	3494	0	3494
9	10.01.44	30	77	162	0	323	16	164	772	2708	2840	-132	3480	4	3484
10	09.56.56	35	77	162	0	304	13	162	753	2774	2730	44	3527	0	3527
11	10.03.42	30	77	162	0	317	16	160	762	2744	2768	-24	3506	0	3506
12	09.57.14	34	79	161	0	314	16	156	760	2700	2670	30	3460	0	3460
13	10.01.30	30	78	162	0	316	16	159	761	2807	2802	5	3568	0	3568
14	10.02.38	31	74	158	0	307	16	164	750	2666	2517	149	3416	0	3416
15	10.09.58	31	74	158	0	319	16	163	761	2564	2438	126	3325	0	3325
16	10.16.17	31	72	157	0	322	16	165	763	2479	2379	100	3242	0	3242
17	0:00:00	31	74	158	0	322	16	162	763	2673	2618	55	3436	0	3436
18	10.40.18	30	96	156	0	314	16	156	768	2443	2490	-47	3211	0	3211
19	11.00.00	34	77	155	0	27	12	159	464	2693	2486	207	3157	19	3176
20	10.47.16	30	76	155	0	304	14	156	735	2640	2485	155	3375	0	3375
21	10.30.00	36	78	156	0	282	9	157	718	2352	2415	-63	3070	0	3070
22	10.03.49	33	78	158	0	290	9	163	731	2361	2289	72	3092	0	3092
23	18.56.34	40	78	155	0	314	16	164	767	2367	2262	105	3134	2	3136
24	10.13.07	29	79	157	0	298	16	160	739	2548	2520	28	3287	0	3287
25	10.26.53	35	75	155	0	311	16	162	754	2567	2587	-20	3321	0	3321
26	09.53.38	36	75	159	0	289	16	162	737	2481	2623	-142	3218	0	3218
27	10.30.00	33	77	158	0	308	16	162	754	2481	2455	26	3235	0	3235
28	10.35.36	36	80	158	0	311	16	161	762	2422	2246	176	3184	0	3184

## SOURCEWISE SCHEDULED DRAWL FROM NORTHERN GRID AS WELL AS AVAILABILITY WITHIN DELHI FOR FEBRUARY 2015

### A) AVAILABILITY FROM GENCO AND PRAGATI STNs. (all fig in MUs)

A (i) RPH	27.634
(ii) GT+STG	59.419
(iii) PRAGATI	113.669
(iv) RITHALA	0.000
(v) BAWANA CCGT	198.970
(vi) Timarpur ó Okhla	10.968
<b>TOTAL</b>	<b>410.660</b>
B) AVAILABILITY FROM BTPS	105.119
C) AUXILIARY CONSUMPTION OF GENERATING STNs. EXCLUDING BTPS	17.311
D) NET GENERATION AVAILABLE WITHIN DELHI(A+B-C)	<b>498.468</b>

### B) SOURCE WISE SCHEDULED DRAWL FROM THE NORTHERN GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
B/SUIL	4.354	4.175	4.354	4.175
SALAL	12.155	11.650	12.155	11.650
SASAN	172.911	165.622	169.097	161.977
TANKAPUR	1.534	1.468	1.526	1.461
CHAMERA	8.737	8.381	8.737	8.381
CHAMERA -II	6.585	6.311	6.585	6.311
CHAMERA -III	3.229	3.095	3.229	3.095
DHAULIGANGA	3.149	3.015	3.149	3.015
SEWA -2	5.836	5.594	5.836	5.594
URI	16.527	15.844	16.527	15.844
URI-II	0.000	0.000	0.000	0.000
KOTESHWAR	8.657	8.289	8.657	8.289
PARBATI3	1.469	1.408	1.469	1.408
RAMPUR	0.000	0.000	0.000	0.000
MUNDRA_UMPP	0.000	0.000	0.000	0.000
ANTA (GAS)	20.828	19.917	7.977	7.626
ANTA (RLNG)	8.729	8.383	0.000	0.000
ANTA (LIQUID)	0.000	0.000	0.000	0.000
DADRI (GAS)	32.610	31.204	10.127	9.694
DADRI (RLNG)	24.942	23.914	0.000	0.000
DADRI (LIQUID)	0.000	0.000	0.000	0.000
AURAIYA (GAS)	22.947	21.967	7.850	7.520
AURAIYA (RLNG)	14.332	13.725	0.000	0.000
AURAIYA (LIQUID)	0.000	0.000	0.000	0.000
SINGRAULI	91.555	87.651	86.211	82.536
RIHAND -I	60.146	57.585	49.158	47.066
RIHAND -II	76.447	73.192	62.122	59.471
RIHAND -III	82.447	78.931	67.917	65.016
UNCHAHAHAR-I	15.450	14.792	9.743	9.325
UNCHAHAHAR-II	30.456	29.159	17.910	17.137
UNCHAHAHAR-III	18.625	17.832	13.255	12.688
DADRI (TH)	375.444	359.461	261.036	249.921
DADRI (TH) STAGE-II	317.859	304.330	234.855	224.839
NAPP	28.201	27.000	28.190	26.988
RAPP 'B'	0.000	0.000	0.000	0.000
RAPP 'C'	24.981	23.932	24.981	23.932
NATHPA JHAKRI	16.011	15.331	11.944	11.437
DULASTI	9.552	9.150	9.552	9.150
TEHRI	23.052	22.070	23.052	22.070
JHAJJAR	0.000	0.000	0.000	0.000
KHELGAON	30.523	29.223	22.177	21.227
KHELGAON-II	99.298	95.070	83.080	79.541
FARAKA	13.251	12.687	9.976	9.549
TALA	0.734	0.702	0.734	0.702
TALCHER	0.000	0.000	0.000	0.000
DVC	95.497	94.264	94.264	90.187

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
UTTAR PRADESH	7.987	7.795	7.795	7.441
TRIPUA	0.000	0.000	0.000	0.000
MAHARASHTRA	0.000	0.000	0.000	0.000
DVC CTPS (BRPL)	0.000	0.000	0.000	0.000
DVC CTPS (BYPL)	0.000	0.000	0.000	0.000
DVC CTPS (NDPL)	0.000	0.000	0.000	0.000
METHON POWER(NDPL)LT-06	173.515	171.093	171.093	163.823
DVC MEJIA (LT-08)(BYPL)	0.000	0.000	0.000	0.000
URS	0.000	0.000	0.000	0.000
JAMMU & KASHMIR	0.000	0.000	0.000	0.000
HIMACHAL PRADESH	0.000	0.000	0.000	0.000
PUNJAB	17.495	17.153	17.153	16.422
MADHYA PRADESH	0.000	0.000	0.000	0.000
HARYANA	10.934	10.720	10.720	10.264
DVC LT-9	0.000	0.000	0.000	0.000
HARYANA (LT-05)	22.927	22.477	22.477	21.518
WEST BENGAL	23.713	23.408	23.408	22.400
ORISSA	0.000	0.000	0.000	0.000
TO HARYANA	0.000	0.000	0.000	0.000
TO MEGHALAYA	-15.403	-15.735	-15.735	-16.435
TO UTTAR PRADESH	-40.793	-41.865	-41.865	-43.731
TO JAMMU & KASHMIR	-157.019	-160.765	-160.765	-167.914
TO KERALA	0.000	0.000	0.000	0.000
TO ASSAM	-17.451	-17.772	-17.772	-18.563
TO MADHYA PRADESH	-16.584	-16.864	-16.864	-17.613
TO JHARKHAND	-11.364	-11.477	-11.477	-11.988
TO RAJASTHAN	0.000	0.000	0.000	0.000
TO MAHARASHTRA	0.000	0.000	0.000	0.000
BTPS TO MP	0.000	0.000	0.000	0.000
TO HIMACHAL PRADESH	-79.089	-80.667	-80.667	-84.254
TO WEST BENGAL	0.000	0.000	0.000	0.000
POWER EXCHANGE(IEX)	66.105	63.198	66.105	63.198
TO POWER EXCHANGE (IEX)	-26.736	-27.896	-26.736	-27.896
POWER EXCHANGE(PX)	0.063	0.060	0.063	0.060
TO POWER EXCHANGE (PX)	-11.510	-12.023	-11.510	-12.023
TO SHARE PROJECT (HARYANA)	-26.850	-28.043	-26.850	-28.043
TO SHARE PROJECT (PUNJAB)	-3.977	-4.156	-3.977	-4.156
<b>TOTAL</b>	<b>1695.020</b>	<b>1604.964</b>	<b>1282.026</b>	<b>1191.332</b>

**C) AGENCY WISE BREAKUP OF ENERGY SCHEDULED DRAWL FROM THE GRID**

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
NTPC - NR	1192.817	1142.043	828.161	792.838
NTPC - ER	143.072	136.980	115.233	110.318
NHPC	73.126	70.090	73.118	70.083
NPC	53.182	50.931	53.170	50.920
SASAN	172.911	165.622	169.097	161.977
KOTESHWAR	8.657	8.289	8.657	8.289
MUNDRA_UMPP	0.000	0.000	0.000	0.000
NATHPA JHAKRI	16.011	15.331	11.944	11.437
TEHRI	23.052	22.070	23.052	22.070
TALA	0.734	0.702	0.734	0.702
JHAJJAR	0.000	0.000	0.000	0.000
TALCHER	0.000	0.000	0.000	0.000
DVC	95.497	94.264	94.264	90.187
UTTAR PRADESH	7.987	7.795	7.795	7.441
DVC CTPS (BRPL)	0.000	0.000	0.000	0.000
DVC CTPS (BYPL)	0.000	0.000	0.000	0.000
DVC CTPS (NDPL)	0.000	0.000	0.000	0.000
METHON POWER (NDPL)-LT-06	173.515	171.093	171.093	163.823
DVC MEJIA (LT-08)(BYPL)	0.000	0.000	0.000	0.000
URS	0.000	0.000	0.000	0.000
PUNJAB	17.495	17.153	17.153	16.422
MADHYA PRADESH(WR)	0.000	0.000	0.000	0.000
HARYANA	10.934	10.720	10.720	10.264
DVC (FOR NDPL) LT-09	0.000	0.000	0.000	0.000

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
HARYANA (LT -05)	22.927	22.477	22.477	21.518
WEST BENGAL	23.713	23.408	23.408	22.400
POWER EXCHANGE(IEX)	66.105	63.198	66.105	63.198
POWER EXCHANGE(PX)	0.063	0.060	0.063	0.060
<b>TOTAL</b>	<b>2101.797</b>	<b>2022.26</b>	<b>1696.244</b>	<b>1623.947</b>

**D) AGENCY WISE BREAKUP OF ENERGY SCHEDULED BY NRLDC FOR EXPORT TO OTHER UTILITIES FROM DTL**

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT POWER PERIPHERY
TO HARYANA	0.000	0.000	0.000	0.000
TO MEGHALAYA	-15.403	-15.735	-15.735	-16.435
TO UTTAR PRADESH	-40.793	-41.865	-41.865	-43.731
TO JAMMU & KASHMIR	-157.019	-160.765	-160.765	-167.914
TO ASSAM	-17.451	-17.772	-17.772	-18.563
TO KERALA	0.000	0.000	0.000	0.000
TO MADHYA PRADESH	-16.584	-16.864	-16.864	-17.613
TO JHARKHAND	-11.364	-11.477	-11.477	-11.988
TO RAJASTHAN	0.000	0.000	0.000	0.000
TO MAHARASHTRA	0.000	0.000	0.000	0.000
BTPS TO MP	0.000	0.000	0.000	0.000
TO HIMACHAL PRADESH	-79.089	-80.667	-80.667	-84.254
TO WEST BENGAL	0.000	0.000	0.000	0.000
TO POWER EXCHANGE (IEX)	-26.736	-27.896	-26.736	-27.896
TO POWER EXCHANGE (PX)	-11.510	-12.023	-11.510	-12.023
TO SHARE PROJECT (HARYANA)	-26.850	-28.043	-26.850	-28.043
TO SHARE PROJECT (PUNJAB)	-3.977	-4.156	-3.977	-4.156
<b>TOTAL</b>	<b>-406.777</b>	<b>-417.262</b>	<b>-414.218</b>	<b>-432.615</b>
<b>TOTAL SCHEDULED DRAWAL FROM THE GRID</b>	<b>1695.020</b>	<b>1604.964</b>	<b>1282.026</b>	<b>1191.332</b>
TOTAL CONSUMPTION INCLUDING AUX. OF GENERATING STNs. EXCLUDING BTPS				1704.390
NET CONSUMPTION				<b>1687.079</b>
AVAILABILITY WITHIN DELHI				498.468
ACTUAL DRAWAL FROM THE GRID				1188.611
OVER DRAWAL(+)/UNDER DRAWAL(-) FROM THE GRID ON THE BASIS OF SCHEDULED ALLOCATION MADE BY NRLDC TO DELHI AT PERIPHERY				-2.721
LOAD SHEDDING				0.767
UNRESTRICTED DEMAND (GROSS)				1705.157
UNRESTRICTED DEMAND (NET)				1687.846
MAX. NET CONSUMPTION				65.588 ON 04.02.2015
MAX. LOAD SHEDDING				140MW ON 19.02.2015 AT 21.25HRS.
<b>PEAK LOAD</b>	Peak Demand during the month			SCHEDDING AT PEAK TIME
DAY PEAK	3847MW AT 10.09.58HRS ON 06.02.2015			0 MW
EVENING PEAK	3356MW AT 19.00HRS ON 02.02.2015			0 MW
P.L.F. OF GENCO AND PRAGATI STNs.	RPH			30.46%
	GT			32.75%
	PRAGATI			51.26%
	RITHALA			0.00%
	BAWANA			21.60%
	Timarpur Okhla			102.01%



DATE	No. of Under Freq. Relay Operated	Shedding due to under frequency relay operation in MUs					Shedding due to Grid Restrictions (Over drawl / low freq.)			
		BSES		NDPL	NDMC	TOTAL	BSES		NDPL	NDMC
		BYPL	BRPL				BYPL	BRPL		
1	2	3	4	5	6	7=3 to 6	8	9	10	11
01-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
02-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.015	0.000
03-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
04-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
05-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
06-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
07-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
08-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
09-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
10-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
11-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
12-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
13-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
14-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
15-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.013	0.000	0.000
16-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.011	0.065	0.000	0.000
17-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.007	0.016	0.000
18-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
19-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
20-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
21-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
22-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
23-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.016	0.000
24-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
25-Feb.15	1	0.007	0.000	0.000	0.000	<b>0.007</b>	0.000	0.000	0.000	0.000
26-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
27-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.000	0.000	0.000
28-Feb.15	0	0.000	0.000	0.000	0.000	<b>0.000</b>	0.000	0.014	0.000	0.000
<b>TOTAL</b>	<b>1</b>	<b>0.007</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.007</b>	<b>0.011</b>	<b>0.099</b>	<b>0.047</b>	<b>0.000</b>

Date	Shedding due to Transmission/Grid Constraints in Central Sector Stations / TTC / ATC VOILATION				TOTAL	TOTAL SHEDDING DUE TO GRID RESTRICTIONS	Due to T&D Constraints					
	BSES		NDPL	NDMC			DTL					
	BYPL	BRPL					BSES		NDPL	NDMC	MES	
			12	13			14	15				16=8to15
01-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
02-Feb.15	0.000	0.000	0.000	0.000	<b>0.015</b>	<b>0.015</b>	0.000	0.000	0.000	0.000	0.000	0.000
03-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
04-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
05-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
06-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
07-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
08-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
09-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.001	0.000	0.002	0.000	0.000	0.000
10-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
11-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
12-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
13-Feb.15	0.008	0.000	0.042	0.000	<b>0.050</b>	<b>0.050</b>	0.000	0.000	0.000	0.000	0.000	0.000
14-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
15-Feb.15	0.000	0.000	0.000	0.000	<b>0.013</b>	<b>0.013</b>	0.000	0.000	0.000	0.000	0.000	0.000
16-Feb.15	0.000	0.000	0.000	0.000	<b>0.076</b>	<b>0.076</b>	0.000	0.000	0.000	0.000	0.000	0.000
17-Feb.15	0.000	0.000	0.000	0.000	<b>0.023</b>	<b>0.023</b>	0.000	0.000	0.000	0.000	0.000	0.000
18-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
19-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.009	0.000	0.000	0.000	0.000
20-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
21-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
22-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
23-Feb.15	0.000	0.000	0.000	0.000	<b>0.016</b>	<b>0.016</b>	0.000	0.000	0.000	0.000	0.000	0.000
24-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
25-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.007</b>	0.000	0.000	0.000	0.000	0.000	0.000
26-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.000	0.000	0.000	0.000	0.000
27-Feb.15	0.000	0.000	0.000	0.000	<b>0.000</b>	<b>0.000</b>	0.000	0.006	0.000	0.000	0.000	0.000
28-Feb.15	0.000	0.000	0.000	0.000	<b>0.014</b>	<b>0.014</b>	0.000	0.000	0.000	0.000	0.000	0.000
<b>TOTAL</b>	<b>0.008</b>	<b>0.000</b>	<b>0.042</b>	<b>0.000</b>	<b>0.207</b>	<b>0.214</b>	<b>0.001</b>	<b>0.015</b>	<b>0.002</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


DATE	DUE TO T&D CONSTRAINTS				OTHER AGENCIES LIKE GENCO, BBMB, BTPS ETC.	THEFT PRONE SHEDDING			TOTAL SHEDDING DUE TO T&D CONSTS. & THEFT PRONE	GRAND TOTAL
	DISCOMS					BSES		NDPL		
	BSES		NDPL	NDMC		BSES				
	BYPL	BRPL				BYPL	BRPL			
1	23	24	25	26	27	28	29	30=18 to29	31=30+17	
01-Feb.15	0.001	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.004	0.004
02-Feb.15	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.014	0.017	0.032
03-Feb.15	0.010	0.004	0.009	0.000	0.000	0.000	0.000	0.003	0.026	0.026
04-Feb.15	0.004	0.003	0.000	0.000	0.000	0.000	0.000	0.002	0.009	0.009
05-Feb.15	0.019	0.000	0.000	0.000	0.000	0.000	0.000	0.004	0.023	0.023
06-Feb.15	0.000	0.006	0.0002	0.000	0.000	0.000	0.000	0.012	0.018	0.018
07-Feb.15	0.002	0.011	0.000	0.000	0.000	0.000	0.000	0.000	0.013	0.013
08-Feb.15	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.002
09-Feb.15	0.008	0.000	0.001	0.000	0.000	0.000	0.000	0.018	0.030	0.030
10-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.002	0.002
11-Feb.15	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.008	0.009	0.009
12-Feb.15	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.004	0.010	0.010
13-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.024	0.024	0.074
14-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.020	0.020	0.020
15-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.002	0.015
16-Feb.15	0.002	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.004	0.080
17-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.015	0.015	0.038
18-Feb.15	0.014	0.000	0.000	0.000	0.000	0.000	0.000	0.006	0.020	0.020
19-Feb.15	0.015	0.033	0.003	0.000	0.000	0.000	0.000	0.009	0.069	0.069
20-Feb.15	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.004	0.010	0.010
21-Feb.15	0.000	0.000	0.023	0.000	0.000	0.000	0.000	0.003	0.026	0.026
22-Feb.15	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.002	0.002
23-Feb.15	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.015	0.018	0.034
24-Feb.15	0.013	0.052	0.033	0.000	0.000	0.000	0.000	0.004	0.102	0.102
25-Feb.15	0.003	0.000	0.002	0.000	0.002	0.000	0.000	0.004	0.011	0.018
26-Feb.15	0.000	0.002	0.000	0.000	0.000	0.000	0.000	0.005	0.007	0.007
27-Feb.15	0.000	0.044	0.000	0.000	0.000	0.000	0.000	0.003	0.053	0.053
28-Feb.15	0.006	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.007	0.021
<b>TOTAL</b>	<b>0.106</b>	<b>0.160</b>	<b>0.078</b>	<b>0.000</b>	<b>0.002</b>	<b>0.000</b>	<b>0.000</b>	<b>0.189</b>	<b>0.553</b>	<b>0.767</b>

DATE	(NET CONS.)	MAXI. DEMAND MET DURING THE DAY	TIME OF OCCURRENCE OF MAX DEMAND	SHEDDING AT THIS TIME	UN-RESTRICTED DEMAND	MAXIMUM UN-RESTRICTED DEMAND DURING THE DAY	TIME OF MAX. UN-REST. DEMAND	DEMAND AT THAT TIME	SHEDDING AT THAT TIME
	In Mus.	IN MW	IN HRS.	IN MW	IN MW	IN MW	HRS.	IN MW	IN MW
<b>1</b>	<b>32</b>	<b>33</b>	<b>34</b>	<b>35</b>	<b>36=33+35</b>	<b>37=39+40</b>	<b>38</b>	<b>39</b>	<b>40</b>
01-Feb.15	62.038	<b>3770</b>	09:55:14	0	<b>3770</b>	<b>3770</b>	09:55:14	<b>3770</b>	0
02-Feb.15	62.358	<b>3764</b>	10:16:04	0	<b>3764</b>	<b>3764</b>	10:16:04	<b>3764</b>	0
03-Feb.15	64.571	<b>3750</b>	10:05:46	0	<b>3750</b>	<b>3750</b>	10:05:46	<b>3750</b>	0
04-Feb.15	65.588	<b>3785</b>	09:36:28	0	<b>3785</b>	<b>3785</b>	09:36:28	<b>3785</b>	0
05-Feb.15	64.732	<b>3731</b>	10:02:29	0	<b>3731</b>	<b>3731</b>	10:02:29	<b>3731</b>	0
06-Feb.15	65.149	<b>3847</b>	10:09:58	0	<b>3847</b>	<b>3847</b>	10:09:58	<b>3847</b>	0
07-Feb.15	53.639	<b>3171</b>	10:02:32	0	<b>3171</b>	<b>3171</b>	10:02:32	<b>3171</b>	0
08-Feb.15	56.822	<b>3494</b>	10:03:17	0	<b>3494</b>	<b>3494</b>	10:03:17	<b>3494</b>	0
09-Feb.15	60.327	<b>3480</b>	10:01:44	4	<b>3484</b>	<b>3484</b>	10:01:44	<b>3480</b>	4
10-Feb.15	61.535	<b>3527</b>	09:56:56	0	<b>3527</b>	<b>3527</b>	09:56:56	<b>3527</b>	0
11-Feb.15	61.842	<b>3506</b>	10:03:42	0	<b>3506</b>	<b>3506</b>	10:03:42	<b>3506</b>	0
12-Feb.15	60.873	<b>3460</b>	09:57:14	0	<b>3460</b>	<b>3460</b>	09:57:14	<b>3460</b>	0
13-Feb.15	62.558	<b>3568</b>	10:01:30	0	<b>3568</b>	<b>3568</b>	10:01:30	<b>3568</b>	0
14-Feb.15	58.800	<b>3416</b>	10:02:38	0	<b>3416</b>	<b>3416</b>	10:02:38	<b>3416</b>	0
15-Feb.15	56.474	<b>3325</b>	10:09:58	0	<b>3325</b>	<b>3325</b>	10:09:58	<b>3325</b>	0
16-Feb.15	57.869	<b>3242</b>	10:16:17	0	<b>3242</b>	<b>3242</b>	10:16:17	<b>3242</b>	0
17-Feb.15	58.997	<b>3436</b>	09:51:48	0	<b>3436</b>	<b>3436</b>	09:51:48	<b>3436</b>	0
18-Feb.15	60.225	<b>3211</b>	10:40:18	0	<b>3211</b>	<b>3211</b>	10:40:18	<b>3211</b>	0
19-Feb.15	60.270	<b>3157</b>	11:00	19	<b>3176</b>	<b>3176</b>	11:00	<b>3157</b>	19
20-Feb.15	61.393	<b>3375</b>	10:47:16	0	<b>3375</b>	<b>3375</b>	10:47:16	<b>3375</b>	0
21-Feb.15	57.973	<b>3070</b>	10:30	0	<b>3070</b>	<b>3070</b>	10:30	<b>3070</b>	0
22-Feb.15	55.428	<b>3092</b>	10:03:49	0	<b>3092</b>	<b>3092</b>	10:03:49	<b>3092</b>	0
23-Feb.15	58.139	<b>3134</b>	18:56:34	2	<b>3136</b>	<b>3136</b>	18:56:34	<b>3134</b>	2
24-Feb.15	59.576	<b>3287</b>	10:13:07	0	<b>3287</b>	<b>3287</b>	10:13:07	<b>3287</b>	0
25-Feb.15	61.882	<b>3321</b>	10:26:53	0	<b>3321</b>	<b>3321</b>	10:26:53	<b>3321</b>	0
26-Feb.15	59.201	<b>3218</b>	09:53:38	0	<b>3218</b>	<b>3218</b>	09:53:38	<b>3218</b>	0
27-Feb.15	60.277	<b>3235</b>	10:30	0	<b>3235</b>	<b>3280</b>	10:00	<b>3221</b>	59
28-Feb.15	58.543	<b>3184</b>	10:35:36	0	<b>3184</b>	<b>3184</b>	10:35:36	<b>3184</b>	0
<b>TOTAL</b>	<b>1687.079</b>	<b>3847</b> 06.02.15	10:09:58	0	<b>3847</b> 06.02.15	<b>3847</b>	10:09:58	<b>3847</b>	0

### LOAD PATTERN OF DELHI ON THE DAY OF PEAK DEMAND MET DURING FEBRUARY 2015 ON 06.02.2015- 3847MW AT 10.09.58HRS.

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1637	0	1637
2	1540	0	1540
3	1466	0	1466
4	1492	0	1492
5	1665	0	1665
6	2372	0	2372
7	3226	1	3227
8	3551	7	3558
9	3658	0	3658
10	3807	0	3807
<b>10.09.58</b>	<b>3847</b>	<b>0</b>	<b>3847</b>
11	3668	0	3668
12	3474	0	3474
13	3171	0	3171
14	3852	0	3852
15	3862	0	3862
16	2765	0	2765
17	2771	0	2771
18	3073	0	3073
19	3252	17	3269
20	3196	0	3196
21	2894	0	2894
22	2635	0	2635
23	2274	0	2274
24	1953	0	1953
<b>Total (IN MUS)</b>	<b>65.149</b>	<b>0.018</b>	<b>65.167</b>



**11 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UN-RESTRICTED DEMAND DURING FEBRUARY 2015 ON 06.02.2015- 3847MW AT 10.09.58HRS.**


All figures in MW

Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1637	0	1637
2	1540	0	1540
3	1466	0	1466
4	1492	0	1492
5	1665	0	1665
6	2372	0	2372
7	3226	1	3227
8	3551	7	3558
9	3658	0	3658
10	3807	0	3807
<b>10.09.58</b>	<b>3847</b>	<b>0</b>	<b>3847</b>
11	3668	0	3668
12	3474	0	3474
13	3171	0	3171
14	3852	0	3852
15	3862	0	3862
16	2765	0	2765
17	2771	0	2771
18	3073	0	3073
19	3252	17	3269
20	3196	0	3196
21	2894	0	2894
22	2635	0	2635
23	2274	0	2274
24	1953	0	1953
<b>Total (IN MUS)</b>	<b>65.149</b>	<b>0.018</b>	<b>65.167</b>



**12 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM ENERGY CONSUMED DURING FEBRUARY 2015 – 04.02.2015 – 65.588Mus** All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
01:00	1599	0	1599
02:00	1490	0	1490
03:00	1431	0	1431
04:00	1483	0	1483
05:00	1705	0	1705
06:00	2341	0	2341
07:00	3172	0	3172
08:00	3375	0	3375
09:00	3607	0	3607
09.36.28	3785	0	3785
10:00	3751	0	3751
11:00	3683	0	3683
12:00	3497	0	3497
13:00	3229	0	3229
14:00	2972	4	2976
15:00	2910	0	2910
16:00	2812	0	2812
17:00	2855	0	2855
18:00	3048	0	3048
19:00	3340	1	3341
20:00	3233	1	3234
21:00	2986	0	2986
22:00	2717	0	2717
23:00	2290	0	2290
24:00	1883	0	1883
<b>Total (IN MUS)</b>	<b>65.588</b>	<b>0.018</b>	<b>65.597</b>



**13 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UNRESTRICTED ENERGY DEMAND DURING FEBRUARY 2015 – 04.02.2015 – 65.597 Mus**

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
01:00	1599	0	1599
02:00	1490	0	1490
03:00	1431	0	1431
04:00	1483	0	1483
05:00	1705	0	1705
06:00	2341	0	2341
07:00	3172	0	3172
08:00	3375	0	3375
09:00	3607	0	3607
09.36.28	3785	0	3785
10:00	3751	0	3751
11:00	3683	0	3683
12:00	3497	0	3497
13:00	3229	0	3229
14:00	2972	4	2976
15:00	2910	0	2910
16:00	2812	0	2812
17:00	2855	0	2855
18:00	3048	0	3048
19:00	3340	1	3341
20:00	3233	1	3234
21:00	2986	0	2986
22:00	2717	0	2717
23:00	2290	0	2290
24:00	1883	0	1883
<b>Total (IN MUS)</b>	<b>65.588</b>	<b>0.018</b>	<b>65.597</b>






14 LOAD DURATION CURVE FOR FEBRUARY 2015

Load in MW	Percentage of Time
Above 3600	0.149%
Above 3500	1.935%
Above 3400	5.394%
Above 3300	11.756%
Above 3200	18.750%
Above 3100	24.368%
Above 3000	29.948%
Above 2900	34.896%
Above 2800	39.137%
Above 2700	47.954%
Above 2600	57.180%
Above 2500	62.537%
Above 2400	65.848%
Above 2300	68.043%
Above 2200	69.978%
Above 2100	71.354%
Above 2000	73.028%
Above 1900	74.888%
Above 1800	76.935%
Above 1700	79.539%
Above 1600	82.552%
Above 1500	87.165%
Above 1400	96.949%
Above 1300	99.516%
Above 1200	99.814%
Above 1100	100.000%



FREQUENCY ANALYSIS FOR THE MONTH OF FEBRUARY 2015

Frequency Range in Hz.	Percentage of time
Above 50.6	0.190%
Above 50.4	2.230%
Above 50.2	19.720%
Above 50	85.640%
Above 49.8	99.890%
Above 49.6	99.960%
Above 49.4	100.000%



**16 VOLTAGE PROFILE OF 220 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2015**

**All figures in kV**

Date	NARELA		GAZIPUR	
	Max	Min	Max	Min
01-Feb.15	229.43	214.99	234.33	220.27
02-Feb.15	230.59	217.18	234.72	220.40
03-Feb.15	231.88	214.34	235.11	220.15
04-Feb.15	230.72	214.34	234.33	218.98
05-Feb.15	230.46	216.02	234.11	221.05
06-Feb.15	228.92	215.12	233.30	221.18
07-Feb.15	228.92	217.70	233.69	223.11
08-Feb.15	229.82	217.05	235.11	223.76
09-Feb.15	230.08	214.47	233.95	219.89
10-Feb.15	229.82	213.05	236.01	220.15
11-Feb.15	229.95	214.34	236.27	221.82
12-Feb.15	227.88	214.47	235.62	221.82
13-Feb.15	229.30	213.18	236.65	221.05
14-Feb.15	227.24	215.24	234.72	221.44
15-Feb.15	228.92	214.99	234.98	221.69
16-Feb.15	230.46	217.95	236.40	222.21
17-Feb.15	229.17	218.34	234.07	223.50
18-Feb.15	230.46	218.47	235.88	222.47
19-Feb.15	230.46	216.28	235.62	218.60
20-Feb.15	229.30	214.60	233.82	221.44
21-Feb.15	229.17	213.83	233.95	217.31
22-Feb.15	229.43	217.57	233.17	220.79
23-Feb.15	230.08	215.24	235.11	219.24
24-Feb.15	228.01	214.60	233.82	221.18
25-Feb.15	228.79	214.73	234.46	--
26-Feb.15	229.30	214.99	231.88	221.05
27-Feb.15	228.79	214.08	232.53	219.11
28-Feb.15	228.92	214.08	231.88	219.53

**17 VOLTAGE PROFILE OF 400 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2014**  
**All figures in kV**

Date	400kV Barnauli Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb.15	415.98	03.41.58	392.30	09.53	406.59
02-Feb.15	416.21	01.16.39	393.47	10.48	403.83
03-Feb.15	418.09	03.01.53	392.76	18.41	406.21
04-Feb.15	418.09	03.28.27	390.89	10.19	404.30
05-Feb.15	417.86	03.58.22	393.70	15.40	403.82
06-Feb.15	414.57	03.02.46	394.88	09.50	403.89
07-Feb.15	415.04	03.55.48	396.28	14.24	406.08
08-Feb.15	418.32	03.59.30	397.45	15.48	407.58
09-Feb.15	417.86	03.01.03	391.12	14.46	404.13
10-Feb.15	416.92	03.58.57	387.61	14.47	402.64
11-Feb.15	415.04	04.03.26	390.42	14.49	403.39
12-Feb.15	413.87	04.03.44	389.72	14.18	402.49
13-Feb.15	415.74	04.02.37	386.90	11.39	402.81
14-Feb.15	414.57	21.35.37	392.06	15.43	402.81
15-Feb.15	415.51	05.02.48	393.70	11.32	405.31
16-Feb.15	419.03	05.01.02	397.92	09.12	406.60
17-Feb.15	415.04	03.59.30	397.92	08.36	405.76
18-Feb.15	417.86	04.03.14	397.22	09.17	405.70
19-Feb.15	417.86	04.01.48	394.64	12.12	404.50
20-Feb.15	415.74	01.25.58	396.28	18.53	406.27
21-Feb.15	416.68	03.01.12	393.23	18.43	403.90
22-Feb.15	416.21	03.01.25	399.57	11.09	407.46
23-Feb.15	417.15	03.01.19	395.81	18.41	405.20
24-Feb.15	416.92	04.01.12	395.58	14.51	404.88
25-Feb.15	415.98	05.01	397.45	18.51	407.29
26-Feb.15	416.21	01.58	396.99	18.50	406.89
27-Feb.15	416.21	01.41	396.05	18.54	406.15
28-Feb.15	417.15	03.59	395.11	11.23	406.27

Date	400kV Bawana Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb.15	426.53	23.32.30	405.19	09.53	416.65
02-Feb.15	425.59	03.33.23	404.02	14.36	414.62
03-Feb.15	427.70	03.01.55	403.79	18.39	417.36
04-Feb.15	427.23	03.27.20	405.19	10.19	415.42
05-Feb.15	426.53	03.57.40	406.83	15.36	414.97
06-Feb.15	425.59	03.02.51	403.08	18.32	415.41
07-Feb.15	424.89	03.55.08	408.01	14.32	417.44
08-Feb.15	427.94	03.59.19	408.94	15.49	418.46
09-Feb.15	427.47	03.00.48	402.85	14.46	415.56
10-Feb.15	427.23	03.58.48	399.57	14.47	414.21
11-Feb.15	424.19	04.03.38	401.44	14.49	414.02
12-Feb.15	423.25	04.04.12	401.44	14.18	413.33
13-Feb.15	425.36	21.23.18	400.74	11.39	413.64
14-Feb.15	425.36	21.39.00	403.32	5.45	413.76
15-Feb.15	425.36	21.56.13	406.13	11.32	415.78
16-Feb.15	427.94	03.33.41	409.65	18.42	417.61
17-Feb.15	424.89	21.55.37	408.71	14.51	417.00
18-Feb.15	427.23	04.03.11	409.65	09.14	417.04
19-Feb.15	425.36	21.56.09	407.54	11.21	417.88
20-Feb.15	426.06	01.26.53	407.77	18.53	417.05
21-Feb.15	426.06	03.01.11	405.19	18.42	414.54
22-Feb.15	426.06	03.01.01	409.65	06.43	417.32
23-Feb.15	426.30	01.59.59	407.54	18.43	415.41
24-Feb.15	424.89	04.01.20	405.66	14.45	414.51
25-Feb.15	425.12	23.30	406.83	16.27	418.10
26-Feb.15	426.06	02.01	407.77	18.51	417.10
27-Feb.15	425.89	01.46	405.66	18.54	415.92
28-Feb.15	425.36	03.59	406.13	11.22	415.51

## 18 DETAILS OF LUMPED CAPACITORS AT NEAREST 220 KV SUBSTATION

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>1</b>	<b>IP YARD</b>		30		<b>30</b>
1	Kamla Market			16.35	<b>16.35</b>
2	Minto Road				<b>0</b>
3	GB Pant Hosp			15.88	<b>15.88</b>
4	Delhi Gate			10.9	<b>10.9</b>
5	Tilakmarg			5.04	<b>5.04</b>
7	Cannaught Place			10.08	<b>10.08</b>
8	Kilokri		10.08	10.48	<b>20.56</b>
9	NDSE				<b>0</b>
11	Nizamuddin				<b>0</b>
12	Exhibition-I				<b>0</b>
13	Exhibition-II				<b>0</b>
14	Defence Colony				<b>0</b>
15	IG Stadium		10.08	5.45	<b>15.53</b>
16	Lajpat Nagar				<b>0</b>
17	IP Estate			10.9	<b>10.9</b>
	<b>LT BYPL</b>				<b>5.6</b>
		<b>0</b>	<b>50.16</b>	<b>85.08</b>	<b>140.84</b>
<b>2</b>	<b>Electric Lane</b>				
1	Electric Lane			5.04	<b>5.04</b>
2	Scindia House			5.04	<b>5.04</b>
3	Raisina Road			10.08	<b>10.08</b>
4	Raja Bazar			10.08	<b>10.08</b>
	<b>LT NDMC</b>				<b>12</b>
		<b>0</b>	<b>0</b>	<b>30.24</b>	<b>42.24</b>
<b>3</b>	<b>RPH Station</b>		20		<b>20</b>
1	Lahori Gate			10.49	<b>10.49</b>
2	Jama Masjid			10.48	<b>10.48</b>
4	Kamla Market				<b>0</b>
5	Minto Road			10.9	<b>10.9</b>
6	GB Pant Hosp				<b>0</b>
7	IG Stadium				<b>0</b>
	<b>LT BYPL</b>				<b>3</b>
		<b>0</b>	<b>20</b>	<b>31.87</b>	<b>54.87</b>
<b>4</b>	<b>Parkstreet S/stn</b>	20	20		<b>40</b>
1	Shastri Park		10.896	5.45	<b>16.346</b>
2	Faiz Road			18.05	<b>18.05</b>
3	Motia Khan			16.3	<b>16.3</b>
4	Prasad Nagar			16.25	<b>16.25</b>
5	Anand Parbat			10.8	<b>10.8</b>
6	Shankar Road			5.04	<b>5.04</b>
7	Rama Road			0	<b>0</b>
8	Baird Road			10.08	<b>10.08</b>
9	Hanuman Road			5.04	<b>5.04</b>
10	Pusa			5.44	<b>5.44</b>
11	Ridge Valley			0	<b>0</b>
12	B. D. Marg			0	<b>0</b>
13	Nirman Bhawan			5.04	<b>5.04</b>
	<b>LT BYPL</b>			0	<b>30.1</b>
		<b>20.00</b>	<b>30.90</b>	<b>97.49</b>	<b>178.486</b>
<b>5</b>	<b>Naraina S/stn</b>		20	5.04	<b>25.04</b>
1	DMS			10.85	<b>10.85</b>
2	Mayapuri		10.87	10.4	<b>21.27</b>
3	Inderpuri		10	4.8	<b>14.8</b>
4	Rewari line				<b>0</b>
5	Khyber Lane		10.05		<b>10.05</b>
6	Kirbi Place		10.05		<b>10.05</b>
7	Payal			7.2	<b>7.2</b>
8	Saraswati Garden			10.88	<b>10.88</b>
		<b>0</b>	<b>60.97</b>	<b>49.17</b>	<b>110.14</b>

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>6</b>	<b>Mehrauli S/stn</b>	80		5.04	<b>85.04</b>
1	Adchini			14.61	<b>14.61</b>
2	Andheria Bagh			10.85	<b>10.85</b>
3	IIT			10.9	<b>10.9</b>
4	JNU		10.03	10.03	<b>20.06</b>
5	Bijwasan			15.47	<b>15.47</b>
6	DC Saket			9.98	<b>9.98</b>
7	Malviya Nagar				<b>0</b>
8	C Dot			10.48	<b>10.48</b>
9	Vasant kunj B-Blk	21.79		10.9	<b>32.69</b>
10	Vasant kunj C-Blk	20.16		10.48	<b>30.64</b>
11	Palam				<b>0</b>
12	IGNOU			5.04	<b>5.04</b>
13	R. K. Puram-I			10.07	<b>10.07</b>
14	Vasant Vihar			19.25	<b>19.25</b>
15	Pusp Vihar			10.44	<b>10.44</b>
16	Bhikaji Cama Place		10.08	10.07	<b>20.15</b>
	<b>LT BRPL</b>				<b>25</b>
		<b>121.95</b>	<b>20.11</b>	<b>163.61</b>	<b>330.67</b>
<b>7</b>	<b>Vasantkunj S/stn</b>	40		5.04	<b>45.04</b>
1	R. K. Puram-II			10.08	<b>10.08</b>
2	Vasant kunj C-Blk				<b>0</b>
3	Vasant kunj D-Blk			9.63	<b>9.63</b>
4	Ridge Valley				<b>0</b>
	<b>LT BRPL</b>				<b>33.2</b>
		<b>40</b>	<b>0</b>	<b>24.75</b>	<b>97.95</b>
<b>8</b>	<b>Okhla S/stn</b>	60	10	5.04	<b>75.04</b>
1	Balaji			10.8	<b>10.8</b>
2	East of Kailash			15.89	<b>15.89</b>
3	Alaknanda			16.3	<b>16.3</b>
4	Malviya Nagar	21.79		10.85	<b>32.64</b>
5	Masjid Moth			16.3	<b>16.3</b>
6	Nehru Place			21.34	<b>21.34</b>
7	Okhla Ph-I	21.79		16.3	<b>38.09</b>
8	Okhla Ph-II		20.93	15.47	<b>36.4</b>
9	Shivalik			10.8	<b>10.8</b>
10	Batra			15.9	<b>15.9</b>
11	VSNL			10.9	<b>10.9</b>
12	Siri Fort			10.49	<b>10.49</b>
13	Tuglakabad			10.85	<b>10.85</b>
	<b>LT BRPL</b>				<b>59</b>
		<b>103.58</b>	<b>30.93</b>	<b>187.23</b>	<b>380.74</b>
<b>9</b>	<b>Lodhi Road S/stn</b>		20		<b>20</b>
1	Defence Colony		14.85		<b>14.85</b>
2	Hudco		10.9		<b>10.9</b>
3	Lajpat Nagar		10.9		<b>10.9</b>
4	Nizamuddin		10.44		<b>10.44</b>
5	Vidyut Bhawan				<b>0</b>
6	Ex. Gr. II				<b>0</b>
7	IHC				<b>0</b>
	<b>LT BRPL</b>				<b>42</b>
		<b>0</b>	<b>67.09</b>	<b>0</b>	<b>109.09</b>
<b>10</b>	<b>Sarita Vihar S/stn</b>	20		5.04	<b>25.04</b>
1	Sarita Vihar			10.07	<b>10.07</b>
2	MCIE			10.06	<b>10.06</b>
3	Mathura Road	20.16		11.69	<b>31.85</b>
4	Jamia Millia			10.89	<b>10.89</b>
5	Sarai Julena		10.08	16.29	<b>26.37</b>
6	Jasola			5.44	<b>5.44</b>
	<b>LT BRPL</b>				<b>23.6</b>
		<b>40.16</b>	<b>10.08</b>	<b>69.48</b>	<b>143.32</b>

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>11</b>	<b>Wazirabad</b>				
1	Bhagirathi		14.4	10.9	25.3
2	Ghonda	21.79	22.56	15.94	60.29
3	Seelam Pur		10.08	21.39	31.47
4	Dwarkapuri			15.46	15.46
5	Nandnagri	20.16		16.35	36.51
6	Yamuna Vihar			16.2	16.2
7	East of Loni Road			10.8	10.8
8	Shastri Park			10.9	10.9
9	Karawal Nagar			5.4	5.4
10	Sonia Vihar			7.2	7.2
	<b>LT BYPL</b>				<b>10</b>
		<b>41.95</b>	<b>47.04</b>	<b>130.54</b>	<b>229.53</b>
<b>12</b>	<b>Geeta Colony</b>				
1	Geeta Colony				0
2	Kanti Nagar			10.49	10.49
3	Kailash Nagar			10.9	10.9
4	Seelam Pur			15.48	15.48
5	Shakar Pur				0
	<b>LT BYPL</b>				<b>5.8</b>
		<b>0</b>	<b>0</b>	<b>36.87</b>	<b>42.67</b>
<b>13</b>	<b>Gazipur S/stn</b>	40		5.04	45.04
1	Dallupura	28.8		10.9	39.7
2	Vivek Vihar			9.57	9.57
3	GT Road			10.85	10.85
4	Kondli	20.16		10.85	31.01
5	MVR-I			10.9	10.9
6	MVR-II	20.16		10.9	31.06
7	PPG Ind. Area			10.06	10.06
	<b>LT BYPL</b>				<b>20.6</b>
		<b>109.12</b>	<b>0</b>	<b>79.07</b>	<b>208.79</b>
<b>14</b>	<b>Patparganj S/stn</b>	40	20	5.04	65.04
1	GH-I	19.89		10.45	30.34
2	GH-II	20.09		10.9	30.99
3	CBD		10.03	15.48	25.51
4	Guru Angad Nagar			15.49	15.49
5	Karkadooma		10.8	10.44	21.24
6	Preet Vihar			10.07	10.07
7	CBD-II			10.8	10.8
8	Shakarpur			10.8	10.8
9	Jhilmil			10.8	10.8
10	Dilshad Garden	20.16		16.35	36.51
11	Khichipur	21.79		10.49	32.28
12	Mother Dairy				0
13	Scope Building				0
14	Vivek Vihar				0
15	Akhardham			14.6	14.6
	<b>LT BYPL</b>				<b>23.3</b>
		<b>121.93</b>	<b>40.83</b>	<b>151.71</b>	<b>337.77</b>
<b>15</b>	<b>Najafgarh S/stn</b>	60		5.04	65.04
1	A4 Paschim Vihar			10.8	10.8
2	Nangloi	21.73		15.84	37.57
3	Nangloi WW	20.89		10.85	31.74
4	Pankha Road			15.88	15.88
5	Jaffarpur			15.43	15.43
7	Inst. Area Janakpuri			17.6	17.6
8	Paschimpuri		10.05	15.47	25.52
9	Paschim Vihar	41.83		15.43	57.26
10	Mukherjee Park			20.83	20.83
11	Udyog Nagar			10.43	10.43
12	Choukhandi			10.07	10.07
	<b>LT BRPL</b>				<b>27</b>
		<b>144.45</b>	<b>10.05</b>	<b>163.67</b>	<b>345.17</b>



Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>16</b>	<b>Pappankalan-I S/stn</b>	20		5.04	<b>25.04</b>
1	Bindapur Grid G-3 PPK	21.73		15.85	<b>37.58</b>
2	Bodella-I	20.1		16.24	<b>36.34</b>
3	Bodella-II	21.73		17.64	<b>39.37</b>
4	DC Janakpuri			10.03	<b>10.03</b>
5	G-2 PPK			10.8	<b>10.8</b>
6	G-5 PPK			15.51	<b>15.51</b>
7	G-6 PPK			5.4	<b>5.4</b>
8	G-15 PPK			10.8	<b>10.8</b>
9	Harinagar	21.18		16.25	<b>37.43</b>
10	Rewari line			5.44	<b>5.44</b>
	<b>LT BRPL</b>				<b>13.5</b>
		<b>104.74</b>	<b>0</b>	<b>129</b>	<b>247.24</b>
<b>17</b>	<b>BBMB Rohtak Road</b>				
1	S.B. Mill			10.07	<b>10.07</b>
2	Rama Road			10.88	<b>10.88</b>
3	Ram Pura			10.48	<b>10.48</b>
4	Rohtak Road			8.04	<b>8.04</b>
5	Vishal			10.4	<b>10.4</b>
6	Tri Nagar			5.44	<b>5.44</b>
7	Madipur			10.43	<b>10.43</b>
8	Sudershan Park			10.08	<b>10.08</b>
9	Kirti Nagar			5.44	<b>5.44</b>
		<b>0</b>	<b>0</b>	<b>81.26</b>	<b>81.26</b>
<b>18</b>	<b>Shalimarbagh S/stn</b>		40	6	<b>46</b>
1	S.G.T. Nagar			5.44	<b>5.44</b>
2	Wazirpur-1			17.18	<b>17.18</b>
3	Wazirpur-2			11.39	<b>11.39</b>
4	Ashok Vihar			5.44	<b>5.44</b>
5	Rani Bagh			10.88	<b>10.88</b>
6	Haiderpur			11.39	<b>11.39</b>
7	SMB FC			5.44	<b>5.44</b>
8	SMB KHOSLA			5.44	<b>5.44</b>
	<b>LT TPDDL</b>				<b>30</b>
		<b>0</b>	<b>40</b>	<b>78.6</b>	<b>148.6</b>
<b>19</b>	<b>Subzimandi S/stn</b>			6	<b>6</b>
1	Shakti Nagar			5.94	<b>5.94</b>
2	Gulabibagh			10.88	<b>10.88</b>
3	Shahzadabagh			13.68	<b>13.68</b>
4	DU			5.44	<b>5.44</b>
5	Tripolia			10.88	<b>10.88</b>
	B. G. Road			5.4	<b>5.4</b>
	<b>LT BYPL</b>				<b>0.9</b>
	<b>LT TPDDL</b>				<b>20</b>
		<b>0</b>	<b>0</b>	<b>58.22</b>	<b>79.12</b>
<b>20</b>	<b>Narela S/stn</b>	40		5.04	<b>45.04</b>
1	A-7 Narela			10.88	<b>10.88</b>
2	AIR Kham pur			6	<b>6</b>
3	Ashok vihar			10.48	<b>10.48</b>
4	Azad Pur			5.44	<b>5.44</b>
5	Tri Nagar			5.44	<b>5.44</b>
6	Badli	20		5.95	<b>25.95</b>
7	DSIDC Narela-1			5.95	<b>5.95</b>
8	GTK			5.44	<b>5.44</b>
9	Jahangirpuri	20	10	0	<b>30</b>
10	Bhalswa			3.6	<b>3.6</b>
	<b>LT TPDDL</b>				<b>10</b>
		<b>80</b>	<b>10</b>	<b>64.22</b>	<b>164.22</b>

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>21</b>	<b>Gopalpur S/stn</b>		30	5.04	<b>35.04</b>
1	Azad Pur			10.88	<b>10.88</b>
2	Hudson Lane			5.44	<b>5.44</b>
3	Wazirabad			2.4	<b>2.4</b>
4	Indra Vihar			5.44	<b>5.44</b>
6	GTK Road			5.94	<b>5.94</b>
7	Jahangirpuri		10	5.95	<b>15.95</b>
8	Civil lines			5.44	<b>5.44</b>
9	Pitam Pura-1			5.44	<b>5.44</b>
10	Pitam Pura-3			5.44	<b>5.44</b>
11	Air Khampur			5.95	<b>5.95</b>
12	SGT Nagar			5.95	<b>5.95</b>
13	Tiggipur			10.88	<b>10.88</b>
	<b>LT TPDDL</b>				<b>29</b>
		<b>0</b>	<b>40</b>	<b>80.19</b>	<b>149.19</b>
<b>22</b>	<b>Rohini S/stn</b>	40		6	<b>46</b>
1	Rohini Sec-22			10.88	<b>10.88</b>
2	Rohini Sec-23	20		5.44	<b>25.44</b>
3	Rohini Sec-24			5.44	<b>5.44</b>
4	Rohini-1			5.44	<b>5.44</b>
5	Rohini-3			5.95	<b>5.95</b>
6	Rohini-4			11.39	<b>11.39</b>
7	Rohini-5			11.39	<b>11.39</b>
8	Rohini-6			5.95	<b>5.95</b>
9	Mangolpuri-1			16.83	<b>16.83</b>
10	Mangolpuri-2	20		5.94	<b>25.94</b>
11	Pitam Pura-1	20		5.04	<b>25.04</b>
12	Pitam Pura-2			10.48	<b>10.48</b>
13	Rohini DC-1			14.4	<b>14.4</b>
	<b>LT TPDDL</b>				<b>30</b>
		<b>100</b>	<b>0</b>	<b>120.57</b>	<b>250.57</b>
<b>23</b>	<b>Kanjhawa S/stn</b>	20		5.04	<b>25.04</b>
1	Bawana Clear Water			10.88	<b>10.88</b>
2	Pooth Khoord			5.44	<b>5.44</b>
		<b>20</b>	<b>0</b>	<b>21.36</b>	<b>41.36</b>
<b>24</b>	<b>BAWANA S/stn</b>				
1	Bawana S/stn No. 6			10.88	<b>10.88</b>
2	Bawana S/stn No. 7				<b>0</b>
		<b>0</b>	<b>0</b>	<b>10.88</b>	<b>10.88</b>
<b>25</b>	<b>Kashmerigate S/stn</b>			5.04	<b>5.04</b>
1	Civil lines			5.44	<b>5.44</b>
2	Town Hall			8.64	<b>8.64</b>
3	Fountain			5.45	<b>5.45</b>
	<b>LT BYPL</b>				<b>2.7</b>
		<b>0</b>	<b>0</b>	<b>24.57</b>	<b>27.27</b>
<b>26</b>	<b>Pappankalan-II</b>				
1	DMRC-I				<b>0</b>
2	DMRC-II				<b>0</b>
<b>27</b>	<b>Trauma Center (AIIMS)</b>				
1	AIIMS		13.26	5.04	<b>18.3</b>
2	Trauma Center			10.08	<b>10.08</b>
3	Netaji Nagar			15.12	<b>15.12</b>
4	Sanjay Camp			10.08	<b>10.08</b>
5	Kidwai Nagar			5.04	<b>5.04</b>
6	SJ Airport			5.04	<b>5.04</b>
	Race Course			5.04	<b>5.04</b>
		<b>0</b>	<b>13.26</b>	<b>55.44</b>	<b>68.7</b>

Sl. No	SUB-STATION	INSTALLED CAPACITY			
		66KV	33kV	11kV	TOTAL
<b>28</b>	<b>MUNDKA</b>				
	Rohini-2			11.39	11.39
	<b>LT BRPL</b>				18.5
		0	0	11.39	29.89
<b>29</b>	<b>DSIDC BAWANA</b>				
	DSIDC NRL-1	20			20
	DSIDC NRL-2			10.88	10.88
		20	0	10.88	30.88
<b>30</b>	<b>RIDGE VALLEY</b>				
	Keventry Diary			10.08	10.08
	Nehru Park			5.04	5.04
	Bapu Dham			10.08	10.08
		0	0	25.2	25.2
<b>31</b>	<b>IP EXTN (PRAGATI)</b>				
	Vidyut Bhawan			10.08	10.08
	Dalhousie Road			5.04	5.04
	School Lane			5.04	5.04
	<b>LT NDMC</b>				12.29
		0	0	20.16	32.45
	<b>TOTAL CAPACITY</b>	1067.9	491.4	2092.7	4139

Utility	HT	LT	Total
BYPL	864	102	966
TPDDL	657	119	776
NDMC	180	24	204
DTL	754	0	754
BRPL	1158	242	1400
RPH	20	0	20
MES	20	0	20
<b>TOTAL</b>	<b>3652</b>	<b>487</b>	<b>4139</b>

**20      DETAILS OF BREAK-DOWNS DURING THE MONTH OF FEBRUARY 2015**

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
1	26-04-14	06:00	INDRAPRASTHA POWER 33kV 10MVAR CAP. BANK-III	Contd.		CAPACITOR BANK NO-3 IS UNDER OUTAGE DUE TO NON AVAILABILITY OF NCT.
2	14-06-14	04:18	220kV MAHARANIBAGH-MASJID MOTH CKT-I	11-02-15	09:57	AT MAHARANI BAGH CKT TRIPPED ON D/P,R-PH,Z-1, DIST-3.2KMS. AT MASJID MOTH D/P,Z-1. TRIED AT MAHARANI BAGH AT 04.47HRS. BUT AGAIN TRIPPED. CABLE OF THE CKT DECLARED FAULTY AS CABLE DAMAGED IN DIGGING OPERATION BY PGCIL CONTRACTOR.
3	17-09-14	15:33	220kV GAZIPUR - BTPS CKT	Contd.		AT BTPS CKT TRIPPED ON D/P,Z-1,Y-PH, DIST-10.2KMS. AT GAZIPUR CKT TRIPPED ON D/P,Z-1,Y-PH, DIST-9.69KMS. CABLE FAULTY BEING REPLACED BY TRANSMISSION COMPANY OF UP .
4	19-12-14	18:51	220kV MAHARANIBAGH-TRAUMA CENTER CKT-I	Contd.		AT MAHARANIBAGH CKT TRIPPED ON Y-PH E/F. AT TRAUMA CENTER CKT TRIPPED ON D/P, Z-1, B-PH. CABLE FAULTY.
5	11-01-15	14:26	BAWANA 400/220kV 315MVA ICT-II	03-02-15	12:24	ICT MADE OFF DUE TO POOR DGA TEST RESULT. FORMATION OF HIGH LEVEL OF ACETYLENE GAS NOTED IN DGA TEST. INTERNAL INSPECTION DONE AND TX OIL CHANGED.
6	01-02-15	03:45	NARELA 220/66kV 100MVA Tx-I	01-02-15	04:09	TX TRIPPED ON 186.
7	01-02-15	00:18	400kV Ballabgarh-Bamnauli Ckt-II	01-02-15	00:35	AT BAMNAULI CKT TRIPPED ON D/P,MAIN-2,C-N-PH,Z-1, AND 186. NO TRIPPING AT OTHER END.
8	02-02-15	01:23	220KV SHALIMARBAGH-WAZIRPUR CKT-II	02-02-15	02:34	AT SMB CKT TRIPPED ON : MAIN-1, MAIN-2: GENERAL TRIP, MASTER TRIP. NO TRIPPING AT WAZIRPUR.
9	04-02-15	09:40	220kV KANJHAWALA-NAJAFGARH CKT-2	04-02-15	16:52	AT KANJHAWALA CKT TRIPPED ON D/P,B-Y-PH,DIST-7.2KM. AT NJF CKT TRIPPED ON D/P,B-C-PH,DIST-7.835KM. 220KV BUS COUPLER ALSO TRIPPED ON E/F AND O/C AT KANJHAWALA.
10	07-02-15	05:15	PRAGATI 220/66kV 160MVA Tx-I	07-02-15	00:01	BUS BAR PROTECTION OPERATED AT GT. 66KV I/C-1 OF TX TRIPPED ON BUS DIFFERENTIAL AT GT STATION. PT JUMPER OF DMRC CKT-1 TOWARDS BUS-3 SNAPPED AT GT YARD.
11	07-02-15	05:15	PRAGATI 220/66kV 160MVA Tx-II	07-02-15	11:09	TX TRIPPED ON OLTC BUCHHOLZ AND 86.
12	08-02-15	08:01	BAWANA 400/220kV 315MVA ICT-IV	08-02-15	11:25	ICT TRIPPED ON DIFFERENTIAL PROTECTION,R,Y AND B-PH. 220KV I/C-4 TRIPPED ON DIFFERENTIAL PROTECTION.R-PH BUS ISOLATOR DROPPED JUMPER 220KV SIDE DAMAGED.
13	08-02-15	08:01	220KVBAWANA- ROHINI CKT-II	08-02-15	08:29	AT ROHINI-2 CKT TRIPPED ON D/P,Z-1. NO TRIPPING AT BAWANA.
14	09-02-15	19:13	220kV GOPALPUR-SUBZI MANDI CKT-I	10-02-15	13:45	AT GOPALPUR CKT TRIPPED ON VT FUSE FAILURE. NO TRIPPING AT SUBZIMANDI
15	10-02-15	10:35	DIAL 220/66kV 160MVA Tx-II	02-03-15	14:54	POOR DGA TEST RESULT. TX MADE OFF DUE TO FORMATION OF ACETYLENE GAS
16	11-02-15	22:20	LODHI RD 33/11kV, 16MVA Tx-III	11-02-15	23:10	TX TRIPPED ALONG WITH 11KV I/C-3 TRIPPED ON DIFFERENTIAL,R Y AND B PHASE ALONG WITH 11KV NBCC EAST BLOCK FEEDER TRIPPED WITHOUT INDICATION.
17	16-02-15	06:35	LODHI RD 33/11kV, 16MVA Tx-III	16-02-15	06:58	TX TRIPPED ON DIFFERENTIAL.
18	17-02-15	17:02	220kV BAMNAULI-NARAINA CKT-I	17-02-15	17:40	AT BAMNAULI CKT TRIPPED ON 186 A&B. NO TRIPPING AT NARAINA.
19	19-02-15	18:27	LODHI RD 33/11kV, 16MVA Tx-III	19-02-15	18:36	TX TRIPPED ON DIFFERENTIAL Y & B-PH. 11KV I/C-3 TRIPPED ON 86.

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
20	19-02-15	18:36	LODHI RD 33/11kV, 16MVA Tx-III	19-02-15	18:40	TX TRIPPED ON DIFFERENTIAL Y & B-PH. 11KV I/C-3 TRIPPED ON 86.
21	21-02-15	06:05	ROHINI 66/11kV, 20MVA Tx-II	21-02-15	06:26	TX ALONG WITH 11KV I/C-2 TRIPPED ON 86.
22	24-02-15	14:12	MASJID MOTH 220/33kV 100MVA Tx-I	24-02-15	14:50	33KV I/C-1 TRIPPED ON 86 ALONG WITH 33KV SIRI FORT FEEDER WHICH TRIPPED ON O/C,E/F. B & Y- CT OF 33KV SIRI FORT FEEDER DAMAGED.
23	24-02-15	14:12	MASJID MOTH 220/33kV 100MVA Tx-II	24-02-15	14:32	33KV I/C-2 TRIPPED ON O/C,E/F ALONG WITH 33KV SIRI FORT FEEDER WHICH TRIPPED ON O/C,E/F. B & Y- CT OF 33KV SIRI FORT FEEDER DAMAGED.
24	24-02-15	14:12	MASJID MOTH 33 KV SIRIFORT	24-02-15	19:10	CKT TRIPPED ON O/C,E/F. B & Y- CT OF CKT DAMAGED.
25	24-02-15	17:53	PAPPANKALAN-I 220/66kV 100MVA Tx-IV	24-02-15	18:15	TX TRIPPED ON O/C, E/F,86B ALONG WITH 66KV I/C-4 WHICH TRIPPED ON INTER TRIP.
26	24-02-15	06:50	220kV DSII DC BAWANA-NARELA CKT-II	23-01-15	12:54	AT DSIDC CKT TRIPPED ON D/P, B-PH, DIST-1.29 KM. NO TRIPPING AT NARELA.
27	25-02-15	09:31	220kV BAWANA - KANJHAWALA CKT-2	25-02-15	09:50	AT BAWANA CKT TRIPPED ON D/P,Z-1,C-PH,DIST-1.85KM. AT KANJHAWALA CKT TRIPPED ON D/P, R & Y-PH.
28	25-02-15	16:15	220 KV I.P.- RPH CKT-I	25-02-15	16:50	AT RPH CKT TRIPPED ON O/C,E/F, 186A&B, A/R. NO TRIPPING AT IP S/STN.
29	26-02-15	22:40	PATPARGANJ 220/33kV 100MVA Tx-I	26-02-15	23:02	TX WAS MADE OFF AS TRIP CKT FAULTY INDICATION APPEARED ON RELAY PANEL. TX MADE OFF FOR INSPECTION.
30	26-01-15	12:05	220kV MEHRAULI - BTPS CKT. - I	26-02-15	16:19	AT MEHRAULI CKT TRIPPED ON D/P,Z-2,A-N-PH, DIST-15.5KM. AT BTPS CKT TRIPPED ON D/P,Z-1,DIST-2.9KM.
31	27-02-15	13:02	OKHLA 33kV NEHRU PLACE CKT-II	27-02-15	16:10	CKT TRIPPED ON E/F. MONKEY ELECTROCUTED IN YARD.
32	28-02-15	01:30	220kV WAZIRABAD-GEETA COLONY CKT-I	28-02-15	02:06	CKT MADE OFF AS PROBLEM OCCURED IN TRIP CKT OF CB.

**20 DETAILS OF UNDER FREQUENCY RELAY OPERATIONS IN DELHI POWER SYSTEM DURING THE MONTH OF FEBRUARY 2015**

DATE	S. N.	TIME		Name of Grid	NAME OF AFFECTED FEEDERS	MODE	LOAD RELIEF IN MW
		OUT	IN				
25.02.15	1	14:20	14:25	220KV GAZIPUR	66KV KONDLI CKT. I & II, 66KV VIVEK VIHAR CKT. I & II	DF/DT MODE	84