

DELHI TRANSCO LTD.

STATE LOAD DISPATCH CENTER

PROGRESS REPORT

FEBRUARY 2012

S. No.	CONTENTS	Page No.
1.	Salient Features of Delhi Power System	3
2.	Performance of Generating Stations within Delhi	4
3.	Details of Outage of Generating Stations within Delhi	5-26
4.	Allocation of Power to Delhi from unallocated quota of central sector	27-31
5.	Allocation of Power to Discoms	32
6.	Power Availability Demand Position of Delhi at the time of occurrence of Peak Demand	33
7.	Power Availability Demand Position of Delhi at the time of occurrence of Maximum Un-Restricted Demand	34
8.	Source wise scheduled drawl from grid and Availability within Delhi	35-37
9.	Shedding Details	38-41
10.	Load Curve for the Day of Peak Demand	42
11.	Load Curve for the day of occurrence of Maximum Un-Restricted Demand	43
12.	Load Curve for the day of Maximum Energy Consumed	44
13.	Load Curve for the day of Maximum Un-Restricted Energy Demand	45
14.	Load Duration Curve	46
15.	Frequency Analysis	47
16.	Voltage Profile for significant 220kV Sub-Stations	48
17.	Voltage Profile for significant 400kV Sub-Stations	49-50
18.	Details of Capacitors Installations in Delhi	51-56
19.	Tripping Details of 400/220 KV System in Delhi Power System	57-58
20.	Details of Under frequency Relay operations in Delhi Power System	59

SALIENT FEATURES OF DELHI POWER SYSTEM

Sr. No.	Features	FEBRUARY 2012	FEBRUARY 2011
1	Effective Generation Capacity within Delhi in MW		
	Rajghat Power House	135	135
	Gas Turbine	270	270
	Pragati Power Corporation Ltd.	330	330
	Badapur Thermal Power Station	705	705
	Rithala GT	108	73
	Total	1548	1513
2	Maximum Unrestricted Demand (MW)	3608	3306
	Date	03.02.2012	04.02.2011
	Time	10.04.57	10.01.26
3	Peak Demand met (MW)	3608	3306
	Date	03.02.2012	04.02.2011
	Time	10.04.57	10.01.26
4	Peak Availability (MW)	3551	3381
5	Shortage (-) / Surplus (+) in MW	(-)51	(+)75
6	Percentage Shortage (-) / Surplus (+)	(-)1.41	(+) 2.27
7	Maximum Energy Consume in a day (Mus)	64.033	57.931
8	Energy Consumed during the month	1702.186	1524.178
9	Load Shedding in Mus		
A)	Due to Grid Restrictions		
i)	Under Frequency Relay Operations	0.000	0.004
ii)	Manual Load shedding from DTL S/Stns.	0.000	0.000
iii)	Load Shedding due to low frequency / Low Voltage / TTC/ATC Violation		
	NDPL	0.185	0.082
	BRPL	0.022	0.158
	BYPL	0.006	0.000
	NDMC	0.000	0.000
	MES	0.000	0.000
iv)	Due to transmission Constraints in Central Sector	0.000	0.000
	Total due to Grid Restriction	0.213	0.244
B)	Due to Constraints in System in Mus		
	DTL	0.100	0.212
	NDPL	2.247	0.396
	BRPL	0.160	0.144
	BYPL	0.103	0.150
	NDMC	0.000	0.001
	MES	0.000	0.000
	Other Agencies	0.008	0.002
	Total	2.618	0.905
11	Grand Total in Mus	2.831	1.149

2. **PERFORMANCE OF GENERATING STATIONS WITHIN DELHI DURING FEBRUARY 2012**

A) For the month of FEBRUARY 2012

All Figures in MUs

S. No	Stations	Gross Generation	Aux. Consumption	Net Generation	Availability (%)	Backing Down
1.	RPH	73.084	8.762	64.322	77.54	0
2.	GT	56.053	1.819	54.234	87.85	107.344
3.	PPCL	209.629	4.966	204.663	97.92	14.288
4.	BTPS	406.728	8.99	397.738	101.82	79.566
5.	Rithala	14.038	0.263	13.775	--	--
6.	Bawana	81.151	1.611	79.540	68.68	31.703
	TOTAL	840.683	26.411	814.272		

B) For the Year 2011-12 (Upto FEBRUARY 2012)

Power Station	Effective Capacity (MW)	Net Generation in MUs For FEB 2012	Availability (%) For FEB. 2012	PLF (%) For FEB. 2012	Cumulative Generation in MUs upto FEB. 2012 for the year 2011-12	Cumulative Availability in % upto FEB. 2012 for the year 2011-12	Cumulative PLF in % upto FEB. 2012 for the year 2011-12
RPH	135	64.322	77.54	77.54	737.909	67.92	67.84
GT	270	54.234	87.85	28.96	1165.977	78.30	53.17
PPCL	330	204.663	97.92	91.50	2332.554	92.26	87.45
BTPS	705	397.738	101.82	83.60	4038.143	87.60	77.04
Rithala	108	13.775	--	--	221.425	--	--
Bawana	216	79.540	68.68	47.38	167.717	55.36	41.00
TOTAL	1764	814.272			8663.725		

3 DETAILS OF OUTAGES OF GENERATING STNS. WITHIN DELHI W.E.F. APRIL 2010

(A) RPH STATION

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	67.5	11.05.11	20.11	11.05.11	21.28	Flash in yard
		21.05.11	01.53	21.05.11	05.25	Tripped alongwith tripping of associated transmission lines
		22.05.11	23.00	23.05.11	01.55	Boiler flame failure
		31.05.11	12.35	02.06.11	03.03	Condenser tube leakage
		10.06.11	05.40	10.06.11	12.32	UAT abnormality
		10.06.11	12.45	10.06.11	13.00	UAT abnormality
		03.07.11	11.40	06.07.11	17.19	Due to fire in 220/33kV 100MVA Pr. Tr.
		10.07.11	21.30	28.07.11	10.08	Tripped alongwith tripping of associated transmission lines
		30.07.11	14.50	31.07.11	24.00	Moisture in IBT -2
		06.08.11	06.32	08.08.11	01.31	Desynchronization due to moisture in 220kV Pr. Tr.
		15.08.11	14.17	15.08.11	21.20	Stopped due to low demand and high frequency.
		25.08.11	18.07	27.08.11	4.17	Boiler tube leakage
		01.09.11	11.41	01.09.11	12.52	Turbine tripped
		02.09.11	04.22	12.09.11	05.20	Boiler tube leakage
		13.09.11	07.05	13.09.11	09.01	Boiler flame failure
		15.09.11	12.01	15.09.11	13.12	Boiler flame failure
		15.09.11	12.45	16.09.11	00.09	Boiler flame failure
		16.09.11	17.03	18.09.11	17.50	Stopped due to wet coal
		19.09.11	00.10	19.09.11	01.28	Boiler flame failure
		21.09.11	03.46	21.09.11	04.50	Boiler flame failure
		02.10.11	12.33	02.10.11	12.54	High furnance pressure
		04.10.11	18.16	05.10.11	07.53	Leakage in boiler durm
		17.10.11	18.23	17.10.11	20.50	C&I Fault
		19.10.11	09.42	19.10.11	10.40	Furnance pressure high
		19.10.11	13.20	23.10.11	02.08	Boiler tube leakage
		23.10.11	15.58	23.10.11	16.35	Durm level very low
		01.11.11	13.03	01.11.11	13.35	Due to tripping of bay No. 9
		10.11.11	09.55	10.11.11	12.42	C & I Problem
		11.11.11	11.27	11.11.11	13.18	Due to tripping of bay No. 2
		11.11.11	13.33	11.11.11	17.19	Turbine problem
		15.11.11	21.35	26.11.11	23.05	Boiler tube leakage
		05.12.11	22.08	06.12.11	08.07	Grid Disturbance
		06.12.11	08.58	06.12.11	09.32	Boiler flame failure
		12.12.11	11.47	12.12.11	12.44	Both FD fans tripped
		12.12.11	22.21	19.12.11	16.32	Boiler tube leakage
		24.12.11	17.10	24.12.11	17.35	Flame failure
		24.12.11	20.15	29.12.11	21.16	Boiler tube leakage
		04.01.12	14.06	21.01.12	21.50	Flame failure
		23.01.12	21.35	27.01.12	01.28	Very low furnance pressure
		03.02.12	21.33	08.02.12	13.12	Boiler tube leakage
26.02.12	11.40	26.02.12	13.42	Grid disturbance		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	67.5	03.04.11	23.45	04.04.11	01.40	Turbine shaft vibration high
		28.04.11	06.38	28.04.11	15.27	To attend hot spot on 33kV Breaker
		21.05.11	01.53	21.05.11	07.32	Tripped alongwith tripping of associated transmission lines
		22.05.11	21.14	22.05.11	22.00	FD fan tripping
		26.05.11	12.10	26.05.11	13.00	Low boiler drum level
		31.05.11	23.15	01.06.11	08.12	Condenser tube leakage
		02.06.11	11.07	04.06.11	11.14	Boiler tube leakage
		04.06.11	16.50	04.06.11	17.50	Tripped on jerk
		04.06.11	18.18	04.06.11	20.12	Feed pump problem
		03.07.11	11.40	06.07.11	10.37	Due to fire in 220/33kV 100MVA Pr. Tr.
		10.07.11	13.53	27.07.11	05.10	Due to IBT-I, protection relay operated
		27.07.11	11.38	27.07.11	21.04	Due to tripping of bay no. 17
		30.07.11	14.50	31.07.11	03.45	Moisture in IBT -2
		06.08.11	07.00	08.08.11	00.10	Desynchronization due to moisture in 220kV Pr. Tr.
		15.08.11	14.21	15.08.11	22.00	Stopped due to low demand and high frequency.
		20.08.11	00.31	20.08.11	01.20	Boiler flame failure
		30.08.11	00.24	31.08.11	24.00	Boiler tube leakage
		31.08.11	00.00	01.09.11	08.38	Boiler tube leakage
		10.09.11	00.08	12.09.11	05.00	Coal handling plant problem
		13.09.11	03.50	13.09.11	05.00	Electrical fault
		25.09.11	10.57	25.09.11	11.30	Turbine vibration
		30.09.11	22.14	03.10.11	06.00	Boiler tube leakage
		01.11.11	13.03	01.11.11	13.50	Due to tripping of bay no. 19
		03.11.11	20.16	03.11.11	13.45	Turbine problem
		08.11.11	21.05	11.11.11	00.13	Boiler tube leakage
		11.11.11	11.27	11.11.11	14.16	Due to tripping of bay no. 2
		16.11.11	16.10	16.11.11	16.50	Electrical fault
		17.11.11	09.36	17.11.11	10.05	Turbine tripped
		25.11.11	12.35	25.11.11	13.23	
		30.11.11	20.58	30.11.11	22.55	Turbine vibration high
		30.11.11	23.12	01.12.11	03.35	
		01.01.11	10.06	01.12.11	10.33	
		05.12.11	22.08	06.12.11	05.22	Grid disturbance
		07.12.11	13.08	07.12.11	14.07	Due to tripping of Pr. Tr.
		05.01.12	06.02	05.01.12	12.30	Tripped on jerk
		16.01.12	14.54	17.01.12	01.10	Electrical fault
		24.02.12	07.17	24.02.12	09.46	Due to leakage in boiler leakage pump
		26.02.12	10.54	26.02.12	13.02	Grid disturbance

(B)

Gas Turbine

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	01.04.11	00.00	11.04.11	20.25	Machine stopped as generation available in open cycle mode
		12.04.11	00.02	12.04.11	18.25	
		16.04.11	17.17	17.04.11	10.15	
		17.04.11	17.02	22.04.11	11.10	Machine stopped due to low demand
		30.04.11	12.20	05.05.11	00.45	Machine stopped as generation available in open cycle mode
		15.05.11	06.15	16.05.11	23.50	
		17.05.11	08.37	17.05.11	17.29	Machine stopped as generation available on spot RLNG
		21.05.11	12.13	21.05.11	16.36	Stopped due to low demand and high frequency.
		02.06.11	09.32	03.06.11	10.25	
		08.06.11	20.35	09.06.11	00.34	Electrical trouble
		17.06.11	01.02	18.06.11	01.22	Machine stopped as generation available in open cycle mode
		19.06.11	07.04	21.06.11	03.05	
		26.06.11	12.20	27.06.11	11.26	Stopped due to low demand and high frequency.
		30.06.11	11.50	02.07.11	20.29	
		08.07.11	23.05	10.07.11	16.42	
		07.08.11	21.40	17.08.11	11.40	Machine stopped as generation available on spot RLNG
		20.08.11	12.20	20.08.11	22.00	Machine stopped as per SLDC message to maintain only 109 MW
		20.08.11	22.00	21.08.11	18.30	Machine is not available due to problem in Excitation
		21.08.11	18.30	22.08.11	15.58	Machine stopped as generation available on spot RLNG
		23.08.11	14.15	25.08.11	12.40	
		31.08.11	14.32	31.08.11	15.36	Stopped to attend lube oil leakage
		03.09.11	09.02	03.09.11	10.30	Stopped due to low demand and high frequency.
		03.09.11	13.05	03.09.11	13.35	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		04.09.11	02.47	06.09.11	17.20	Stopped due to low demand and high frequency.
		11.09.11	22.05	14.09.11	20.36	Machine stopped as generation available on spot RLNG
		15.09.11	01.14	19.09.11	11.55	Machine stopped as generation available on spot open cycle mode
		20.09.11	01.15	20.09.11	13.40	
		21.09.11	01.32	21.09.11	17.16	
		22.09.11	00.02	22.09.11	08.42	
		23.09.11	00.35	24.09.11	10.47	
		25.09.11	00.02	26.09.11	10.10	
		27.09.11	00.20	27.09.11	08.40	
		27.09.11	15.15	27.09.11	15.25	Machine came on FSNL during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		28.09.11	01.10	28.09.11	08.52	Machine stopped as generation available on spot open cycle mode
		29.09.11	02.10	29.09.11	10.57	
		30.09.11	00.12	30.09.11	10.20	
		30.09.11	23.50	01.10.11	19.38	
		01.10.11	23.04	03.10.11	10.45	
		03.10.11	23.59	04.10.11	10.54	Machine stopped due to swapping of gas to PPCL
		08.10.11	23.59	09.10.11	08.37	
25.10.11	00.50	25.10.11	05.58	Machine stopped as generation available on spot RLNG		
25.10.11	07.45	25.10.11	10.17	Machine tripped on rotating diode earth fault		
07.11.11	02.05	07.11.11	08.14	Machine stopped to maintain only 115 MW load due to overloading of Pragati- Maharani bagh ckt .		
07.11.11	22.17	07.11.11	23.31	Tripped due to tripping of 2 MVA Tx-I		
08.11.11	00.45	12.11.11	18.06	Machine stopped as generation available on spot RLNG		
12.11.11	20.02	13.11.11	18.02			
20.11.11	03.15	20.11.11	09.40			
26.11.11	15.02	30.11.11	10.20	Stopped due to high TAD		
				Machine stopped as generation available on spot RLNG		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	07.12.11	03.35	08.12.11	00.50	Machine stopped as generation available on spot RLNG
		13.12.11	00.05	13.12.11	05.46	
		16.12.11	01.30	16.12.11	08.43	
		16.12.11	22.30	17.12.11	06.20	
		18.12.11	23.06	21.12.11	12.55	
		23.12.11	00.02	23.12.11	09.50	
		23.12.11	22.05	24.12.11	08.55	
		25.12.11	01.20	25.12.11	07.10	
		25.12.11	17.05	27.12.11	05.40	
		28.12.11	00.02	28.12.11	05.48	
		28.12.11	22.19	29.12.11	09.48	
		29.12.11	14.02	30.12.11	06.40	
		31.12.11	00.45	31.12.11	08.50	
		31.12.11	19.55	02.01.11	06.25	
		05.01.12	03.22	05.01.12	11.45	
		05.01.12	18.02	07.01.12	07.55	Machine stopped as generation available on spot RLNG
		08.01.12	00.05	09.01.12	07.55	
		10.01.12	01.46	10.01.12	06.41	
		10.01.12	23.55	11.01.12	06.55	
		11.01.12	19.02	12.01.12	09.25	
		16.01.12	00.28	20.01.12	07.40	
		20.01.12	10.30	24.01.12	14.15	
		01.02.12	07.30	06.02.12	09.20	Stopped due to low demand and high frequency
		06.02.12	21.00	26.02.12	11.00	
		26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.
		27.02.12	17.00	29.02.12	23.59	Stopped due to low demand and high frequency

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage	
		Date	Time	Date	Time		
2	30	01.04.11	00.00	11.04.11	21.37	Machine stopped as generation is available in open cycle mode.	
		12.04.11	00.02	12.04.11	20.27		
		12.04.11	21.00	21.04.11	12.48		
		24.04.11	23.35	25.04.11	05.20	Machine tripped on high vibration	
		30.04.11	18.15	05.05.11	19.45	Due to swapping of gas to PPCL.	
		13.05.11	16.02	13.05.11	18.10	High exhaust temp spread.	
		15.05.11	06.18	15.05.11	21.35	Stopped due to low demand and high frequency.	
		21.05.11	12.13	21.05.11	12.55		
		15.06.11	07.35	15.06.11	08.25	Loss of flame	
		15.06.11	17.40	15.06.11	18.40	Loss of flame	
		15.06.11	22.10	16.06.11	03.22	Loss of flame	
		18.06.11	02.02	20.06.11	17.35	Machine stopped as generation available in open cycle mode	
		02.07.11	21.12	03.07.11	16.10		
		08.07.11	23.02	10.07.11	19.27		
		06.08.11	00.05	07.08.11	15.50	Machine stopped as generation available on spot RLNG	
		07.08.11	23.10	16.08.11	12.20		
		17.08.11	14.30	17.08.11	19.00		
		03.09.11	11.05	03.09.11	17.05	Machine stopped as generation available on spot RLNG	
		11.09.11	22.05	12.09.11	21.58		
		13.09.11	00.02	14.09.11	17.45		
		15.09.11	01.04	19.09.11	11.56	Machine stopped as generation available in open cycle mode	
		20.09.11	01.15	20.09.11	13.14		
		21.09.11	01.32	21.09.11	17.20		
		22.09.11	00.02	22.09.11	08.27		
		23.09.11	01.02	24.09.11	10.40		
		25.09.11	00.02	26.09.11	09.45		
		27.09.11	00.10	27.09.11	08.48		
		28.09.11	01.05	28.09.11	08.40		
		29.09.11	02.02	29.09.11	10.55		
		30.09.11	00.12	30.09.11	10.20		
		30.09.11	23.50	01.10.11	19.10		
		01.10.11	23.06	03.10.11	10.50		
		03.10.11	23.59	04.10.11	10.50		
		16.10.11	13.03	16.10.11	07.12		Tripped on condensate level high trip alarm & reverse power on protection panel
		07.11.11	02.05	07.11.11	08.05		Machine stopped as generation available on spot RLNG
		20.11.11	05.55	20.11.11	09.32	Machine stopped as generation available in open cycle mode	
		26.11.11	18.41	29.11.11	10.14	Machine stopped as generation available on spot RLNG	
		30.11.11	10.15	30.11.11	14.00	Machine tripped on combined cycle trip alarm	
		30.11.11	14.00	30.11.11	17.35	Machine stopped as generation available on spot RLNG	
		08.12.11	17.10	09.12.11	07.56		
		14.12.11	00.55	14.12.11	05.58		
		14.12.11	22.31	15.12.11	13.15		
16.12.11	22.45	17.12.11	10.13				
19.12.11	03.35	19.12.11	15.20	Tripped on TAD very high.			
24.12.11	19.52	25.12.11	00.35	Tripped on high exhaust temp. spread.			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	30	03.01.12	12.10	05.01.12	11.04	Machine stopped as generation available on spot RLNG
		17.01.12	06.32	18.01.12	10.25	
		22.01.12	00.01	23.01.12	08.36	
		24.01.12	22.20	25.01.12	07.25	Stopped due to low demand and high frequency
		27.01.12	20.01	28.01.12	00.40	
		28.01.12	16.15	01.02.12	01.05	
		01.02.12	07.31	26.02.12	11.00	
		26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.
		27.02.12	17.00	29.02.12	23.59	Stopped due to low demand and high frequency

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	11.04.11	11.25	11.04.11	20.41	Due to failure of Auxiliary supply.
		12.04.11	00.02	12.04.11	18.35	Machine stopped as generation available on open cycle mode
		12.04.11	21.10	13.04.11	09.40	
		16.04.11	03.50	17.04.11	21.27	
		19.04.11	00.02	19.04.11	05.52	Due to low demand and high frequency.
		20.04.11	00.02	20.04.11	05.52	
		28.04.11	02.05	28.04.11	13.55	Due to swapping of gas to PPCL.
		04.05.11	01.32	04.05.11	11.50	Machine stopped as generation available on spot RLNG
		08.05.11	03.16	08.05.11	22.44	Stopped due to low demand and high frequency.
		09.05.11	21.45	10.05.11	15.37	
		10.05.11	15.37	10.05.11	20.15	Electrical trouble
		10.05.11	20.15	11.05.11	16.20	Machine stopped as generation available on spot RLNG
		12.05.11	00.05	12.05.11	10.11	
		17.05.11	18.15	17.05.11	23.59	
		18.05.11	00.00	27.07.11	00.00	Start command executed but smoke observed from the Diesel Engine
		27.07.11	00.00	27.07.11	12.25	Machine stopped as generation available on spot RLNG
		27.07.11	19.02	28.07.11	15.00	
		28.07.11	21.35	29.07.11	12.00	
		29.07.11	16.40	30.07.11	01.37	
		30.07.11	02.10	30.07.11	13.02	Machine started for making the drum per 10Kg/cm sq. for passivation of boiler #3
		30.07.11	14.10	30.07.11	23.32	Machine stopped as generation available on spot RLNG
		30.07.11	23.58	31.07.11	23.59	
		01.08.11	19.50	03.08.11	11.01	
		13.08.11	05.35	16.08.11	05.20	
		17.08.11	20.10	18.08.11	10.45	
		18.08.11	12.32	18.08.11	17.32	
		25.08.11	14.15	26.08.11	12.20	Machine stopped as generation available on spot RLNG
		03.09.11	09.05	09.09.11	19.35	
		21.09.11	05.02	21.09.11	13.43	Machine stopped as generation available on open cycle mode.
		27.09.11	15.15	27.09.11	15.58	Machine tripped during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		27.10.11	15.15	31.10.11	07.12	Stopped due to low demand and high frequency.
		03.11.11	02.32	03.11.11	09.27	
		23.11.11	00.05	26.11.11	04.50	Machine stopped as generation available on spot RLNG
26.11.11	15.40	26.11.11	18.10	Machine stopped as generation available on spot RLNG		
08.12.11	23.16	12.09.11	08.06			
10.12.11	23.30	12.12.10	05.46			
14.12.11	15.15	15.12.11	12.50			
15.12.11	14.17	15.12.11	17.30			
18.12.11	20.20	18.12.11	22.30	Machine tripped on 63TP-1,Buch-1 alarm operated on protection pannel.		
18.12.11	20.20	18.12.11	22.30	Machine stopped as generation available on spot RLNG		
19.12.11	02.15	19.12.11	12.55	Tripped on TAD very high.		
19.12.11	23.25	20.12.11	14.15	Machine stopped as generation available on spot RLNG		
21.12.11	14.30	21.12.11	17.50			
28.12.11	15.35	28.12.11	22.04			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	06.01.12	23.55	07.01.12	07.37	Machine stopped as generation available on spot RLNG
		14.01.12	23.00	18.01.12	10.02	
		20.01.12	00.05	20.01.12	07.55	
		21.01.12	00.05	21.01.12	08.10	
		22.01.12	16.47	22.01.12	21.44	
		24.01.12	11.20	24.01.12	13.50	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure
		24.01.12	22.20	25.01.12	07.28	Stopped due to low demand and high frequency
		25.01.12	18.20	27.01.12	05.48	
		28.01.12	23.50	31.01.12	16.30	
		01.02.12	01.56	01.02.12	07.26	Machine stopped as generation available on spot RLNG
		06.02.12	21.12	11.02.12	19.02	Stopped due to low demand and high frequency
		26.02.12	09.45	27.02.12	17.25	Machine tripped on high LTTH as ACW already stopped at 9:02 hrs.to attend the leakages of ACW line near GT#5 Transformer.

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	30	11.04.11	11.25	11.04.11	20.00	Due to failure of Auxiliary supply.
		12.04.11	19.45	12.04.11	20.35	Machine came on FSNL
		13.04.11	09.14	14.04.11	00.45	Machine stopped as generation available on open cycle mode
		16.04.11	10.05	17.04.11	12.50	
		21.05.11	04.00	23.05.11	10.37	Stopped due to low demand and high frequency.
		23.05.11	14.25	26.05.11	14.42	
		26.05.11	18.24	30.05.11	16.05	Machine stopped as generation available on spot RLNG
		02.06.11	09.35	03.06.11	10.50	
		03.06.11	11.15	06.06.11	10.40	Stopped due to low demand and high frequency.
		22.06.11	18.02	23.06.11	02.57	Machine stopped as generation available in open cycle mode
		16.07.11	14.20	31.07.11	23.59	
		01.08.11	00.00	05.08.11	12.17	Machine stopped as generation available on spot RLNG
		11.08.11	06.58	11.08.11	09.05	Machine tripped on loss of flame
		12.08.11	04.40	12.08.11	05.35	Machine tripped on high TAD
		12.08.11	06.52	12.08.11	15.40	Tripped without any alarm in control room
		15.08.11	10.42	16.08.11	06.15	
		16.08.11	15.31	16.08.11	20.28	Machine stopped as generation available on spot RLNG.
		16.08.11	23.50	21.08.11	00.55	
		21.08.11	08.15	27.08.11	23.59	Machine stopped as there was low demand
		03.09.11	13.05	03.09.11	13.40	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		03.09.11	14.10	09.09.11	19.50	Machine stopped as generation available on spot RLNG
		16.09.11	09.13	16.09.11	11.34	Machine tripped on exhaust over temp high
		16.09.11	15.35	16.09.11	17.08	Due to problem of AC supply the Battery voltage came down to 111 Volt. Machine stopped as per request from C&I division.
		21.09.11	14.23	21.09.11	21.27	Machine stopped as generation available on open cycle mode
		24.10.11	06.00	24.10.11	11.40	
		25.10.11	00.52	25.10.11	05.55	Machine stopped as generation available on spot RLNG
		25.10.11	19.20	26.10.11	17.55	
		27.10.11	15.15	02.11.11	11.40	
		13.11.11	23.58	14.11.11	05.58	Stopped due to low demand and high frequency.
		19.11.11	01.16	19.11.11	13.44	Machine stopped as generation available on spot RLNG
		20.11.11	07.15	20.11.11	09.33	Machine tripped on high TAD
		20.11.11	10.15	20.11.11	15.55	Machine tripped on high TAD
		03.12.11	19.05	05.12.11	05.25	
		18.12.11	00.01	19.12.11	02.44	Machine stopped as generation available on spot RLNG
		19.12.11	07.42	19.12.11	11.22	Stopped on TAD very high.
		20.12.11	02.55	20.12.11	09.30	Tripped on TAD very high.
		21.12.11	00.02	21.12.11	07.50	Machine stopped due to low demand.
		21.12.11	18.14	22.12.11	08.25	
		26.12.11	12.54	26.12.11	22.15	Machine stopped as generation available on spot RLNG
		14.01.12	23.00	18.01.12	12.10	
28.01.12	00.16	28.01.12	00.40	Tripped on Gen.Gac electrical protection trouble normal shut down. On protection pannel negative phase sequence trip appeared		
28.01.12	00.40	28.01.12	15.30			
06.02.12	21.00	11.02.12	18.12	Machine stopped due to low demand.		
26.02.12	09.00	27.02.12	17.10	Machine stopped for attending the leakages of ACW line near GT#5 Transformer.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	11.04.11	11.25	11.04.11	12.55	Due to failure of Auxiliary supply.
		11.04.11	14.25	11.04.11	14.55	Due to failure of Auxiliary supply.
		12.04.11	17.42	16.04.11	17.15	Machine stopped as generation available on open cycle
		17.04.11	14.32	18.04.11	20.17	Due to low demand and high frequency.
		21.04.11	22.45	30.04.11	17.24	
		03.05.11	04.01	03.05.11	14.40	Machine stopped as generation available on spot RLNG
		04.05.11	01.35	04.05.11	12.40	
		05.05.11	11.05	05.05.11	11.50	
		05.06.11	19.16	05.07.11	19.25	
		07.05.11	21.35	08.05.11	21.45	
		13.05.11	01.05	13.05.11	05.50	Machine stopped as generation available in open cycle
		13.05.11	18.30	15.05.11	18.28	Machine stopped as generation available on spot RLNG
		20.05.11	01.17	20.05.11	13.35	
		21.05.11	10.55	23.05.11	19.15	Due to low demand and high freq.
		31.05.11	00.05	31.05.11	16.13	Machine stopped as generation available in open cycle mode
		31.05.11	23.02	03.06.11	10.15	Machine tripped on high exhaust temperature trip
		05.06.11	08.04	05.06.11	12.28	
		07.06.11	14.58	07.06.11	16.28	Machine stopped as generation available in open cycle mode
		14.06.11	03.46	15.06.11	19.45	
		15.06.11	22.03	16.06.11	01.14	Machine tripped on high vibration
		16.06.11	05.17	16.06.11	11.44	
		16.06.11	20.02	16.06.11	22.50	Electrical trouble
		16.06.11	23.50	17.06.11	00.15	Machine came on FSNL while changing the faulty u/v relay
		26.06.11	09.02	03.07.11	16.18	Due to low demand and high freq
		07.07.11	14.55	16.07.11	13.15	Machine stopped as generation available on spot RLNG
		07.08.11	00.02	08.08.11	00.10	
		15.08.11	10.42	16.08.11	06.15	
		16.08.11	15.31	16.08.11	20.28	
		16.08.11	23.50	21.08.11	00.55	
		21.08.11	08.15	21.08.11	11.25	
		21.08.11	14.02	31.08.11	23.59	
		01.09.11	17.38	02.09.11	21.50	Machine stopped as generation available on spot RLNG
		03.09.11	13.05	03.09.11	13.45	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		04.09.11	02.50	14.09.11	18.30	Machine is stopped due to low demand and high freq
		14.09.11	18.30	29.10.11	22.45	machine taken under shut down for turbine rotor replacement
		30.10.11	01.50	31.10.11	11.38	Machine stopped as generation available in open cycle
		01.11.11	07.20	01.11.11	17.50	Machine is stopped due to low demand and high freq
		02.11.11	01.11	08.11.11	12.00	
		08.11.11	12.00	11.11.11	12.40	Machine not taken on load due problem in diesel Engine
		11.11.11	18.53	26.11.11	13.06	Machine stopped due to high vibration at BB4 & BB5 i.e 9 mm/se for further inspection by BGGTS
		29.11.11	14.25	29.11.11	21.14	Machine tripped by tripping 11 KV breaker manually as reverse power operated fail alarm appeared on protection pannel.
		03.12.11	14.37	06.12.11	18.02	Machine stopped as generation available on spot RLNG
07.12.11	03.40	07.12.11	06.00	Machine taken under Shut down by M-I division to attend lube oil leakage.		
07.12.11	11.30	07.12.11	18.30	Machine stopped as generation available on spot RLNG		
07.12.11	23.35	08.12.11	16.23			
12.12.11	19.29	14.12.11	14.23			
19.12.11	09.20	19.12.11	13.10	Tripped on TAD very high.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	02.01.12	08.40	03.01.12	11.20	Machine stopped as generation available on spot RLNG
		13.01.12	01.15	14.01.12	06.48	
		19.01.12	00.00	19.01.12	08.00	
		20.01.12	00.00	20.01.12	10.10	
		24.01.12	11.20	24.01.12	12.45	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure
		25.01.12	18.20	27.01.12	10.05	Machine is stopped due to low demand and high freq
		27.01.12	15.02	31.01.12	23.59	
		01.02.12	00.00	06.02.12	08.35	Machine stopped as generation available on spot RLNG
		29.02.12	11.32	09.02.12	11.45	Machine came on FSNL as both 160MVA transformer tripped at both end.
		11.02.12	19.15	26.02.12	11.00	Machine is stopped due to low demand and high freq
		26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.
		27.02.12	17.00	29.02.12	23.59	Machine is stopped due to low demand and high freq

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	11.04.11	11.25	11.04.11	13.20	Due to failure of Auxiliary supply.
		11.04.11	14.25	11.04.11	20.55	Due to failure of Auxiliary supply.
		12.04.11	00.02	12.04.11	17.40	Machine stopped as generation available on open cycle mode
		12.04.11	18.37	16.04.11	12.20	Due to low demand and high frequency
		17.04.11	21.56	18.04.11	19.55	
		19.04.11	00.02	19.04.11	05.55	
		20.04.11	00.02	20.04.11	05.42	
		22.04.11	12.18	24.04.11	11.45	Machine stopped as generation available on Spot RLNG
		24.04.11	16.10	26.04.11	21.20	Due to low demand and high frequency
		27.04.11	00.05	30.04.11	12.12	
		07.05.11	03.40	07.05.11	11.02	
		08.05.11	22.02	09.05.11	21.25	Machine stopped as generation available on spot RLNG
		12.05.11	10.51	12.05.11	15.18	
		13.05.11	00.05	13.05.11	18.33	
		21.05.11	18.30	23.05.11	10.55	Stopped due to low demand and high frequency.
		26.06.11	09.02	04.07.11	11.00	
		04.07.11	15.15	05.07.11	11.00	Machine stopped as generation available on spot RLNG
		15.07.11	23.05	20.07.11	12.50	Due to low demand and high frequency
		23.07.11	02.17	23.07.11	03.27	Machine tripped on loss of flame
		24.07.11	04.15	25.07.11	09.17	Due to low demand and high frequency
		03.08.11	15.25	03.08.11	20.20	Machine stopped as generation available on spot RLNG
		05.08.11	02.01	05.08.11	20.58	
		17.08.11	04.02	20.08.11	22.10	
		22.08.11	16.30	23.08.11	11.30	
		24.08.11	01.50	31.08.11	23.59	
		01.09.11	17.48	02.09.11	21.40	Machine stopped as generation available on spot RLNG
		03.09.11	13.05	03.09.11	13.45	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		06.09.11	18.35	11.09.11	18.25	Stopped due to low demand and high frequency.
		21.09.11	18.40	23.09.11	00.27	Machine tripped due to blowing of fuse of Mark-Vi.
		27.09.11	15.15	27.09.11	15.30	Machine came on FSNL during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		01.10.11	17.30	01.10.11	22.02	Tripped with STG#3 Generator breaker trip battery voltage ground alarm
		20.10.11	20.16	21.10.11	15.10	Tripped on communication link failed with any of IO pack & loss of flame
		31.10.11	10.32	03.11.11	09.20	Stopped due to low demand and high frequency
01.12.11	00.45	01.12.11	06.25	Machine stopped as generation available on spot RLNG		
01.12.11	09.58	03.12.11	13.55			
05.12.11	19.02	07.12.11	03.05			
09.12.11	22.20	12.12.11	18.40			
15.12.11	23.55	16.12.11	08.41			
18.12.11	14.02	18.12.11	20.10			
19.12.11	04.10	19.12.11	10.55		Tripped on TAD very high.	
20.12.11	01.25	20.12.11	09.15	Tripped on TAD very high.		
21.12.11	18.32	22.12.11	07.52	Machine stopped as generation available on spot RLNG		
22.12.11	17.50	23.12.11	09.52			
23.12.11	14.20	24.12.11	08.40			
25.12.11	00.46	25.12.11	07.02			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	25.12.11	23.55	26.12.11	11.58	Machine stopped as generation available on spot RLNG
		27.12.11	00.05	27.12.11	05.25	
		28.12.11	00.45	28.12.11	05.15	
		28.12.11	23.25	29.12.11	09.40	
		29.12.11	23.01	30.12.11	07.55	
		31.12.11	00.45	31.12.11	05.25	
		31.12.11	17.10	02.01.12	06.15	
		04.01.12	23.02	05.01.12	02.50	
		05.01.12	23.52	06.01.12	07.46	
		06.01.12	23.50	11.01.12	12.30	
		12.01.12	00.30	12.01.12	08.00	
		12.01.12	23.58	13.01.12	00.59	
		13.01.12	02.00	13.01.12	07.55	
		13.01.12	14.45	14.01.12	06.40	
		16.01.12	00.30	17.01.12	06.10	
		21.01.12	00.10	21.01.12	08.20	
		22.01.12	00.02	23.01.12	08.45	
		24.01.12	00.02	24.01.12	06.45	
		24.01.12	11.25	24.01.12	12.25	Machine stopped as DD of HRSG#6 not taking close command due to failure of DC supply.
		24.01.12	22.25	25.01.12	11.40	Stopped due to low demand and high frequency
		25.01.12	16.55	01.02.12	07.10	
		09.02.12	11.32	09.02.12	11.47	Machine came on FSNL as both 160MVA transformer tripped at both end.
11.02.12	20.53	26.02.12	11.00	Stopped due to low demand and high frequency		
26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.		
27.02.12	17.00	29.02.12	23.59	Stopped due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG -1	30	01.04.11	00.00	16.04.11	00.40	To attend miscellaneous problems
		16.04.11	11.10	17.04.11	14.27	Machine stopped attend leakage.
		17.04.11	17.02	21.04.11	20.58	Machine stopped due to low demand
		23.04.11	06.32	23.04.11	11.10	Problem in 24 Volt DC supply.
		30.04.11	00.52	30.04.11	02.56	Machine stopped due to low demand Machine tripped and following relay operated
		30.04.11	18.15	05.05.11	05.05	
		05.05.11	23.35	06.05.11	02.28	
		07.05.11	01.45	07.05.11	03.40	
		10.05.11	13.50	10.05.11	17.40	Low vacuum
		15.05.11	06.20	15.05.11	22.54	To attend various leakages
		21.05.11	09.50	21.05.11	14.05	Tripped on Ch-I &II
		21.05.11	16.22	21.05.11	17.35	Machine tripped on low vacuum.
		30.05.11	09.20	30.05.11	11.05	Machine tripped on low vacuum.
		07.06.11	02.43	07.06.11	05.20	Tripped on Ch-I &II
		19.06.11	07.04	21.06.11	02.10	To attend various leakages
		21.06.11	15.58	21.06.11	16.59	To attend various leakages
		08.07.11	23.05	10.07.11	19.34	Due to low demand and high frequency
		26.07.11	13.50	26.07.11	15.01	Machine tripped on flase alarm of Shaft Vibratrtion V. high and Housing vibration v.high
		26.07.11	15.20	26.07.11	16.46	Machine tripped on flase alarm of Shaft Vibratrtion V. high and Housing vibration v.high
		29.07.11	15.55	29.07.11	17.31	Machine tripped manually as the vaccum dropped upto -0.40 kg/cm2 due to tripping of BFP-1A as another BFP-1B was under preventive maintenance
		29.07.11	17.42	29.07.11	18.11	Machine tripped on hot well level high
		07.08.11	18.58	15.08.11	00.00	Machine tripped due to problem in Control valve and boxed up for further inspection as directed by Mech division
		15.08.11	00.00	16.08.11	15.20	Machine not taken on bar due to low demand
		03.09.11	13.05	03.09.11	14.40	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		11.09.11	17.25	14.10.11	05.10	Machine tripped on Generator shaft vibration v. high. Machine boxed for further inspection of generator Rotor & Excitor. After examining the parameters of Generator Rotor it was decided to replace it with new Rotor
		07.11.11	22.17	08.11.11	01.28	Tripped due to tripping of 2 MVA Tx-I
		08.11.11	06.48	08.11.11	08.18	STG#1 tripped due to coupling breaker of 2 MVR Tx-1&II and DG set tripped and no relay/alarm appearing on breaker of Tx.
		20.11.11	04.48	20.11.11	12.05	Machine tripped with following relay operated 27G, 40G ,86GA II, 27GX, 30GTA/30GTB,63 GT-1,multipliers,aux relay in Class A Group-I and Class B -86 GB, AVR VTI fuse and AVR VT-2 .
		25.11.11	19.02	25.11.11	22.15	Stopped to attend hot spot on Y-Phase line isolater.
		26.11.11	18.41	28.11.11	12.44	Machine stopped as generation available on spot RLNG
28.11.11	12.58	29.11.11	14.55	Machine stopped due to high vibration on Turbine FJB & RJB.		
30.11.11	10.15	30.11.11	13.29	Machine tripped manually due to tripping of GT# 2		
12.12.11	06.59	12.12.11	08.53	Tripped on low vaccum due to tripping CEP as 800KVA Trf-1 tripped on Buck-holtz relay		
13.12.11	11.05	13.12.11	13.32	Machine tripped		
16.12.11	22.45	17.12.11	08.20	Machine stopped as generation available on spot RLNG		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG #1	30	19.12.11	03.35	19.12.11	16.46	Tripped due to tripping of GT#2 as TAD of GT#2 very high.
		24.12.11	19.10	24.12.11	21.40	Tripped on Gen. front bearings vibration very high on right side probe. Relay operated 86GB, aux. relay 60A, 60AX, Aux. relay for 60PP, 60PPX, Aux. relay for 60 Pmax.
		29.12.11	14.34	29.12.11	19.35	Tripped on class A relay trip alarm. Following relay appear in DDC room of STG#1: Gen. class A trip relay 86GA, Gen. class B tripping relay 86GB, Aux. relay for 60AX, 60PPA, 60PMA, 32G & 27GX also appeared.
		30.12.11	14.53	30.12.11	15.52	Tripped on CH-I & CH-II operated.
		05.01.12	03.22	05.01.12	12.37	Stopped due to stopping of GT#1 due to high TAD.
		17.01.12	03.51	17.01.12	06.32	Tripped on turbine shaft vibration (RJB) very high alarm.
		17.01.12	06.32	18.01.12	12.25	Machine stopped as generation available on spot RLNG
		18.01.12	13.10	18.01.12	19.55	Tripped on Low vacuum.
		22.01.12	00.01	23.01.12	10.55	Machine stopped as generation available on spot RLNG
		24.01.12	11.20	24.01.12	16.10	Machine tripped due to failure of Aux. supply as 20 MVA Transformer tripped on lind stage gas pressure
		01.02.12	03.03	01.02.12	18.15	Tripped & ESV closed MI appeared in alarm pannel.
		01.02.12	18.15	06.02.12	11.25	Machine stopped due to low demand
		06.02.12	21.00	26.02.12	11.00	
		26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.
27.02.12	17.00	29.02.12	23.59	Machine stopped due to low demand		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG 2	30	11.04.11	10.40	17.04.11	16.20	Low vacuum
		21.05.11	04.00	23.05.11	11.00	Machine stopped due to low demand
		23.05.11	11.00	25.05.11	12.59	Machine tripped on Rotor earth fault
		24.05.11	13.00	26.05.11	18.20	Machine stopped as generation available on spot RLNG
		26.05.11	18.24	30.05.11	20.25	
		02.06.11	09.36	06.06.11	10.40	Machine stopped due to low demand & high frequency
		19.06.11	15.05	19.06.11	20.00	Low vacuum
		22.06.11	18.02	23.06.11	04.25	To attend various leakages
		28.06.11	16.03	28.06.11	17.53	Tripped on Ch-I & II
		16.07.11	14.20	03.08.11	14.45	Machine stopped as generation available on spot RLNG
		14.08.11	11.36	16.08.11	07.50	
		03.09.11	03.20	03.09.11	04.25	Machine stopped for replacement of speed pick up
		03.09.11	13.05	03.09.11	14.10	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		03.09.11	14.10	09.09.11	21.25	Machine stopped as generation available on spot RLNG
		25.09.11	12.05	25.09.11	14.28	Machine tripped due to malfunctioning of deaerator level as BFP-2A tripped and 2B did not take start command due to non availability of Deaerator level.
		26.09.11	20.35	26.09.11	21.50	BFP-2A tripped due to malfunctioning of Deaerator level. Deaerator Level V.Low , Low, High, very high alarm appeared. BFP-2B taken into service it also tripped on same alarm. Machine tripped on low vacuum.
		11.10.11	14.30	11.10.11	16.50	Machine tripped from DDC for checking the hunting in parameters.
		19.10.11	03.02	19.10.11	07.08	Machine tripped due to class B relay operated.
		20.10.11	12.50	20.10.11	14.02	Tripped due to jerk in control room.
		21.10.11	11.50	21.10.11	13.05	Machine stopped due to choking of CEP Stainer as another CEP was under preventive maintenance
		27.10.11	15.15	31.10.11	10.20	Machine stopped due to low demand & high frequency
		12.12.11	06.59	12.12.11	10.10	Tripped due to tripping of 800KVA Trf-1 on low vacuum as both running CEPs tripped.
		18.12.11	14.50	18.12.11	15.45	Tripped due to the following parameters disappeared on BCD & CRT:lube oil temp.,exhaust steam temp.,condensate temp.,BFP discharge header pressure &temp.
		18.12.11	19.20	19.12.11	00.08	Tripped due to HRSG#3 drum level very low.
		19.12.11	02.15	19.12.11	03.40	Tripped due to tripping of GT#3 as TAD of GT#3 very high.
		19.12.11	07.42	19.12.11	13.45	Stopped due to stopping of GT#4 because TAD very high.
		20.12.11	02.55	20.12.11	11.58	Tripped due to tripping of GT#4 as TAD of GT#4 very high.
		14.01.12	23.00	18.01.12	12.00	Machine stopped as generation on Spot R-LNG is not required by SLDC
		24.01.12	11.20	24.01.12	13.35	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure
		06.02.12	08.40	06.02.12	09.25	Machine stopped due to BFP
06.02.12	21.12	10.02.12	20.48	Machine stopped due to low demand		
26.02.12	09.00	27.02.12	19.25	Machine stopped for attending the leakages of ACW line near GT#5 Transformer.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG 3	30	11.04.11	11.25	17.04.11	16.28	Due to failure of Auxiliary supply.
		17.04.11	20.05	18.04.11	21.55	Machine stopped due to low demand
		22.04.11	12.17	30.04.11	16.16	Machine available on spot R-LNG
		01.05.11	14.52	01.05.11	15.40	Steam Turbine Speed very high.
		07.05.11	03.40	07.05.11	13.58	Machine stopped due to low demand
		12.05.11	09.16	13.05.11	20.35	Main steam temperature low
		21.05.11	18.30	23.05.11	13.55	Machine stopped due to low demand
		05.06.11	10.15	05.06.11	11.15	Low vacuum
		06.06.11	09.05	06.06.11	11.25	Turbine shaft vibration high
		13.06.11	13.10	13.06.11	14.34	Machine tripped on CH-I& II.
		26.06.11	09.02	30.06.11	23.59	Machine stopped due to low demand
		20.07.11	13.50	20.07.11	14.20	Machine tripped on Both the boiler trip alarm. No alarm appeared in the Turbine interlock page.
		20.07.11	14.36	20.07.11	15.20	Machine tripped on Both the boiler trip alarm. No alarm appeared in the Turbine interlock page.
		28.07.11	07.04	28.07.11	07.43	Machine tripped due to tripping of HRSGs. HRSG tripped on low drum level as BFP-3A tripped due to malfunctioning of temperature of NDE of motor.
		17.08.11	04.02	21.08.11	00.15	Machine stopped as generation available on spot RLNG.
		22.08.11	13.15	23.08.11	13.45	Machine tripped on Class A. machine cleared from Elect division but not taken on load due to low demand.
		24.08.11	01.50	31.08.11	23.59	Machine stopped due to low demand
		03.09.11	13.05	03.09.11	15.10	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		06.09.11	18.35	11.09.11	22.10	Machine Stopped due to low demand & high frequency
		16.09.11	09.35	16.09.11	11.45	Machine tripped on class A alarm
		18.09.11	08.54	18.09.11	09.25	Machine tripped on Gen class A trip, AVR trip command and excitation field breaker open.
		20.09.11	09.03	20.09.11	09.27	Machine tripped on class A alarm
		21.09.11	16.40	23.09.11	03.10	Machine tripped due to tripping of GT#6
		27.09.11	15.15	27.09.11	16.00	Machine tripped as GT#6 came on FSNL
		01.10.11	17.30	02.10.11	01.45	Tripped with GT#6 Generator breaker trip battery voltage ground alarm.
		13.10.11	05.10	13.10.11	08.33	Machine tripped as all the parameters disapperaed.
		13.10.11	14.42	13.10.11	14.55	Machine tripped on low vaccum as CEP-3A tripped on Hot well very low alarm. It is found that Condensate water drained from the drain of CPH-5. This drain valve is being cut by the O/h team.
		20.10.11	20.16	21.10.11	17.25	Tripped due to tripping of GT#6.
		31.10.11	10.30	03.11.11	12.35	Machine Stopped due to low demand & high frequency
		19.12.11	09.20	19.12.11	12.57	Tripped due to tripping of GT#5 as TAD of GT#5 very high
		02.01.12	06.05	02.01.12	06.55	Stopped due to MS temprature low.
		04.01.12	07.09	04.01.12	07.39	Tripped on Hot well level high.
13.01.12	02.00	14.01.12	08.58	Machine stopped as generation available on spot RLNG		
24.01.12	11.20	24.01.12	14.15	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure		
24.01.12	15.40	24.01.12	17.30	Machine tripped while normalizing the supply from 20 MVA Tx		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG #3	30	25.01.12	18.20	27.01.12	12.35	Machine Stopped due to low demand & high frequency
		27.01.12	15.02	31.01.12	23.59	
		01.02.12	00.00	06.02.12	12.05	
		09.02.12	11.32	09.02.12	13.25	Machine tripped as both 160MVA transformer tripped at both end.
		11.02.12	20.53	26.02.12	11.00	Machine Stopped due to low demand & high frequency
		26.02.12	11.00	27.02.12	17.00	Machine not available due to leakage in ACW line near GT#5 Transformer.
		27.02.12	17.00	29.02.12	23.59	Machine Stopped due to low demand & high frequency

(C)

PRAGATI STATION

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	104	01.04.11	23.28	03.04.11	11.37	Stopped for maintenance work
		03.04.11	20.03	04.04.11	19.09	Rotor earth fault
		04.04.11	14.45	06.04.11	13.35	Unit stopped due to low demand and high frequency
		06.04.11	21.45	08.04.11	08.01	Stopped for maintenance work
		08.04.11	18.45	08.04.11	24.00	Internal fault
		09.04.11	00.00	10.04.11	15.52	Unit stopped due to low demand and high frequency
		25.04.11	17.58	25.04.11	23.08	Tripped alongwith trippings of associated transmission lines.
		21.05.11	01.30	21.05.11	02.56	Grid disturbance
		21.05.11	22.10	23.05.11	08.45	Generation backing down due to low demand and high frequency
		05.06.11	11.02	05.06.11	17.43	Shutdown for attending hot spot and general maintenance
		28.07.11	21.18	29.07.11	22.59	Leakage of air compressor
		02.11.11	00.00	02.11.11	05.58	Inspection of boiler
		09.02.12	11.36	09.02.12	13.04	Grid disturbance
2	104	03.04.11	13.50	03.04.11	20.28	Stopped for maintenance work
		06.04.11	13.50	06.04.11	21.35	Stopped for maintenance work
		08.04.11	08.22	08.04.11	19.20	Stopped for maintenance work
		10.04.11	21.27	11.04.11	12.11	Internal fault
		30.04.11	00.52	30.04.11	01.10	Tripped alongwith trippings of associated transmission lines.
		05.05.11	10.51	07.05.11	05.26	Internal problem
		14.05.11	07.21	14.05.11	19.13	Internal check
		05.06.11	05.00	05.06.11	10.43	Shutdown for attending hot spot and general maintenance
		10.06.11	05.54	11.06.11	15.44	Generation backing down due to low demand and high frequency
		26.06.11	11.38	27.06.11	10.29	Generation backing down due to low demand and high frequency
		27.06.11	10.29	27.06.11	10.55	Lube oil system fault
		15.08.11	10.35	16.08.11	07.00	Generation backing down due to low demand and high frequency
		05.09.11	05.39	05.09.11	07.21	Grid disturbance
		05.12.11	22.00	06.12.11	01.07	Electrical fault
		09.12.11	14.05	09.12.11	14.32	Due to heavy jerk
		19.12.11	13.58	19.12.11	17.03	Air filter damage
		30.12.11	10.30	30.12.11	14.04	Replacement of air tube valve
		05.01.12	06.02	05.01.12	08.04	Grid disturbance
		07.01.12	22.03	07.01.12	22.21	AVR Fault at generation end
		13.01.12	04.36	13.02.12	16.00	Generation backing down due to low demand and high frequency
		13.02.12	04.36	13.02.12	16.00	Generation backing down due to low demand and high frequency
		26.02.12	10.54	26.02.12	11.53	Grid disturbance

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	122	12.04.11	09.00	12.04.11	18.59	High furnace temperature
		25.04.11	17.57	25.04.11	18.56	Tripped alongwith trippings of associated transmission lines.
		21.05.11	01.32	21.05.11	02.53	
		05.06.11	09.50	05.06.11	13.38	Shutdown for attending hot spot and general maintenance
		07.06.11	00.47	13.06.2011	10.19	Internal fault
		05.09.11	09.44	05.09.11	10.28	Internal fault
		19.11.11	09.39	19.11.11	11.16	Internal fault
		05.12.11	22.00	06.12.11	02.18	Electrical fault
		09.12.11	14.05	09.12.11	16.51	Due to heavy jerk
		26.12.11	01.01	26.12.11	02.01	Internal fault
		05.01.12	06.02	05.01.12	12.06	Grid disturbance
		07.01.12	22.03	08.01.12	00.43	AVR fault at generation end.
		09.02.12	11.42	09.02.12	13.14	Grid disturbance
		26.02.12	10.54	26.02.12	12.48	Grid disturbance

(D) BADARPUR THERMAL POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	95	10.06.11	11.04	13.06.11	21.58	Generation backing down due to low demand and high frequency
		26.06.11	09.43	27.06.11	13.07	
		27.06.11	17.26	27.06.11	17.51	Furnaces pressure high
		08.07.11	20.25	12.07.11	15.53	Generation backing down due to low demand and high frequency
		15.07.11	18.11	15.07.11	18.47	Low vacuum
		20.08.11	11.22	20.08.11	12:05	Condenser tube leakage
		01.09.11	23.18	22.09.11	19:24	Planned shutdown
		23.09.11	02.09	23.09.11	18.54	Problem in coal mill
		25.09.11	13.26	25.09.11	14.20	Fire out
		03.10.11	21.06	03.10.11	22.26	Flame failure in furnance
		04.10.11	18.16	05.10.11	07.53	Boiler tube leakage
		05.10.11	19.46	15.10.11	20.30	Furnance vaccume failure
		08.10.11	08.27	08.10.11	09.17	Flame failure
		22.10.11	09.14	22.10.11	10.21	Furnance vaccume low
		30.10.11	00.05	30.10.11	01.17	Fire out
		25.12.11	02.30	27.12.11	01.19	Boiler tube leakage
		02.01.12	17.39	03.01.12	14.25	Boiler tube leakage
		07.01.12	02.38	07.01.12	03.28	Internal fault
		09.01.12	01.44	03.01.12	03.26	Flame failure
		16.01.12	15.05	16.01.12	15.47	False tripping of IO fan
04.02.12	21.00	05.02.12	13.00	Generation backing down due to low demand and high frequency		
07.02.12	11.32	07.02.12	20.37	Electrical protection failure		
2	95	03.04.11	00.50	20.04.11	21.35	Shut-down for over-hauling
		21.05.11	23.13	23.05.11	20.52	Generation backing down due to low demand and high frequency
		27.06.11	16.41	02.07.11	17.42	
		11.07.11	14.54	11.07.11	16.37	False relay tripping
		12.09.11	10.34	12.09.11	17.27	Furnace disturbance
		14.09.11	09.46	14.09.11	09.11	Fire out
		10.10.11	11.20	10.10.11	13.56	Flame failure
		17.10.11	12.32	24.10.11	21.20	Water shortage
		24.10.11	21.35	24.10.11	22.00	Flame failure
		13.11.11	17.35	13.11.11	19.19	Grid disturbance
		20.12.11	08.12	20.12.11	09.33	Vacuum pressure low

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	95	17.04.11	17.01	17.04.11	18.58	Tripped along with tripping of associated transmission lines
		30.04.11	18.32	30.04.11	19.32	Due to tripping of generator transformer
		30.04.11	21.52	02.05.11	05.42	Electrical fault
		26.05.11	17.13	30.05.11	10.24	Generation backing down due to low demand and high frequency
		02.06.11	19.41	06.06.11	11.43	
		07.07.11	01.47	26.07.11	15.35	Turbine blade failure
		09.08.11	03.24	10.08.11	04.11	Generator failure
		02.10.11	21.56	02.10.11	23.10	Flame failure
		06.10.11	00.58	06.10.11	03.10	Flame failure
		11.10.11	20.16	11.10.11	21.07	Furnance fire out
		13.10.11	07.07	14.10.11	04.42	Boiler tube leakage
		15.10.11	01.12	25.10.11	18.27	Boiler tube leakage
		25.10.11	05.12	27.10.11	02.18	Water shortage
		20.11.11	14.11	21.11.11	07.23	Boiler tube leakage
		25.11.11	05.33	26.11.11	09.50	Economizer tube leakage
		26.12.11	16.29	27.12.11	10.55	Boiler tube leakage
		05.02.12	13.54	06.02.12	12.40	Charging from Unit #3 to unit #1
21.02.12	12.08	22.02.12	18.00	Generation backing down due to low demand and high frequency		
4	210	17.04.11	17.01	17.04.10	20.26	Tripped along with tripping of associated transmission lines
		04.05.11	07.41	08.05.11	11.18	Control system failure
		24.06.11	13.07	24.06.11	16.16	Excitation system failure
		22.08.11	06.59	24.08.11	08.40	Shortage of water
		11.09.11	19.38	13.09.11	16.19	Low furnance pressure
		16.09.11	05.21	16.09.11	07.28	Flame failure
		16.09.11	10.25	16.09.11	11.40	Flame failure
		11.10.11	07.10	11.10.11	08.55	Flame failure
		11.10.11	20.16	11.10.11	12.30	Flame failure
		27.10.11	13.05	31.10.11	23.59	Furnance vaccum low
		30.11.11	03.05	22.12.11	20.18	Annual maintenance
		23.12.11	01.30	24.12.11	19.10	Boiler tube leakage
		12.01.12	06.08	13.01.12	09.50	Boiler tube leakage
09.02.12	19.57	10.02.12	19.00	Electrical protection fault		
5	210	17.06.11	17.47	21.06.11	10.10	Generation backing down due to low demand and high frequency
		21.06.11	11.41	21.06.11	13.04	Furnaces vacuum high
		22.06.11	01.09	22.06.11	04.55	Furnaces vacuum high
		22.06.11	05.07	22.06.11	08.15	Unit auxiliary transformer problem
		12.07.11	13.59	13.07.11	08.05	Hot spot on generation bus
		14.08.11	10.35	17.08.11	08.37	Generation backing down due to low demand and high frequency
		14.09.11	10.45	14.09.11	13.28	Flame failure
		16.09.11	13.50	16.09.11	15.15	Flame failure
		16.09.11	19.33	16.09.11	20.42	Flame failure
		17.09.11	07.52	17.09.11	13.47	Fire out
		19.10.11	11.16	29.10.11	16.45	Water shortage
		26.11.11	00.22	27.11.11	02.27	Boiler tube leakage
		26.12.11	19.05	28.12.11	09.42	Furnance failure
13.02.12	10.16	16.02.12	21.42	Generation backing down due to low demand and high frequency		

4

ALLOCATION OF POWER TO DELHI

A)

Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 22.05.2011**Time block 00.00hrs. to 12.00hrs. & 23.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
<u>NPC</u>							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	0	0	89
Total	15676	1766	2873	2537	0	0	2537
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	231	201	0	0	201
Grand Total	22386	1957	3393	2980	0	0	2980

B) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 22.05.2011

Time block 12.00hrs. to 23.00hrs. @ 16% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	39	34	165
Rihand	1000	150	100	87	20	17	104
Rihand Stage -II	1000	150	126	109	20	17	127
ANTA GPS	419	63	44	41	8	8	49
Auriya GPS	663.36	99	72	67	9	9	76
Dadri GPS	829.78	129	91	85	8	7	92
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	19	17	655
Unchahaar-I TPS	420	20	24	21	3	2	23
Unchahaar-II TPS	420	63	47	41	8	7	48
Unchahaar-III TPS	210	31	29	25	4	4	29
TOTAL	8782	1152	2174	1902	138	122	2023
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	7	7	45
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	2	2	17
Dhauli Ganga HEP	280	42	37	35	6	5	40
Koteshwar HEP	100	0	10	9	1	1	11
Dulhasti HEP	390	58	50	48	8	7	55
TOTAL	3174	172	361	343	24	23	365
<u>NPC</u>							
Narora APS	440	64	47	41	8	7	48
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	14	12	61
TOTAL	1320	194	103	89	23	20	109
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	20	19	142
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	13	12	102
Total	15776	1766	2882	2547	217	195	2741
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	231	201	5	4	205
Grand Total	22486	1957	3403	2989	222	199	3188

C) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 07.10.2011

Time block 00.00hrs. to 12.00hrs. & 23.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
THDC							
Tehri Hydro	1000	99	103	89	0	0	89
Total	15676	1766	2873	2537	0	0	2537
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	500	38	0	0	0	0	0
Grand Total	22386	1957	3162	2779	0	0	2779

D) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 07.10.2011

Time block 12.00hrs. to 23.00hrs. @ 16% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	39	34	164
Rihand	1000	150	100	87	20	17	104
Rihand Stage -II	1000	150	126	109	20	17	126
ANTA GPS	419	63	44	41	8	8	49
Auriya GPS	663.36	99	72	67	9	8	75
Dadri GPS	829.78	129	91	85	8	7	92
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	19	17	655
Unchahaar-I TPS	420	20	24	21	3	2	23
Unchahaar-II TPS	420	63	47	41	8	7	48
Unchahaar-III TPS	210	31	29	25	4	4	29
TOTAL	8782	1152	2174	1902	137	121	2022
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	7	7	45
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	2	2	17
Dhauri Ganga HEP	280	42	37	35	5	5	40
Koteshwar HEP	100	0	10	9	1	1	11
Dulhasti HEP	390	58	50	48	8	7	55
TOTAL	3174	172	361	343	24	23	365
<u>NPC</u>							
Narora APS	440	64	47	41	8	7	48
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	9	7	56
TOTAL	1320	194	103	89	17	15	104
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	20	19	142
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	13	12	102
Total	15776	1766	2882	2547	211	189	2736
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	0	0	5	4	4
Grand Total	22486	1957	3172	2788	216	193	2982

E) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 04.11.2011

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
<u>NPC</u>							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	200	0	20	19	0	0	19
TOTAL	1200	99	123	108	0	0	108
Total	15876	1766	2892	2556	0	0	2556
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	0	0	0	0	0
Grand Total	22586	1957	3182	2798	0	0	2798

5 ALLOCATION OF POWER TO DISCOMS

ALLOCATION OF POWER TO VARIOUS LICENCEES AS PER ORDER OF DERC AND DECISION OF GNCTD FOR ALLOCATION OF CENTRAL SECTOR STATIONS (DADRI THERMAL & BTPS) AND STATE SECTOR GENERATING STATIONS w.e.f. 01.04.2011.

(Allocation In %)

(A) 10.00hrs. to 17.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.98	0.00	24.18	36.87	23.97	100.00
3. BTPS	15.94	7.09	21.88	33.37	21.72	100.00
4. RPH	0.85	0.00	28.39	42.97	27.79	100.00
5. GT	0.93	0.00	28.28	42.99	27.80	100.00
6. Pragati	26.69	0.00	20.77	31.76	20.7	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00

(B) 00.00hrs. to 10.00hrs. and 17.00hrs. to 24.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.05	0.00	24.18	36.87	24.90	100.00
3. BTPS	15.07	7.09	21.88	33.37	22.59	100.00
4. RPH	0.00	0.00	28.39	42.97	28.64	100.00
5. GT	0.00	0.00	28.28	42.99	28.73	100.00
6. Pragati	25.76	0.00	20.77	31.76	21.71	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00

6 POWER AVAILABILITY-DEMAND POSITION AT THE TIME OF PEAK DEMAND MET DURING FEBRUARY 2012

All figures in MW

Date	Time of peak demand	Generation within Delhi							Import from the Grid	Schedule from the Grid	OD(-) / UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	BTPS	Rithala	Bawana	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)
1	9:47:48	99	85	321	621	19	179	1324	2187	2410	223	3511	0	3511
2	9:34:19	95	84	318	624	19	181	1321	2149	2317	168	3470	0	3470
3	10:04:57	96	84	314	581	19	153	1247	2361	2304	-57	3608	0	3608
4	9:58:03	54	84	304	607	19	147	1215	2095	2334	239	3310	0	3310
5	9:49:34	57	81	310	493	19	0	960	2345	2331	-14	3305	0	3305
6	9:41:11	59	161	315	585	19	0	1139	2268	2399	131	3407	0	3407
7	9:45:54	58	80	316	634	18	0	1106	2327	2317	-10	3433	0	3433
8	9:51:44	59	80	318	615	19	134	1225	2275	2368	93	3500	0	3500
9	9:48:38	102	80	323	624	19	160	1308	2176	2428	252	3484	0	3484
10	9:51:41	105	80	319	422	19	201	1146	2404	2595	191	3550	0	3550
11	9:43:25	105	80	318	556	19	180	1258	2298	2536	238	3556	0	3556
12	10:21:41	105	83	310	551	19	167	1235	2186	2462	276	3421	0	3421
13	10:04:00	103	81	151	495	19	168	1017	2355	2537	182	3372	0	3372
14	10:20:59	103	82	306	413	19	166	1089	2279	2520	241	3368	0	3368
15	8:45:48	104	82	314	430	13	172	1115	2230	2296	66	3345	2	3347
16	9:48:00	107	82	319	420	13	150	1091	2209	2335	126	3300	0	3300
17	10:06:01	106	82	319	624	13	158	1302	2152	2110	-42	3454	118	3572
18	10:00:37	104	82	316	581	13	179	1275	2047	2264	217	3322	0	3322
19	10:13:28	106	83	309	598	13	0	1109	2187	2302	115	3296	0	3296
20	9:57:49	110	84	310	612	13	0	1129	2274	2445	171	3403	0	3403
21	9:52:18	103	82	302	510	25	0	1022	2112	2541	429	3134	0	3134
22	9:43:20	103	83	303	593	15	0	1097	2053	2649	596	3150	0	3150
23	19:32:18	100	81	302	566	28	0	1077	2077	2223	146	3154	0	3154
24	9:38:11	45	81	312	554	31	0	1023	2198	2292	94	3221	0	3221
25	9:44:03	101	82	315	558	26	0	1082	1948	2380	432	3030	0	3030
26	9:58:48	96	0	318	522	26	0	962	2161	2084	-77	3123	0	3123
27	9:54:03	102	0	312	611	27	150	1202	1906	2476	570	3108	0	3108
28	9:52:08	92	83	307	612	24	19	1137	1938	2507	569	3075	0	3075
29	10:01:46	104	83	308	524	24	153	1196	1999	2568	569	3195	0	3195

POWER AVAILABILITY- DEMAND POSITION AT THE TIME OF MAXIMUM UNRESTRICTED DEMAND DURING FEBRUARY 2012

Date	Time of peak demand	Generation within Delhi							Import from the Grid	Schedule from the Grid	OD(-) / UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	BTPS	Rithala	Bawana	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)
1	9:47:48	99	85	321	621	19	179	1324	2187	2410	223	3511	0	3511
2	9:34:19	95	84	318	624	19	181	1321	2149	2317	168	3470	0	3470
3	10:04:57	96	84	314	581	19	153	1247	2361	2304	-57	3608	0	3608
4	9:58:03	54	84	304	607	19	147	1215	2095	2334	239	3310	0	3310
5	9:49:34	57	81	310	493	19	0	960	2345	2331	-14	3305	0	3305
6	9:41:11	59	161	315	585	19	0	1139	2268	2399	131	3407	0	3407
7	9:45:54	58	80	316	634	18	0	1106	2327	2317	-10	3433	0	3433
8	9:51:44	59	80	318	615	19	134	1225	2275	2368	93	3500	0	3500
9	9:48:38	102	80	323	624	19	160	1308	2176	2428	252	3484	0	3484
10	9:51:41	105	80	319	422	19	201	1146	2404	2595	191	3550	0	3550
11	9:43:25	105	80	318	556	19	180	1258	2298	2536	238	3556	0	3556
12	10:21:41	105	83	310	551	19	167	1235	2186	2462	276	3421	0	3421
13	10:04:00	103	81	151	495	19	168	1017	2355	2537	182	3372	0	3372
14	10:20:59	103	82	306	413	19	166	1089	2279	2520	241	3368	0	3368
15	8:45:48	104	82	314	430	13	172	1115	2230	2296	66	3345	2	3347
16	9:48:00	107	82	319	420	13	150	1091	2209	2335	126	3300	0	3300
17	10:06:01	106	82	319	624	13	158	1302	2152	2110	-42	3454	118	3572
18	10:00:37	104	82	316	581	13	179	1275	2047	2264	217	3322	0	3322
19	10:13:28	106	83	309	598	13	0	1109	2187	2302	115	3296	0	3296
20	9:57:49	110	84	310	612	13	0	1129	2274	2445	171	3403	0	3403
21	9:52:18	103	82	302	510	25	0	1022	2112	2541	429	3134	0	3134
22	9:43:20	103	83	303	593	15	0	1097	2053	2649	596	3150	0	3150
23	19:32:18	100	81	302	566	28	0	1077	2077	2223	146	3154	0	3154
24	9:38:11	45	81	312	554	31	0	1023	2198	2292	94	3221	0	3221
25	9:44:03	101	82	315	558	26	0	1082	1948	2380	432	3030	0	3030
26	9:58:48	96	0	318	522	26	0	962	2161	2084	-77	3123	0	3123
27	9:54:03	102	0	312	611	27	150	1202	1906	2476	570	3108	0	3108
28	9:52:08	92	83	307	612	24	19	1137	1938	2507	569	3075	0	3075
29	10:01:46	104	83	308	524	24	153	1196	1999	2568	569	3195	0	3195

SOURCEWISE SCHEDULED DRAWL FROM NORTHERN GRID AS WELL AS AVAILABILITY WITHIN DELHI FOR FEBRUARY 2012

A) AVAILABILITY FROM GENCO AND PRAGATI STNs. (all fig in MUs)

A (i) RPH	73.084
(ii) GT+STG	56.053
(iii) PRAGATI	209.629
(iv) RITHALA	14.038
(v) BAWANA CCGT	81.151
TOTAL	433.955
B) AVAILABILITY FROM BTPS	369.175
C) AUXILIARY CONSUMPTION OF GENERATING STNs. EXCLUDING BTPS	17.421
D) NET GENERATION AVAILABLE WITHIN DELHI(A+B-C)	785.709

B) SOURCE WISE SCHEDULED DRAWL FROM THE NORTHERN GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
B/SUIL	4.080	3.924	2.906	2.786
SALAL	13.016	12.501	9.975	9.555
TANKAPUR	0.952	0.912	0.797	0.762
CHAMERA	6.928	6.657	5.239	5.020
CHAMERA -II	5.474	5.258	4.191	4.014
DHAULIGANGA	3.167	3.038	2.575	2.465
SEWA -2	7.112	6.837	5.159	4.945
URI	18.506	17.797	13.099	12.557
KOTESHWAR	7.552	7.251	7.552	7.251
ANTA (GAS)	19.694	18.918	12.673	12.169
ANTA (RLNG)	10.013	9.597	0.121	0.115
ANTA (LIQUID)	0.625	0.596	0.000	0.000
DADRI (GAS)	36.803	35.327	26.153	25.084
DADRI (RLNG)	22.737	21.797	0.268	0.255
DADRI (LIQUID)	0.123	0.117	0.000	0.000
AURAIYA (GAS)	26.104	25.044	16.938	16.241
AURAIYA (RLNG)	18.400	17.663	0.177	0.169
AURAIYA (LIQUID)	4.170	4.002	0.000	0.000
SINGRAULI	93.428	89.682	85.611	82.195
RIHAND -I	58.274	55.954	50.965	48.944
RIHAND -II	84.974	81.538	74.038	71.055
UNCHAHAAR-I	16.099	15.449	13.063	12.538
UNCHAHAAR-II	31.120	29.865	25.325	24.308
UNCHAHAAR-III	19.415	18.631	15.719	15.087
DADRI (TH)	491.176	471.256	408.881	392.238
DADRI (TH) STAGE-II	495.647	475.588	456.917	438.401
NAPP	11.020	10.582	11.020	10.582
RAPP 'B'	0.000	0.000	0.000	0.000
RAPP 'C'	37.094	35.596	37.094	35.596
NATHPA JHAKRI	17.309	16.611	5.051	4.847
DULASTI	4.179	3.988	4.179	3.988
TEHRI	25.127	24.105	25.127	24.105
JHAJJAR	0.000	0.000	0.000	0.000
KHELGAON	16.543	15.892	16.541	15.890
KHELGAON-II	62.668	60.160	62.624	60.117
FARAKA	0.000	0.000	0.000	0.000
TALA	1.433	1.374	1.433	1.374
TALCHER	0.000	0.000	0.000	0.000
DVC	151.883	150.299	150.299	144.281
CHATTISHGARH	0.000	0.000	0.000	0.000
ANDHRA	0.000	0.000	0.000	0.000
DVC TATA STEEL (NDPL)	128.956	127.605	127.605	122.665
ORISSA	0.000	0.000	0.000	0.000
KERALA	0.000	0.000	0.000	0.000
HIMACHAL PRADESH	0.000	0.000	0.000	0.000
WEST BENGAL	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR)	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR-ER)	0.000	0.000	0.000	0.000
NAGALAND	0.000	0.000	0.000	0.000

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
UTTRANCHAL	0.000	0.000	0.000	0.000
GOA	0.000	0.000	0.000	0.000
MAHARASHTRA	0.000	0.000	0.000	0.000
MEGHALAYA	0.000	0.000	0.000	0.000
TO CHHATISHGARH	-27.311	-27.907	-27.907	-29.082
TO ANDHRA	-0.360	-0.371	-0.371	-0.383
TO MADHYA PRADESH	-70.371	-71.469	-71.469	-74.478
TO JAMMU & KASHMIR	-8.278	-8.436	-8.436	-8.792
TO TAMILNADU	-10.755	-11.010	-11.010	-11.471
TO RAJASTHAN	-49.441	-50.354	-50.354	-52.405
TO HIMACHAL PRADESH	-40.904	-41.688	-41.688	-43.448
TO KERALA(ER)	-12.993	-13.286	-13.286	-13.808
TO UTTRANCHAL	-47.009	-47.906	-47.906	-49.920
POWER EXCHANGE(IEX)	1.657	1.585	1.657	1.585
TO POWER EXCHANGE (IEX)	-129.361	-134.652	-129.361	-134.652
POWRER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TO POWER EXCHANGE (PX)	-14.563	-15.152	-14.563	-15.152
TO SHARE PROJECT (HARYANA)	-10.211	-10.668	-10.211	-10.668
TO SHARE PROJECT (PUNJAB)	-4.451	-4.643	-4.451	-4.643
TOTAL	1527.446	1445.453	1249.958	1164.284

C) AGENCY WISE BREAKUP OF ENERGY SCHEDULED DRAWL FROM THE GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
NTPC - NR	1428.801	1371.023	1186.848	1138.799
NTPC - ER	79.211	76.052	79.165	76.008
NHPC	63.414	60.912	48.121	46.092
NPC	48.113	46.178	48.113	46.178
KOTESHWAR	7.552	7.251	7.552	7.251
NATHPA JHAKRI	17.309	16.611	5.051	4.847
TEHRI	25.127	24.105	25.127	24.105
TALA	1.433	1.374	1.433	1.374
JHAJJAR	0.000	0.000	0.000	0.000
TALCHER	0.000	0.000	0.000	0.000
DVC	151.883	150.299	150.299	144.281
CHATTISHGARH	0.000	0.000	0.000	0.000
ANDHRA	0.000	0.000	0.000	0.000
DVC TATA STEEL (NDPL)	128.956	127.605	127.605	122.665
ORISSA	0.000	0.000	0.000	0.000
KERALA	0.000	0.000	0.000	0.000
HIMACHAL PRADESH	0.000	0.000	0.000	0.000
WEST BENGAL	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR)	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR-ER)	0.000	0.000	0.000	0.000
NAGALAND	0.000	0.000	0.000	0.000
UTTRANCHAL	0.000	0.000	0.000	0.000
GOA	0.000	0.000	0.000	0.000
MAHARASHTRA	0.000	0.000	0.000	0.000
MEGHALAYA	0.000	0.000	0.000	0.000
POWER EXCHANGE(IEX)	1.657	1.585	1.657	1.585
POWER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TOTAL	1953.455	1882.995	1680.971	1613.185

D) AGENCY WISE BREAKUP OF ENERGY SCHEDULED BY NRLDC FOR EXPORT TO OTHER UTILITIES FROM DTL

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT POWER PERIPHERY
TO CHHATISHGARH	-27.311	-27.907	-27.907	-29.082
TO MADHYA PRADESH	-70.371	-71.469	-71.469	-74.478
TO ANDHRA	-0.360	-0.371	-0.371	-0.383
TO JAMMU & KASHMIR	-8.278	-8.436	-8.436	-8.792
TO TAMILNADU	-10.755	-11.010	-11.010	-11.471
TO RAJASTHAN	-49.441	-50.354	-50.354	-52.405
TO HIMACHAL PRADESH	-40.904	-41.688	-41.688	-43.448
TO KERALA(ER)	-12.993	-13.286	-13.286	-13.808
TO UTTANCHAL	-47.009	-47.906	-47.906	-49.920
TO POWER EXCHANGE (IEX)	-129.361	-134.652	-129.361	-134.652
TO POWER EXCHANGE (PX)	-14.563	-15.152	-14.563	-15.152
TO SHARE PROJECT (HARYANA)	-10.211	-10.668	-10.211	-10.668
TO SHARE PROJECT (PUNJAB)	-4.451	-4.643	-4.451	-4.643
TOTAL	-426.009	-437.542	.431.013	-448.902
TOTAL SCHEDULED DRAWAL FROM THE GRID	1527.446	1445.453	1249.958	1164.287
TOTAL CONSUMPTION INCLUDING AUX. OF GENERATING STNS. EXCLUDING BTPS				1719.607
NET CONSUMPTION				1702.186
AVAILABILITY WITHIN DELHI				785.709
ACTUAL DRAWAL FROM THE GRID				916.477
OVER DRAWAL(+)/UNDER DRAWAL(-) FROM THE GRID ON THE BASIS OF SCHEDULED ALLOCATION MADE BY NRLDC TO DELHI AT PERIPHERY				-247.807
LOAD SHEDDING				-2.831
UNRESTRICTED DEMAND (GROSS)				1722.438
UNRESTRICTED DEMAND (NET)				1705.017
MAX. NET CONSUMPTION				64.033Mus. ON 09.02.2012
MAX. LOAD SHEDDING				201MW ON 26.02.2012 AT 11.00HRS.
PEAK LOAD	Peak Demand during the month			SHEDDING AT PEAK TIME
DAY PEAK	3608MW AT 10.04.57HRS ON 03.02.2012			NIL
EVENING PEAK	3306MW AT 19.00.00HRS ON 10.02.2012			6 MW
P.L.F. OF GENCO AND PRAGATI STNs.	RPH GT PRAGATI RITHALA BAWANA			77.78% 29.83% 91.27% 18.68% 53.93%

SHEDDING DETAILS DURING THE MONTH OF FEBRUARY 2012.

ALL FIGURES IN MUs

DATE	No. of Under Freq. Relay Operated	Shedding due to under frequency relay operation in MUs					Shedding due to Grid Restrictions (Over drawl / low freq.)			
		BSES		NDPL	NDMC	TOTAL	BSES		NDPL	NDMC
		BYPL	BRPL				BYPL	BRPL		
1	2	3	4	5	6	7=3 to 6	8	9	10	11
01-Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02- Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000
03- Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
04- Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05- Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
07 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.022	0.000	0.000
09 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
13 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.185	0.000
18 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22- Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29 - Feb -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Total	0	0.000	0.000	0.000	0.000	0.000	0.006	0.022	0.185	0.000

ALL FIGURES IN MUs

Date	Shedding due to Transmission/Grid Constraints in Central Sector Stations / TTC / ATC VOILATION				TOTAL	TOTAL SHEDDING DUE TO GRID RESTRICTIONS	Due to T&D Constraints				
	BSES		NDPL	NDMC			DTL				
	BYPL	BRPL					BSES	NDPL	NDMC	MES	
			BYPL	BRPL							
1	12	13	14	15	16=8to15	17=16+7	18	19	20	21	22
01-Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02- Feb -12	0.000	0.000	0.000	0.000	0.006	0.006	0.000	0.000	0.000	0.000	0.000
03- Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
04- Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05- Feb- 12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
06 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
07 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08 - Feb -12	0.000	0.000	0.000	0.000	0.022	0.022	0.000	0.000	0.000	0.000	0.000
09 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.016	0.000	0.004	0.012	0.000
10 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
12 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.0003	0.000	0.000
13 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
14 - Feb-12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17 - Feb -12	0.000	0.000	0.000	0.000	0.185	0.185	0.000	0.000	0.004	0.000	0.000
18 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
21 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22- Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000
25 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.051	0.012	0.000	0.000	0.000
27 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Total	0.000	0.000	0.000	0.000	0.213	0.213	0.068	0.012	0.008	0.012	0.000

ALL FIGURES IN MU\$


DATE	DUE TO T&D CONSTRAINTS				OTHER AGENCIES LIKE GENCO, BBMB, BTPS ETC.	THEFT PRONE SHEDDING			TOTAL SHEDDING DUE TO T&D CONSTS. & THEFT PRONE	GRAND TOTAL
	DISCOMS					BSES		NDPL		
	BSES		NDPL	NDMC		BYPL	BRPL			
	BYPL	BRPL								
1	23	24	25	26	27	28	29	30=18 to29	31=30+17	
01-Feb -12	0.000	0.000	0.010	0.000	0.000	0.000	0.000	0.112	0.122	0.122
02- Feb -12	0.007	0.000	0.005	0.000	0.000	0.000	0.000	0.115	0.127	0.133
03- Feb -12	0.004	0.083	0.091	0.000	0.005	0.000	0.000	0.117	0.300	0.300
04- Feb -12	0.000	0.000	0.002	0.000	0.000	0.000	0.000	0.103	0.105	0.105
05- Feb- 12	0.013	0.000	0.027	0.000	0.000	0.000	0.000	0.093	0.133	0.133
06 - Feb -12	0.000	0.000	0.013	0.000	0.000	0.000	0.000	0.106	0.119	0.119
07 - Feb -12	0.000	0.003	0.002	0.000	0.000	0.000	0.000	0.097	0.102	0.102
08 - Feb -12	0.000	0.000	0.019	0.000	0.000	0.000	0.000	0.105	0.124	0.146
09 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.108	0.140	0.140
10 - Feb -12	0.009	0.000	0.039	0.000	0.000	0.000	0.000	0.114	0.162	0.162
11 - Feb -12	0.002	0.000	0.031	0.000	0.000	0.000	0.000	0.111	0.144	0.144
12 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.102	0.102	0.102
13 - Feb -12	0.016	0.000	0.004	0.000	0.000	0.000	0.000	0.119	0.139	0.139
14 - Feb -12	0.000	0.018	0.004	0.000	0.000	0.000	0.000	0.120	0.142	0.142
15 - Feb -12	0.000	0.000	0.063	0.000	0.000	0.000	0.000	0.127	0.190	0.190
16 - Feb -12	0.000	0.020	0.001	0.000	0.000	0.000	0.000	0.125	0.146	0.146
17 - Feb -12	0.000	0.000	0.031	0.000	0.000	0.000	0.000	0.064	0.099	0.284
18 - Feb -12	0.000	0.025	0.000	0.000	0.000	0.000	0.000	0.000	0.025	0.025
19 - Feb -12	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.005	0.005
20 - Feb -12	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.001	0.001
21 - Feb -12	0.018	0.000	0.028	0.000	0.000	0.000	0.000	0.000	0.046	0.046
22- Feb -12	0.014	0.000	0.007	0.000	0.000	0.000	0.000	0.000	0.021	0.021
23 - Feb -12	0.000	0.000	0.009	0.000	0.000	0.000	0.000	0.000	0.009	0.009
24 - Feb -12	0.000	0.000	0.011	0.000	0.003	0.000	0.000	0.000	0.015	0.015
25 - Feb -12	0.011	0.005	0.006	0.000	0.000	0.000	0.000	0.000	0.022	0.022
26 - Feb -12	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.066	0.066
27 - Feb -12	0.009	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009	0.009
28 - Feb -12	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.000	0.003	0.003
29 - Feb -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Total	0.103	0.160	0.409	0.000	0.008	0.000	0.000	1.838	2.618	2.831

DATE	(NET CONS.)	MAXL DEMAND MET DURING THE DAY	TIME OF OCCURRENCE OF MAX DEMAND	SHEDDING AT THIS TIME	UN-RESTRICTED DEMAND	MAXIMUM UN-RESTRICTED DEMAND DURING THE DAY	TIME OF MAX. UN-REST. DEMAND	DEMAND AT THAT TIME	SHEDDING AT THAT TIME
	In Mus.	IN MW	IN HRS.	IN MW	IN MW	IN MW	HRS.	IN MW	IN MW
1	32	33	34	35	36=33+35	37=39+40	38	39	40
01-Feb -12	62.248	3511	09:47:48	0	3511	3511	09:47:48	3511	0
02- Feb -12	62.833	3470	09:34:19	0	3470	3470	09:34:19	3470	0
03- Feb -12	62.928	3608	10:04:57	0	3608	3608	10:04:57	3608	0
04- Feb -12	59.585	3310	09:58:03	0	3310	3310	09:58:03	3310	0
05- Feb -12	54.272	3305	09:49:34	0	3305	3305	09:49:34	3305	0
06 - Feb -12	59.039	3407	09:41:11	0	3407	3407	09:41:11	3407	0
07 - Feb -12	61.063	3433	09:45:54	0	3433	3433	09:45:54	3433	0
08 - Feb -12	62.907	3500	09:51:44	0	3500	3500	09:51:44	3500	0
09 - Feb -12	64.033	3484	09:48:38	0	3484	3484	09:48:38	3484	0
10 - Feb -12	63.735	3550	09:51:41	0	3550	3550	09:51:41	3550	0
11 - Feb -12	62.024	3556	09:43:25	0	3556	3556	09:43:25	3556	0
12 - Feb -12	58.089	3421	10:21:41	0	3421	3421	10:21:41	3421	0
13 - Feb -12	60.329	3372	10:04:00	0	3372	3372	10:04:00	3372	0
14 - Feb -12	60.679	3368	10:20:59	0	3368	3368	10:20:59	3368	0
15 - Feb -12	60.571	3345	08:45:48	2	3347	3347	08:45:48	3345	2
16 - Feb -12	61.171	3300	09:48	0	3300	3300	09:48	3300	0
17 - Feb -12	62.965	3454	10:06:01	118	3572	3572	10:06:01	3454	118
18 - Feb -12	60.085	3322	10:00:37	0	3322	3322	10:00:37	3322	0
19 - Feb -12	54.904	3296	10:13:28	0	3296	3296	10:13:28	3296	0
20 - Feb -12	53.589	3403	09:57:49	0	3403	3403	09:57:49	3403	0
21 - Feb -12	52.988	3134	09:52:18	0	3134	3134	09:52:18	3134	0
22- Feb -12	55.254	3150	09:43:20	0	3150	3150	09:43:20	3150	0
23 - Feb -12	54.729	3154	19:32:18	0	3154	3154	19:32:18	3154	0
24 - Feb -12	55.513	3221	09:38:11	0	3221	3221	09:38:11	3221	0
25 - Feb -12	53.069	3030	09:44:03	0	3030	3030	09:44:03	3030	0
26 - Feb -12	53.829	3123	09:58:48	0	3123	3123	09:58:48	3123	0
27 - Feb -12	56.886	3108	09:54:03	0	3108	3108	09:54:03	3108	0
28 - Feb -12	55.343	3075	09:52:08	0	3075	3075	09:52:08	3075	0
29 - Feb -12	57.526	3195	10:01:46	0	3195	3195	10:01:46	3195	0
Total	1702.186	3608 03.02.2012	10:04:57	0	3608 03.02.2012	10:04:57	10:01:16	3608	0

10 **LOAD PATTERN OF DELHI ON THE DAY OF PEAK DEMAND MET DURING FEBRUARY 2012 ON 03.02.2012- 3608MW at 10.04.57HRS.**

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1593	0	1593
2	1505	0	1505
3	1470	0	1470
4	1472	0	1472
5	1619	0	1619
6	2114	4	2118
7	3160	12	3172
8	3358	46	3404
9	3460	17	3477
10	3530	0	3530
10.04.57	3608	0	3608
11	3316	60	3376
12	3208	48	3256
13	2904	0	2904
14	2723	0	2723
15	2682	0	2682
16	2670	0	2670
17	2744	0	2744
18	2952	0	2952
19	3179	82	3261
20	3102	30	3132
21	2844	13	2857
22	2524	13	2537
23	2185	13	2198
24	1790	0	1790
ENERGY IN MUS	62.928	0.300	63.228



11 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UN-RESTRICTED DEMAND DURING FEBRUARY 2012 ON 03.02.2012-3608MW at 10.04.57HRS.

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1593	0	1593
2	1505	0	1505
3	1470	0	1470
4	1472	0	1472
5	1619	0	1619
6	2114	4	2118
7	3160	12	3172
8	3358	46	3404
9	3460	17	3477
10	3530	0	3530
10.04.57	3608	0	3608
11	3316	60	3376
12	3208	48	3256
13	2904	0	2904
14	2723	0	2723
15	2682	0	2682
16	2670	0	2670
17	2744	0	2744
18	2952	0	2952
19	3179	82	3261
20	3102	30	3132
21	2844	13	2857
22	2524	13	2537
23	2185	13	2198
24	1790	0	1790
ENERGY IN MUS	62.928	0.300	63.228



12 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM ENERGY CONSUMED DURING FEBRUARY 2012 – 09.02.2012 – 64.033 Mus

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1545	0	1545
2	1449	0	1449
3	1412	0	1412
4	1433	0	1433
5	1592	7	1599
6	2261	0	2261
7	3049	30	3079
8	3290	28	3318
9	3371	0	3371
10	3409	0	3409
11	3281	0	3281
12	3125	0	3125
13	2861	0	2861
14	2727	0	2727
15	2729	0	2729
16	2664	0	2664
17	2708	0	2708
18	2982	0	2982
19	3281	28	3309
20	3114	31	3145
21	2959	0	2959
22	2648	0	2648
23	2218	0	2218
24	1790	0	1790
ENERGY IN MUS	64.033	0.140	64.173



13 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UNRESTRICTED ENERGY DEMAND DURING FEBRUARY 2012 – 09.02.2012 – 64.173 Mus


All figures in MW

Hrs.	Demand	Load Shedding	Un-Restricted Demand
1	1545	0	1545
2	1449	0	1449
3	1412	0	1412
4	1433	0	1433
5	1592	7	1599
6	2261	0	2261
7	3049	30	3079
8	3290	28	3318
9	3371	0	3371
10	3409	0	3409
11	3281	0	3281
12	3125	0	3125
13	2861	0	2861
14	2727	0	2727
15	2729	0	2729
16	2664	0	2664
17	2708	0	2708
18	2982	0	2982
19	3281	28	3309
20	3114	31	3145
21	2959	0	2959
22	2648	0	2648
23	2218	0	2218
24	1790	0	1790
ENERGY IN MUS	64.033	0.140	64.173




14 LOAD DURATION CURVE FOR FEBRUARY 2012

Load in MW	Percentage of Time
Above 1200	100 %
Above 1400	92.1 %
Above 1600	83.06 %
Above 1800	78.69 %
Above 2000	74.74 %
Above 2200	70.46 %
Above 2400	59.77 %
Above 2600	43.93 %
Above 2800	29.07 %
Above 3000	16.26 %
Above 3200	6.11 %
Above 3400	1.64 %



FREQUENCY ANALYSIS FOR THE MONTH OF FEBRUARY 2012

Frequency Range in Hz.	Percentage of time
Above 49	100 %
Above 49.25	99.96 %
Above 49.5	98.96 %
Above 49.75	80.33 %
Above 50	29.83 %
Above 50.25	2.14 %
Above 50.5	0.04 %



16 VOLTAGE PROFILE OF 220 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2012

All figures in kV

Date	NARELA		GAZIPUR	
	Max	Min	Max	Min
01-Feb -12	--	--	--	--
02- Feb -12	235.11	217.7	232.40	216.67
03- Feb -12	236.40	215.12	231.89	217.31
04- Feb -12	235.89	216.28	232.53	216.67
05- Feb -12	237.82	222.34	233.31	218.99
06 - Feb -12	238.59	215.38	233.18	216.02
07 - Feb -12	--	--	--	--
08 - Feb -12	--	--	--	--
09 - Feb -12	--	--	--	--
10 - Feb -12	--	--	--	--
11 - Feb -12	--	--	--	--
12 - Feb -12	--	--	--	--
13 - Feb -12	--	--	--	--
14 - Feb-12	238.34	216.28	233.31	215.64
15 - Feb -12	--	--	--	--
16 - Feb -12	240.14	220.80	234.08	--
17 - Feb -12	240.27	221.70	231.11	--
18 - Feb -12	240.14	225.70	234.08	217.57
19 - Feb -12	239.75	224.92	235.24	219.12
20 - Feb -12	238.98	223.12	233.43	216.54
21 - Feb -12	--	--	--	--
22- Feb -12	238.21	221.70	233.05	216.93
23 - Feb -12	--	--	--	--
24 - Feb -12	238.34	219.25	232.02	218.35
25 - Feb -12	239.11	218.22	233.31	214.19
26 - Feb -12	238.85	225.44	233.31	220.15
27 - Feb -12	235.24	217.70	234.24	217.70
28 - Feb -12	239.24	217.31	233.18	212.80
29 - Feb -12	238.21	220.41	233.18	216.67

17 VOLTAGE PROFILE OF 400 KV SUB-STATIONS IN DELHI DURING FEBRUARY 2012
All figures in kV

Date	400kV Barnauli Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb -12	--	--	--	--	--
02- Feb -12	418.33	03.19.36	391.60	12.16.30	403.84
03- Feb -12	412.47	23.54.08	392.07	14.31.35	402.12
04- Feb -12	419.03	03.44.51	389.25	12.19.10	406.06
05- Feb- 12	419.50	04.01.05	395.82	11.11.29	409.03
06 - Feb-12	419.50	02.41.09	392.07	11.10.18	406.72
07 - Feb -12	--	--	--	--	--
08 - Feb -12	--	--	--	--	--
09 - Feb -12	--	--	--	--	--
10 - Feb -12	--	--	--	--	--
11 - Feb -12	--	--	--	--	--
12 - Feb -12	--	--	--	--	--
13 - Feb -12	--	--	--	--	--
14 - Feb-12	420.21	03.58.55	396.05	11.13.41	407.81
15 - Feb -12	--	--	--	--	--
16 - Feb -12	--	--	--	--	--
17 - Feb -12	420.21	04.06.17	392.30	14.36.44	406.76
18 - Feb -12	421.38	04.04.18	394.65	12.47.08	406.94
19 - Feb -12	421.61	04.00.38	397.46	10.22.49	409.87
20 - Feb -12	419.74	03.47.28	392.77	09.48.38	406.94
21 - Feb -12	--	--	--	--	--
22- Feb -12	417.86	05.06.04	391.36	11.17.15	404.25
23 - Feb -12	--	--	--	--	--
24 - Feb -12	417.16	20.57.39	396.99	12.14.33	407.36
25 - Feb -12	419.50	04.00.04	392.07	12.21.42	406.83
26 - Feb -12	419.03	02.16.17	396.76	12.37.57	410.08
27 - Feb -12	422.79	05.06.36	393.71	10.30.06	407.52
28 - Feb -12	418.10	04.00.57	384.33	11.01.03	402.65
29 - Feb -12	418.56	05.04.29	393.24	11.04.40	405.08

Date	400kV Bawana Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Feb -12	--	--	--	--	--
02- Feb -12	423.02	03.19.16	397.93	11.47.18	410.45
03- Feb -12	422.55	02.51.21	397.93	14.31.15	410.58
04- Feb -12	423.25	03.44.31	395.58	12.19.10	411.79
05- Feb -12	424.90	04.02.55	400.74	11.18.40	414.59
06 - Feb -12	424.90	230.08	397.93	11.10.38	412.53
07 - Feb -12	--	--	--	--	--
08 - Feb -12	--	--	--	--	--
09 - Feb -12	--	--	--	--	--
10 - Feb -12	--	--	--	--	--
11 - Feb -12	--	--	--	--	--
12 - Feb -12	--	--	--	--	--
13 - Feb -12	--	--	--	--	--
14 - Feb-12	424.19	03.57.35	399.81	11.14.41	412.44
15 - Feb -12	--	--	--	--	--
16 - Feb -12	--	--	--	--	--
17 - Feb -12	423.72	04.06.07	396.76	10.28.42	411.45
18 - Feb -12	424.90	04.04.18	399.81	10.08.47	411.70
19 - Feb -12	425.36	04.00.58	402.15	10.24.29	414.57
20 - Feb -12	423.96	03.47.28	398.40	09.48.28	411.82
21 - Feb -12	--	--	--	--	--
22- Feb -12	423.02	20.53.57	398.40	11.17.50	411.00
23 - Feb -12	--	--	--	--	--
24 - Feb -12	423.25	20.57.39	402.62	12.14.33	412.83
25 - Feb -12	424.43	04.00.14	396.99	12.21.02	412.40
26 - Feb -12	423.96	02.15.27	402.15	12.39.37	415.58
27 - Feb -12	427.94	05.06.26	399.34	10.29.56	413.39
28 - Feb -12	424.43	03.07.04	390.09	11.01.03	409.56
29 - Feb -12	424.90	05.04.29	399.34	10.50.49	412.18

DETAILS OF LUMPED CAPACITORS AT NEAREST 220 KV SUBSTATION

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
1	IP YARD		30		30				30		30		
1	Kamla Market			16.35	16.35					16.35	16.35	8	
2	Minto Road												
3	GB Pant Hosp			15.88	15.88					10.48	10.48	5	
4	Delhi Gate			10.9	10.9					10.9	10.9	8	
5	Tilakmarg			5.04	5.04					5.04	5.04	12	
6	Electric Lane			5.04	5.04					5.04	5.04	19	
7	Cannaught Place			10.08	10.08					10.08	10.08	20	
8	Kilokri		10.08	10.48	20.56				0	5.03	5.03	4	
9	NDSE			5.03	5.03					5.03	5.03	6	
10	AIIMS		10	5.04	15.04				10	5.04	15.04	18	
11	Nizamuddin												
12	Exhibition-I		10		10				0		0	11	
13	Exhibition-II												
14	Defence Colony												
15	IG Stadium		10.08	5.45	15.53				0	5.45	5.45	4	
16	Lajpat Nagar												
17	IP Estate			10.9	10.9					5.45	5.45		
	Total				170.4	239	11	0	40	83.89	123.9	115	
2	IP Extn.												
1	School Lane			5.04	5.04					5.04	5.04	51	
2	Scindia House			5.04	5.04					5.04	5.04		
3	Vidyut Bhawan			10.08	10.08					10.08	10.08	52	
4	Nirman Bhawan			5.04	5.04					5.04	5.04	30	
5	Dalhousie Road			5.04	5.04					5.04	5.04		
	Total				30.24	129	12	0	0	30.24	30.24	133	
3	RPH Station		20	5.04	25.04				20	5.04	25.04		
1	Lahori Gate			10.49	10.49					10.49	10.49	7	
2	Jama Masjid			5.03	5.03					5.03	5.03	8	
4	Kamla Market												
5	Minto Road			10.9	10.9					10.9	10.9	6	
6	GB Pant Hosp												
7	IG Stadium												
	Total				51.46	100	30	0	20	31.46	51.46	21	
4	Parkstreet S/stn	20	20		40			20	20		40		
1	Shastri Park		10.89 6	5.45	16.35				10.89 6	5.45	16.35	47	
2	Faiz Road			10.9	10.9					10.9	10.9	12	
3	Motia Khan			16.3	16.3					16.3	16.3	11	
4	Prasad Nagar			16.25	16.25					16.25	16.25	11	
5	Anand Parbat			10.8	10.8					7.2	7.2	7	
6	Shankar Road			5.04	5.04					5.04	5.04	8	
7	Rama Road			14.4	14.4					7.2	7.2	3	
8	Baird Road			10.08	10.08					10.08	10.08	22	
9	Hanuman Road			5.04	5.04					0	0	11	
10	Pusa			7.2	7.2					7.2	7.2	7	
11	Ridge Valley											53	
12	SJ Airport			5.04	5.04					0	0	9	
13	B. D. Marg											11	
	Total				157.4	233	41	20	30.9	85.62	136.5	212	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
5	Naraina S/stn		20	5.04	25.04				20	0	20		
1	DMS			10.85	10.85					10.85	10.85	6	
2	Mayapuri		10.87	5	15.87				10.87	5	15.87	13	
3	Inderpuri		13.26	5.04	18.3				0	5.04	5.04	7	
4	Rewari line			7.2	7.2					7.2	7.2		
5	Khyber Lane			5.04	5.04					5.04	5.04		
6	Kirbi Place	10		5.97	15.97			10		5.97	15.97		
7	Payal			14.4	14.4					7.2	7.2	4	
	Total				112.7	140	21	10	30.87	46.3	87.17	30	
6	Mehrauli S/stn	80		5.04	85.04			60		5.04	65.04		
1	Adchini			15.12	15.12					10.08	10.08	9	
2	Andheria Bagh			10.85	10.85					10.85	10.85	7	
3	IIT			10.9	10.9					5.45	5.45	7	
4	JNU		10.03	10.08	20.11				10.03	5.04	15.07	23	
5	Bijwasan			10.08	10.08					5.04	5.04	6	
6	DC Saket		10.08	4.54	14.62				0	0	0	10	
7	Malviya Nagar												
8	C Dot			5.4	5.4					0	0	3	
9	Vasant kunj B-Blk	21.79		10.9	32.69			0		0	0	2	
10	Vasant kunj C-Blk	20.16		10.49	30.65			0		0	0	2	
11	Palam											12	
12	IGNOU											2	
13	R. K. Puram-I			10.08	10.08					10.08	10.08	6	
14	Vasant Vihar			15.12	15.12					15.12	15.12	8	
15	Pusp Vihar			9.6	9.6					9.6	9.6		
16	Bhikaji Cama Place		10	10.08	20.08				10	5.04	15.04	9	
	Total				290.3	213	32	60	20.03	81.34	161.4	106	
7	Vasantkunj S/stn	40		5.04	45.04			40		5.04	45.04		
1	R. K. Puram-II			7.2	7.2					0	0	4	
2	Vasant kunj C-Blk										0		
3	Vasant kunj D-Blk	20.16		10.25	30.41			0		0	0	1	
4	Race Course			5.04	5.04					5.04	5.04		
5	Bapu Dham			10.08	10.08					10.08	10.08	24	
6	Nehru Park			10	10					10	10	8	
7	Ridge Valley										0		
	Total				107.8	244	35	40	0	30.16	70.16	37	
8	Okhla S/stn	60	10	5.04	75.04			60	10	5.04	75.04		
1	Balaji			7.2	7.2					3.6	3.6	6	
2	East of Kailash			10	10					5	5	13	
3	Alaknanda			16.25	16.25					10.85	10.85	9	
4	Malviya Nagar	21.79	20.16	10.49	52.44			21.79	20.16	10.49	52.44	77	
5	Masjid Moth			15.94	15.94					5.04	5.04	7	
6	Nehru Place			21.35	21.35					21.35	21.35	20	
7	Okhla Ph-I	21.79		10.9	32.69			21.79		0	21.79	6	
8	Okhla Ph-II		20.93	15.53	36.46				10.9	15.53	26.43	13	
9	Shivalik			10.9	10.9					10.9	10.9	9	
10	Batra			15.8	15.8					15.8	15.8	5	
11	VSNL			10.8	10.8					0	0	7	
12	Siri Fort			10.49	10.49					5.04	5.04	9	
13	Tuglakabad			10.8	10.8					0	0	11	
	Total				326.2	360	52	103.6	41.06	108.6	253.3	192	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
9	Lodhi Road S/stn		20		20				20		20		
1	Defence Colony			10.9	10.9					5.45	5.45	13	
2	Hudco			10.9	10.9					0	0	7	
4	Lajpat Nagar			10.9	10.9					0	0	6	
5	Nizamuddin			10.49	10.49					10.49	10.49	10	
6	Vidyut Bhawan										0	6	
7	Kidwai Nagar			5.04	5.04					5.04	5.04	9	
8	Ex. Gr. II										0		
9	IHC										0		
	Total				68.23	157	61	0	20	20.98	40.98	51	
10	Sarita Vihar S/stn	20		5.04	25.04			20		5.04	25.04		
1	Sarita Vihar			10.08	10.08					10.08	10.08	13	
2	MCIE			10.06	10.06					0	0	4	
3	Mathura Road	20.16		10.08	30.24			20.16		5.04	25.2	3	
4	Jamia Millia			5.4	5.4					0	0	4	
5	Sarai Julena		10.08	10.9	20.98				10.08	10.9	20.98	14	
	Total				101.8	140	-3	40.16	10.08	31.06	81.3	38	
11	South of Wazirabad										0		
1	Bhagirathi		10.03	10.9	20.93				0	10.9	10.9	10	
2	Ghonda	21.79	22.56	15.94	60.29			0	0	15.94	15.94	20	
3	Seelam Pur		10.08	21.39	31.47				0	10.9	10.9	10	
4	Dwarkapuri			15.46	15.46					15.46	15.46	8	
5	Nandnagri	20.16		16.35	36.51			20.16		10.9	31.06	4	
6	Yamuna Vihar			10.8	10.8					1.8	1.8	5	
7	East of Loni Road			10.8	10.8					10.8	10.8	3	
8	Shastri Park			10.9	10.9					5.45	5.45	10	
9	Karawal Nagar			5.4	5.4					5.4	5.4	9	
	Total				202.6	214	64	20.16	0	87.55	107.7	79	
12	Geeta Colony										0		
1	Geeta Colony			10.49	10.49					10.49	10.49	12	
2	Kanti Nagar			10.9	10.9					10.9	10.9	8	
3	Kailash Nagar			15.48	15.48					5.45	5.45	12	
4	Seelam Pur										0		
5	Shakar Pur										0	6	
	Total				36.87	105	45	0	0	26.84	26.84	32	
13	Gazipur S/stn	40		5.04	45.04			40		5.04	45.04		
1	Dallupura	21.79		10.9	32.69			0		10.9	10.9	2	
2	Vivek Vihar			10.57	10.57					5.03	5.03	18	
3	GT Road			10.85	10.85					10.85	10.85	7	
4	Kondli	20.16		10.85	31.01			0		5.45	5.45	3	
5	MVR-I			10.9	10.9					0	0		
6	MVR-II	20.16		10.9	31.06			0		10.9	10.9		
7	PPG Ind. Area			10.06	10.06					0	0	2	
	Total				182.2	164	0	40	0	48.17	88.17	32	
14	Patparganj S/stn	40	20	5.04	65.04			40	10	5.04	55.04		
1	GH-I	19.89		10.45	30.34			0		10.45	10.45	2	
2	GH-II	20.09		10.9	30.99			0		0	0	3	
3	CBD		10.03	15.48	25.51				0	15.48	15.48	9	
4	Guru Angad Nagar			15.49	15.49					15.49	15.49	11	
5	Karkadooma		10.08	10.44	20.52				10.08	10.44	20.52	6	
6	Preet Vihar			10.07	10.07					5.04	5.04	9	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
7	CBD-II			7.2	7.2					0	0	4	
8	Shakarapur			5.4	5.4					3.6	3.6		
9	Jhilmil			9	9					0	0	5	
10	Dilshad Garden	20.16		16.35	36.51			0		0	0	4	
11	Khichripur	21.79		10.49	32.28			0		5.45	5.45	7	
12	Mother Dairy										0		
13	Scope Building										0		
14	Vivek Vihar										0		
15	Akhardham			14.4	14.4					0	0		
	Total				302.8	169	-25	40	20.08	70.99	131.1	60	
15	Najafgarh S/stn	60		5.04	65.04			60		5.04	65.04		
1	A4 Paschim Vihar			10.9	10.9					5.45	5.45	6	
2	Nangloi	21.73		15.85	37.58			21.73		10.85	32.58	39	
3	Nangloi W/W	20.89		5.45	26.34			20.89		5.45	26.34	3	
4	Pankha Road			15.69	15.69					15.69	15.69	6	
5	Jaffarpur			15.49	15.49					0	0	3	
7	Inst. Area Janakpuri			15.9	15.9					5.45	5.45		
8	Paschimpuri		10.05	15.53	25.58				0	5.04	5.04	9	
9	Paschim Vihar	41.83		15.44	57.27			20.1		15.44	35.54	36	
10	Mukherjee Park			15.49	15.49					15.49	15.49	11	
11	Udyog Nagar			10.04	10.04					0	0	8	
12	Choukhandi			10.08	10.08					0	0	7	
	Total				305.4	322	38	122.7	0	83.9	206.6	128	
16	Pappankalan-I S/stn	20		5.04	25.04			20		5.04	25.04		
1	Bindapur	21.73		15.9	37.63			0		5	5	6	
2	Bodella-I	20.1		15.9	36			20.1		15.9	36	6	
3	Bodella-II	21.73		14.53	36.26			0		14.53	14.53	6	
4	DC Janakpuri			10.04	10.04					10.04	10.04	8	
5	G-2 PPK			10.9	10.9					10.9	10.9	3	
6	G-5 PPK			15.53	15.53					15.53	15.53	6	
7	G-6 PPK			5.45	5.45					5.45	5.45	5	
8	G-15 PPK			10.08	10.08					10.08	10.08		
9	Harinagar	21.18		10.49	31.67			0		10.49	10.49	6	
	Total				218.6	334	38	40.1	0	103	143.1	46	
17	BBMB Rohtak Road										0		
1	S.B. Mill			10.08	10.08					0	0	3	
2	GTK Road				0						0		
3	Ram Pura			12.24	12.24					12.24	12.24	7	
4	Rohtak Road			10.08	10.08					5.04	5.04	2	
5	Vishal			5.4	5.4					5.4	5.4	13	
6	Madipur			10.43	10.43					5	5	7	
7	Sudershan Park			10.08	10.08					0	0		
	Total				58.31	151	15	0	0	27.68	27.68	32	
18	Shalimarbagh S/stn		40	6	46				30	6	36		
1	S.G.T. Nagar			13.15	13.15					0	0		
2	Wazirpur-1			20.7	20.7					20.7	20.7	11	
3	Wazirpur-2			14.4	14.4					7.2	7.2	6	
4	Shalimarbagh										0		
5	Ashok Vihar			20.35	20.35					20.35	20.35	11	
6	Rani Bagh			14.4	14.4					7.2	7.2	3	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
7	Haiderpur			13.15	13.15					13.15	13.15	6	
8	SMB FC			7.2	7.2					7.2	7.2		
9	SMB KHOSLA			7.2	7.2					7.2	7.2	4	
	Total				156.6	185	4	0	30	89	119	41	
19	Subzimandi S/stn			6	6					6	6		
1	Shakti Nagar			5.04	5.04					5.04	5.04	4	
2	Gulabibagh			7.2	7.2					7.2	7.2	4	
3	Shahzadabagh			19.44	19.44					19.44	19.44	10	
4	Tripolia			14.4	14.4					7.2	7.2	4	
5	B. G. Road										0	3	
	Total				52.08	105	17	0	0	44.88	44.88	25	
20	Narela S/stn	40		5.04	45.04			40		5.04	45.04		
1	A-7 Narela			14.4	14.4					14.4	14.4		
2	AIR Kham pur			13.15	13.15					0	0	7	
3	Badli	20		5.95	25.95			20		5.95	25.95	21	
4	DSIDC Narela	20		5.95	25.95			20		5.95	25.95	14	
5	DSIDC Narela-2			14.4	14.4					0	0		
6	Jahangirpuri	20	20	5.95	45.95			20	10	5.95	35.95	27	
	Total				184.8	203	-38	100	10	37.29	147.3	69	
21	Gopalpur S/stn		30	5.04	35.04				20	5.04	25.04		
1	Azad Pur			21.6	21.6					21.6	21.6	12	
2	Hudson Lane			5.95	5.95					5.95	5.95	4	
3	Wazirabad			7.2	7.2					7.2	7.2	3	
4	Indra Vihar			5.95	5.95					5.95	5.95		
5	Tri Nagar			14.4	14.4					7.2	7.2	3	
6	GTK Road			13.15	13.15					7.2	7.2	3	
7	Jahangirpuri				0						0		
8	Civil lines			6	6					6	6		
9	DIFR			7.2	7.2					7.2	7.2		
10	Delhi Univ.			7.2	7.2					7.2	7.2		
11	Tiggipur			14.4	14.4					14.4	14.4		
	Total				138.1	209	20				114.9	25	
22	Rohini S/stn	40		6	46			40		6	46		
1	Rohini Sec-24 Ckt-I			14.4	14.4					14.4	14.4	9	
2	Rohini Sec-24 Ckt-II	20		14.4	34.4			20		0	20	9	
3	Rohini-1			7.2	7.2					7.2	7.2	3	
4	Rohini-2			13.15	13.15					5.95	5.95	7	
5	Rohini-3			5.95	5.95					5.95	5.95	4	
6	Rohini-4			13.15	13.15					13.15	13.15	9	
7	Rohini-5			13.15	13.15					13.15	13.15	22	
8	Rohini-6	20		5.95	25.95			20		5.95	25.95	3	
9	Mangolpuri-1			20.35	20.35					5.95	5.95	3	
10	Mangolpuri-2	20		5.04	25.04			20		0	20	13	
11	Saraswati Garden			10.08	10.08					5.04	5.04	4	
12	Pitam Pura-1	20		12.24	32.24			20		5.04	25.04	14	
13	Pitam Pura-2			12.24	12.24					0	0	0	
14	Pitam Pura-3			7.2	7.2					7.2	7.2	4	
15	Rohini DC-1			14.4	14.4					14.4	14.4		
	Total				294.9	317	21				229.4	104	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kV	TOTAL	MW	MVAR	66KV	33kv	11kV	TOTAL	MW	MVAR
23	Kanjhawala S/stn	20		5.04	25.04			20		5.04	25.04		
1	Bawana Clear Water			14.4	14.4					7.2	7.2	3	
2	Pooth Khoord			7.2	7.2					7.2	7.2	3	
3	Ghevra			14.4	14.4					14.4	14.4		
	Total				61.04	58	-13				53.84	6	
24	BAWANA S/stn												
1	Bawana S/stn No. 6				0						0		
2	Bawana S/stn No. 7				0						0		
	Total				0	47	20				0		
25	Kashmeregate S/stn			5.04	5.04					5.04	5.04		
1	Civil lines			6	6					6	6	9	
2	Town Hall			8.64	8.64					8.64	8.64	8	
3	Fountain			5.45	5.45					5.45	5.45	4	
	Total				25.13	50	7				25.13	21	
26	Pappankalan-II												
1	DMRC-I												
2	DMRC-II												
	Total					99	12						
	TOTAL CAPACITY				3636	4687	604				2502	1635	

20 DETAILS OF BREAK-DOWNS DURING THE MONTH OF FEBRUARY 2012

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
01	04.02.12	16.23	220KV GEETA COLONY – PATPARGANJ CKT-II	04.02.12	17.52	CKT. TRIPPED ON DIST PROT `ABC` PHASE ZONE-I AT PATPARGANJ AND ON DIST PROT `ABC` PHASE ZONE-II, 86, 30E, 27RYB AT GEETA COLONY
02	07.02.12	15.15	400/220KV 315MVA ICT-IV AT BAMNAULI	07.02.12	16.00	ICT TRIPPED ON 186A&B, 86B-I ALONG WITH 220KV I/C-IV WHICH TRIPPED ON INTER TRIPPING.
03	07.02.12	15.15	220KV BAMNAULI – DIAL CKT-I	07.02.12	19.40	CKT. TRIPPED ON 186A&B AT BAMNAULI AND ON RED MAIN-I, PROTEC. TRIP, REL RED FUSE FAIL, 52, BR POSITIN INDICATION, RECGE TRIP, BPR `R` PHASE, MAIN-I & II, RED MAIN PHASE PROT. TRIP, REL & RED `R` PHASE, FAULTY DIFFERENTIAL ZONE-I PROT. AT DIAL. CONDUCTOR FOUND DAMAGE BETWEEN TOWER NO.94-95.
04	08.02.12	13.59	220KV KANJHAWALA – NAJAFGARH CKT.	20.02.12	19.35	CKT. TRIPPED ON E/F, 186 AT NAJAFGARH. NO TRIPPING AT KANJHAWALA. AIR LEAKAGE IN ABB MAKE ABCB BREAKER. BREAKER REPLACED WITH SF6 CGL BREAKER.
05	09.02.12	04.46	220/33KV 100MVA PR. TR.-II AT SUBZI MANDI	09.02.12	14.15	TR. TRIPPED ON 86, REFLV.
06	09.02.12	12.01	220KV GOPALPUR – SUBZI MANDI CKT-II	09.02.12	13.26	CKT. TRIPPED ON MAIN-I DIST PROT `RYB` PHASE AND MAIN-II DIST PROT `Y` PHASE ZONE-I AT GOPALPUR. NO TRIPPING AT SUBZI MANDI.
07	09.02.12	11.33	220KV MAHARANI BAGH – PRAGATI CKT	09.02.12	12.00	CKT. TRIPPED ON POLE DISCREPANCY AT MAHARANI BAGH. 220KV PRAGATI – SARITA VIHAR CKT WAS UNDER PLANNED SHUT-DOWN. DUE TO THE TRIPPING OF 220KV PRAGATI –MAHARANI BAGH CKT, PRAGATI (UNIT-I) AND GT STATION ISLANDED FROM THE GRID AND COLLAPSED. THE DETAILED REPORT IS ENCLOSED.
08	09.02.12	14.20	220KV MAHARANI BAGH – PRAGATI CKT	09.02.12	16.14	CKT. TRIPPED ON POLE DISCREPANCY AT MAHARANI BAGH. NO TRIPPING AT PRAGATI.
09	10.02.12	11.30	220KV MEHRAULI – DIAL CKT-II	10.02.12	12.34	CKT. TRIPPED ON 186, DIFFERENTIAL `R` PHASE. NO TRIPPING AT DIAL.
10	16.02.12	10.50	66/11KV 20MVA PR. TR.-II AT DSIDC	16.02.12	18.27	TR. TRIPPED ON 86, DIFFERENTIAL ALONG WITH 11KV I/C-II WHICH TRIPPED ON INTER TRIPPING.
11	20.02.12	23.08	220/33KV 100MVA PR. TR.-IV AT OKHLA	21.02.12	18.30	TR. TRIPPED ON BUCHLOZ ALONG WITH 33KV I/C-III & IV. 33KV I/C-III TRIPPED ON 86, 51A AND 33KV I/C-IV TRIPPED ON 86LV, 80. `R` PHASE BREAKER ISOLATOR OF 33KV EAST OF KAILASH CKT. BROKEN AT OKHLA.
12	23.02.12	12.40	66/11KV 20MVA PR. TR-II AT DSIDC BAWANA	23.02.12	18.15	TR. TRIPPED ON 86, 87.
13	23.02.12	15.38	66/11KV 20MVA PR. TR.-I AT SARITA VIHAR	23.02.12	17.28	TR. TRIPPED ON 30E, SPR, 86.
14	25.02.12	14.47	220/66KV 160MVA PR. TR. AT MUNDKA	25.02.12	16.13	TR. TRIPPED ON 86A&B ALONG WITH 66KV I/C WHICH TRIPPED ON 86.

Contd....2

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
15	26.02.12	10.52	220KV PRAGATI – IP CKT- II	26.02.12	11.30	CKT. TRIPPED ON ACTIVE GROUP-I, DIST PROT `ABC` PHASE ZONE-II AT PRAGATI. NO TRIPPING AT IP. `R` PHASE WAVE TRAP CONDUCTOR OF 220KV PATPARGANJ CKT-II BROKEN AT IP STATION YARD. (DETAILED REPORT ENCLOSED).
16	28.02.12	15.12	220KV MANDOLA – GOPALPUR CKT-II	28.02.12	15.34	CKT. TRIPPED ON DIST PROT `RYB` PHASE, O/C ABC PHASE AT MANDOLA AND ON DIST PROT `RYB` PHASE, ZONE-I AT GOPALPUR
17	28.02.12	16.57	220/33KV 100MVA PR. TR.-II AT MASJID MOTH	28.02.12	17.57	TR. TRIPPED ON DC-22 FAULTY.
18	28.02.12	21.49	220KV BTPS – MEHRAULI CKT-II	28.02.12	22.13	CKT. TRIPPED ON E/F AT BTPS AND ON DIST PROT `ABC` PHASE ZONE-I, 186 AT MEHRAULI

20

DETAILS OF UNDER FREQUENCY RELAY OPERATIONS IN DELHI POWER SYSTEM DURING THE MONTH OF FEBRUARY 2012

DATE	S. N.	TIME		Name of Grid	NAME OF AFFECTED FEEDERS	LOAD RELIEF IN MW
		OUT	IN			
				NIL		