

DELHI TRANSCO LTD.

STATE LOAD DISPATCH CENTER

PROGRESS REPORT

JANUARY 2012

S. No.	CONTENTS	Page No.
1.	Salient Features of Delhi Power System	3
2.	Performance of Generating Stations within Delhi	4
3.	Details of Outage of Generating Stations within Delhi	5-25
4.	Allocation of Power to Delhi from unallocated quota of central sector	26-30
5.	Allocation of Power to Discoms	31
6.	Power Availability Demand Position of Delhi at the time of occurrence of Peak Demand	32
7.	Power Availability Demand Position of Delhi at the time of occurrence of Maximum Un-Restricted Demand	33
8.	Source wise scheduled drawl from grid and Availability within Delhi	34-36
9.	Shedding Details	37-40
10.	Load Curve for the Day of Peak Demand	41
11.	Load Curve for the day of occurrence of Maximum Un-Restricted Demand	42
12.	Load Curve for the day of Maximum Energy Consumed	43
13.	Load Curve for the day of Maximum Un-Restricted Energy Demand	44
14.	Load Duration Curve	45
15.	Frequency Analysis	46
16.	Voltage Profile for significant 220kV Sub-Stations	47
17.	Voltage Profile for significant 400kV Sub-Stations	48-49
18.	Details of Capacitors Installations in Delhi	50-55
19.	Tripping Details of 400/220 KV System in Delhi Power System	56-59
20.	Details of Under frequency Relay operations in Delhi Power System	60

SALIENT FEATURES OF DELHI POWER SYSTEM

Sr. No.	Features	JANUARY 2012	JANUARY 2011
1	Effective Generation Capacity within Delhi in MW		
	Rajghat Power House	135	135
	Gas Turbine	270	270
	Pragati Power Corporation Ltd.	330	330
	Badapur Thermal Power Station	705	705
	Rithala GT	108	73
	Total	1548	1513
2	Maximum Unrestricted Demand (MW)	3934	4114
	Date	20.01.2012	10.01.2011
	Time	10.01.16	10.31.41
3	Peak Demand met (MW)	3934	4111
	Date	20.01.2012	10.01.2011
	Time	10.01.16	10.31.41
4	Peak Availability (MW)	3675	3936
5	Shortage (-) / Surplus (+) in MW	(-) 259	(-)175
6	Percentage Shortage (-) / Surplus (+)	(-)6.58	(-)4.26
7	Maximum Energy Consume in a day (Mus)	69.264	67.059
8	Energy Consumed during the month	1916.798	1839.595
9	Load Shedding in Mus		
A)	Due to Grid Restrictions		
i)	Under Frequency Relay Operations	0.021	0.000
ii)	Manual Load shedding from DTL S/Stns.	0.000	0.000
iii)	Load Shedding due to low frequency / Low Voltage / TTC/ATC Violation		
	NDPL	0.256	0.988
	BRPL	1.175	0.854
	BYPL	0.859	0.131
	NDMC	0.000	0.000
	MES	0.000	0.000
iv)	Due to transmission Constraints in Central Sector	0.000	0.070
	Total due to Grid Restriction	2.311	2.043
B)	Due to Constraints in System in Mus		
	DTL	2.288	0.337
	NDPL	0.288	0.249
	BRPL	0.268	0.422
	BYPL	0.044	0.580
	NDMC	0.000	0.001
	MES	0.000	0.000
	Other Agencies	2.423	0.001
	Total	5.311	1.590
11	Grand Total in Mus	7.622	3.633

2. **PERFORMANCE OF GENERATING STATIONS WITHIN DELHI DURING JANUARY 2012**

A) For the month of JANUARY 2012

All Figures in MUs

S. No	Stations	Gross Generation	Aux. Consumption	Net Generation	Availability (%)	Backing Down
1.	RPH	55.234	6.888	48.346	53.26	0
2.	GT	117.983	3.611	114.372	90.56	62.68
3.	PPCL	229.268	5.303	223.965	98.33	10.505
4.	BTPS	450.677	9.210	441.467	98.24	59.398
5.	Rithala	13.302	0.386	12.916	--	--
6.	Bawana	52.768	0.832	51.936	40.52	13.82
	TOTAL	919.232	26.23	893.002		

B) For the Year 2011-12 (Upto JANUARY 2012)

Power Station	Effective Capacity (MW)	Net Generation in MUs For JAN 2012	Availability (%) For JAN. 2012	PLF (%) For JAN. 2012	Cumulative Generation in MUs upto JAN. 2012 for the year 2011-12	Cumulative Availability in % upto JAN. 2012 for the year 2011-12	Cumulative PLF in % upto JAN. 2012 for the year 2011-12
RPH	135	48.346	53.26	53.26	673.587	67	66.92
GT	270	114.372	90.56	58.39	1117.743	77.40	55.46
PPCL	330	223.965	98.33	93.92	2127.891	97.78	93.38
BTPS	705	441.467	98.24	85.73	3640.405	84.45	75.68
Rithala	108	12.916	--	--	207.650	--	--
Bawana	216	51.936	40.52	32.11	88.177	44.63	35.86
TOTAL	1764	893.002			7855.453		

3 DETAILS OF OUTAGES OF GENERATING STNS. WITHIN DELHI W.E.F. APRIL 2010

(A) RPH STATION

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	67.5	11.05.11	20.11	11.05.11	21.28	Flash in yard
		21.05.11	01.53	21.05.11	05.25	Tripped alongwith tripping of associated transmission lines
		22.05.11	23.00	23.05.11	01.55	Boiler flame failure
		31.05.11	12.35	02.06.11	03.03	Condenser tube leakage
		10.06.11	05.40	10.06.11	12.32	UAT abnormality
		10.06.11	12.45	10.06.11	13.00	UAT abnormality
		03.07.11	11.40	06.07.11	17.19	Due to fire in 220/33kV 100MVA Pr. Tr.
		10.07.11	21.30	28.07.11	10.08	Tripped alongwith tripping of associated transmission lines
		30.07.11	14.50	31.07.11	24.00	Moisture in IBT -2
		06.08.11	06.32	08.08.11	01.31	Desynchronization due to moisture in 220kV Pr. Tr.
		15.08.11	14.17	15.08.11	21.20	Stopped due to low demand and high frequency.
		25.08.11	18.07	27.08.11	4.17	Boiler tube leakage
		01.09.11	11.41	01.09.11	12.52	Turbine tripped
		02.09.11	04.22	12.09.11	05.20	Boiler tube leakage
		13.09.11	07.05	13.09.11	09.01	Boiler flame failure
		15.09.11	12.01	15.09.11	13.12	Boiler flame failure
		15.09.11	12.45	16.09.11	00.09	Boiler flame failure
		16.09.11	17.03	18.09.11	17.50	Stopped due to wet coal
		19.09.11	00.10	19.09.11	01.28	Boiler flame failure
		21.09.11	03.46	21.09.11	04.50	Boiler flame failure
		02.10.11	12.33	02.10.11	12.54	High furnance pressure
		04.10.11	18.16	05.10.11	07.53	Leakage in boiler durm
		17.10.11	18.23	17.10.11	20.50	C&I Fault
		19.10.11	09.42	19.10.11	10.40	Furnance pressure high
		19.10.11	13.20	23.10.11	02.08	Boiler tube leakage
		23.10.11	15.58	23.10.11	16.35	Durm level very low
		01.11.11	13.03	01.11.11	13.35	Due to tripping of bay No. 9
		10.11.11	09.55	10.11.11	12.42	C & I Problem
		11.11.11	11.27	11.11.11	13.18	Due to tripping of bay No. 2
		11.11.11	13.33	11.11.11	17.19	Turbine problem
		15.11.11	21.35	26.11.11	23.05	Boiler tube leakage
		05.12.11	22.08	06.12.11	08.07	Grid Disturbance
		06.12.11	08.58	06.12.11	09.32	Boiler flame failure
		12.12.11	11.47	12.12.11	12.44	Both FD fans tripped
12.12.11	22.21	19.12.11	16.32	Boiler tube leakage		
24.12.11	17.10	24.12.11	17.35	Flame failure		
24.12.11	20.15	29.12.11	21.16	Boiler tube leakage		
04.01.12	14.06	21.01.12	21.50	Flame failure		
23.01.12	21.35	27.01.12	01.28	Very low furnance pressure		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	67.5	03.04.11	23.45	04.04.11	01.40	Turbine shaft vibration high
		28.04.11	06.38	28.04.11	15.27	To attend hot spot on 33kV Breaker
		21.05.11	01.53	21.05.11	07.32	Tripped alongwith tripping of associated transmission lines
		22.05.11	21.14	22.05.11	22.00	FD fan tripping
		26.05.11	12.10	26.05.11	13.00	Low boiler drum level
		31.05.11	23.15	01.06.11	08.12	Condenser tube leakage
		02.06.11	11.07	04.06.11	11.14	Boiler tube leakage
		04.06.11	16.50	04.06.11	17.50	Tripped on jerk
		04.06.11	18.18	04.06.11	20.12	Feed pump problem
		03.07.11	11.40	06.07.11	10.37	Due to fire in 220/33kV 100MVA Pr. Tr.
		10.07.11	13.53	27.07.11	05.10	Due to IBT-I, protection relay operated
		27.07.11	11.38	27.07.11	21.04	Due to tripping of bay no. 17
		30.07.11	14.50	31.07.11	03.45	Moisture in IBT -2
		06.08.11	07.00	08.08.11	00.10	Desynchronization due to moisture in 220kV Pr. Tr.
		15.08.11	14.21	15.08.11	22.00	Stopped due to low demand and high frequency.
		20.08.11	00.31	20.08.11	01.20	Boiler flame failure
		30.08.11	00.24	31.08.11	24.00	Boiler tube leakage
		31.08.11	00.00	01.09.11	08.38	Boiler tube leakage
		10.09.11	00.08	12.09.11	05.00	Coal handling plant problem
		13.09.11	03.50	13.09.11	05.00	Electrical fault
		25.09.11	10.57	25.09.11	11.30	Turbine vibration
		30.09.11	22.14	03.10.11	06.00	Boiler tube leakage
		01.11.11	13.03	01.11.11	13.50	Due to tripping of bay no. 19
		03.11.11	20.16	03.11.11	13.45	Turbine problem
		08.11.11	21.05	11.11.11	00.13	Boiler tube leakage
		11.11.11	11.27	11.11.11	14.16	Due to tripping of bay no. 2
		16.11.11	16.10	16.11.11	16.50	Electrical fault
		17.11.11	09.36	17.11.11	10.05	Turbine tripped
		25.11.11	12.35	25.11.11	13.23	
		30.11.11	20.58	30.11.11	22.55	Turbine vibration high
		30.11.11	23.12	01.12.11	03.35	
		01.01.11	10.06	01.12.11	10.33	
		05.12.11	22.08	06.12.11	05.22	Grid disturbance
		07.12.11	13.08	07.12.11	14.07	Due to tripping of Pr. Tr.
		05.01.12	06.02	05.01.12	12.30	Tripped on jerk
		16.01.12	14.54	17.01.12	01.10	Electrical fault

(B)

Gas Turbine

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	01.04.11	00.00	11.04.11	20.25	Machine stopped as generation available in open cycle mode
		12.04.11	00.02	12.04.11	18.25	
		16.04.11	17.17	17.04.11	10.15	
		17.04.11	17.02	22.04.11	11.10	Machine stopped due to low demand
		30.04.11	12.20	05.05.11	00.45	Machine stopped as generation available in open cycle mode
		15.05.11	06.15	16.05.11	23.50	
		17.05.11	08.37	17.05.11	17.29	Machine stopped as generation available on spot RLNG
		21.05.11	12.13	21.05.11	16.36	Stopped due to low demand and high frequency.
		02.06.11	09.32	03.06.11	10.25	
		08.06.11	20.35	09.06.11	00.34	Electrical trouble
		17.06.11	01.02	18.06.11	01.22	Machine stopped as generation available in open cycle mode
		19.06.11	07.04	21.06.11	03.05	
		26.06.11	12.20	27.06.11	11.26	Stopped due to low demand and high frequency.
		30.06.11	11.50	02.07.11	20.29	
		08.07.11	23.05	10.07.11	16.42	
		07.08.11	21.40	17.08.11	11.40	Machine stopped as generation available on spot RLNG
		20.08.11	12.20	20.08.11	22.00	Machine stopped as per SLDC message to maintain only 109 MW
		20.08.11	22.00	21.08.11	18.30	Machine is not available due to problem in Excitation
		21.08.11	18.30	22.08.11	15.58	Machine stopped as generation available on spot RLNG
		23.08.11	14.15	25.08.11	12.40	
		31.08.11	14.32	31.08.11	15.36	Stopped to attend lube oil leakage
		03.09.11	09.02	03.09.11	10.30	Stopped due to low demand and high frequency.
		03.09.11	13.05	03.09.11	13.35	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		04.09.11	02.47	06.09.11	17.20	Stopped due to low demand and high frequency.
		11.09.11	22.05	14.09.11	20.36	Machine stopped as generation available on spot RLNG
		15.09.11	01.14	19.09.11	11.55	Machine stopped as generation available on spot open cycle mode
		20.09.11	01.15	20.09.11	13.40	
		21.09.11	01.32	21.09.11	17.16	
		22.09.11	00.02	22.09.11	08.42	
		23.09.11	00.35	24.09.11	10.47	
		25.09.11	00.02	26.09.11	10.10	
		27.09.11	00.20	27.09.11	08.40	
		27.09.11	15.15	27.09.11	15.25	Machine came on FSNL during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		28.09.11	01.10	28.09.11	08.52	Machine stopped as generation available on spot open cycle mode
		29.09.11	02.10	29.09.11	10.57	
		30.09.11	00.12	30.09.11	10.20	
		30.09.11	23.50	01.10.11	19.38	
		01.10.11	23.04	03.10.11	10.45	
		03.10.11	23.59	04.10.11	10.54	Machine stopped due to swapping of gas to PPCL
		08.10.11	23.59	09.10.11	08.37	
25.10.11	00.50	25.10.11	05.58	Machine stopped as generation available on spot RLNG		
25.10.11	07.45	25.10.11	10.17	Machine tripped on rotating diode earth fault		
07.11.11	02.05	07.11.11	08.14	Machine stopped to maintain only 115 MW load due to overloading of Pragati- Maharani bagh ckt .		
07.11.11	22.17	07.11.11	23.31	Tripped due to tripping of 2 MVA Tx-I		
08.11.11	00.45	12.11.11	18.06	Machine stopped as generation available on spot RLNG		
12.11.11	20.02	13.11.11	18.02			
20.11.11	03.15	20.11.11	09.40			
26.11.11	15.02	30.11.11	10.20	Stopped due to high TAD		
				Machine stopped as generation available on spot RLNG		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	30	07.12.11	03.35	08.12.11	00.50	Machine stopped as generation available on spot RLNG
		13.12.11	00.05	13.12.11	05.46	
		16.12.11	01.30	16.12.11	08.43	
		16.12.11	22.30	17.12.11	06.20	
		18.12.11	23.06	21.12.11	12.55	
		23.12.11	00.02	23.12.11	09.50	
		23.12.11	22.05	24.12.11	08.55	
		25.12.11	01.20	25.12.11	07.10	
		25.12.11	17.05	27.12.11	05.40	
		28.12.11	00.02	28.12.11	05.48	
		28.12.11	22.19	29.12.11	09.48	
		29.12.11	14.02	30.12.11	06.40	
		31.12.11	00.45	31.12.11	08.50	
		31.12.11	19.55	02.01.11	06.25	
		05.01.12	03.22	05.01.12	11.45	
		05.01.12	18.02	07.01.12	07.55	Machine stopped as generation available on spot RLNG
		08.01.12	00.05	09.01.12	07.55	
		10.01.12	01.46	10.01.12	06.41	
		10.01.12	23.55	11.01.12	06.55	
		11.01.12	19.02	12.01.12	09.25	
16.01.12	00.28	20.01.12	07.40			
20.01.12	10.30	24.01.12	14.15			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage	
		Date	Time	Date	Time		
2	30	01.04.11	00.00	11.04.11	21.37	Machine stopped as generation is available in open cycle mode.	
		12.04.11	00.02	12.04.11	20.27		
		12.04.11	21.00	21.04.11	12.48		
		24.04.11	23.35	25.04.11	05.20	Machine tripped on high vibration	
		30.04.11	18.15	05.05.11	19.45	Due to swapping of gas to PPCL.	
		13.05.11	16.02	13.05.11	18.10	High exhaust temp spread.	
		15.05.11	06.18	15.05.11	21.35	Stopped due to low demand and high frequency.	
		21.05.11	12.13	21.05.11	12.55		
		15.06.11	07.35	15.06.11	08.25	Loss of flame	
		15.06.11	17.40	15.06.11	18.40	Loss of flame	
		15.06.11	22.10	16.06.11	03.22	Loss of flame	
		18.06.11	02.02	20.06.11	17.35	Machine stopped as generation available in open cycle mode	
		02.07.11	21.12	03.07.11	16.10		
		08.07.11	23.02	10.07.11	19.27		
		06.08.11	00.05	07.08.11	15.50	Machine stopped as generation available on spot RLNG	
		07.08.11	23.10	16.08.11	12.20		
		17.08.11	14.30	17.08.11	19.00		
		03.09.11	11.05	03.09.11	17.05	Machine stopped as generation available on spot RLNG	
		11.09.11	22.05	12.09.11	21.58		
		13.09.11	00.02	14.09.11	17.45		
		15.09.11	01.04	19.09.11	11.56	Machine stopped as generation available in open cycle mode	
		20.09.11	01.15	20.09.11	13.14		
		21.09.11	01.32	21.09.11	17.20		
		22.09.11	00.02	22.09.11	08.27		
		23.09.11	01.02	24.09.11	10.40		
		25.09.11	00.02	26.09.11	09.45		
		27.09.11	00.10	27.09.11	08.48		
		28.09.11	01.05	28.09.11	08.40		
		29.09.11	02.02	29.09.11	10.55		
		30.09.11	00.12	30.09.11	10.20		
		30.09.11	23.50	01.10.11	19.10		
		01.10.11	23.06	03.10.11	10.50		
		03.10.11	23.59	04.10.11	10.50		
		16.10.11	13.03	16.10.11	07.12		Tripped on condensate level high trip alarm & reverse power on protection pannel
		07.11.11	02.05	07.11.11	08.05		Machine stopped as generation available on spot RLNG
		20.11.11	05.55	20.11.11	09.32		Machine stopped as generation available in open cycle mode
		26.11.11	18.41	29.11.11	10.14	Machine stopped as generation available on spot RLNG	
		30.11.11	10.15	30.11.11	14.00	Machine tripped on combined cycle trip alarm	
		30.11.11	14.00	30.11.11	17.35	Machine stopped as generation available on spot RLNG	
		08.12.11	17.10	09.12.11	07.56		
14.12.11	00.55	14.12.11	05.58				
14.12.11	22.31	15.12.11	13.15				
16.12.11	22.45	17.12.11	10.13	Tripped on TAD very high.			
19.12.11	03.35	19.12.11	15.20				
24.12.11	19.52	25.12.11	00.35	Tripped on high exhaust temp. spread.			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
2	30	03.01.12	12.10	05.01.12	11.04	Machine stopped as generation available on spot RLNG
		17.01.12	06.32	18.01.12	10.25	
		22.01.12	00.01	23.01.12	08.36	
		24.01.12	22.20	25.01.12	07.25	Stopped due to low demand and high frequency
		27.01.12	20.01	28.01.12	00.40	
		28.01.12	16.15	31.01.12	23.59	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	11.04.11	11.25	11.04.11	20.41	Due to failure of Auxiliary supply.
		12.04.11	00.02	12.04.11	18.35	Machine stopped as generation available on open cycle mode
		12.04.11	21.10	13.04.11	09.40	
		16.04.11	03.50	17.04.11	21.27	
		19.04.11	00.02	19.04.11	05.52	Due to low demand and high frequency.
		20.04.11	00.02	20.04.11	05.52	
		28.04.11	02.05	28.04.11	13.55	Due to swapping of gas to PPCL.
		04.05.11	01.32	04.05.11	11.50	Machine stopped as generation available on spot RLNG
		08.05.11	03.16	08.05.11	22.44	Stopped due to low demand and high frequency.
		09.05.11	21.45	10.05.11	15.37	
		10.05.11	15.37	10.05.11	20.15	Electrical trouble
		10.05.11	20.15	11.05.11	16.20	Machine stopped as generation available on spot RLNG
		12.05.11	00.05	12.05.11	10.11	
		17.05.11	18.15	17.05.11	23.59	
		18.05.11	00.00	27.07.11	00.00	Start command executed but smoke observed from the Diesel Engine
		27.07.11	00.00	27.07.11	12.25	Machine stopped as generation available on spot RLNG
		27.07.11	19.02	28.07.11	15.00	
		28.07.11	21.35	29.07.11	12.00	
		29.07.11	16.40	30.07.11	01.37	
		30.07.11	02.10	30.07.11	13.02	Machine started for making the drum per 10Kg/cm sq. for passivation of boiler #3
		30.07.11	14.10	30.07.11	23.32	Machine stopped as generation available on spot RLNG
		30.07.11	23.58	31.07.11	23.59	
		01.08.11	19.50	03.08.11	11.01	
		13.08.11	05.35	16.08.11	05.20	
		17.08.11	20.10	18.08.11	10.45	
		18.08.11	12.32	18.08.11	17.32	
		25.08.11	14.15	26.08.11	12.20	Machine stopped as generation available on spot RLNG
		03.09.11	09.05	09.09.11	19.35	
		21.09.11	05.02	21.09.11	13.43	Machine stopped as generation available on open cycle mode.
		27.09.11	15.15	27.09.11	15.58	Machine tripped during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		27.10.11	15.15	31.10.11	07.12	Stopped due to low demand and high frequency.
		03.11.11	02.32	03.11.11	09.27	
		23.11.11	00.05	26.11.11	04.50	Machine stopped as generation available on spot RLNG
26.11.11	15.40	26.11.11	18.10	Machine stopped as generation available on spot RLNG		
08.12.11	23.16	12.09.11	08.06			
10.12.11	23.30	12.12.10	05.46			
14.12.11	15.15	15.12.11	12.50			
15.12.11	14.17	15.12.11	17.30	Machine tripped on 63TP-1,Buch-1 alarm operated on protection pannel.		
18.12.11	20.20	18.12.11	22.30	Machine stopped as generation available on spot RLNG		
19.12.11	02.15	19.12.11	12.55	Tripped on TAD very high.		
19.12.11	23.25	20.12.11	14.15	Machine stopped as generation available on spot RLNG		
21.12.11	14.30	21.12.11	17.50			
28.12.11	15.35	28.12.11	22.04			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
3	30	06.01.12	23.55	07.01.12	07.37	Machine stopped as generation available on spot RLNG
		14.01.12	23.00	18.01.12	10.02	
		20.01.12	00.05	20.01.12	07.55	
		21.01.12	00.05	21.01.12	08.10	
		22.01.12	16.47	22.01.12	21.44	
		24.01.12	11.20	24.01.12	13.50	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure
		24.01.12	22.20	25.01.12	07.28	Stopped due to low demand and high frequency
		25.01.12	18.20	27.01.12	05.48	
		28.01.12	23.50	31.01.12	16.30	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	30	11.04.11	11.25	11.04.11	20.00	Due to failure of Auxiliary supply.
		12.04.11	19.45	12.04.11	20.35	Machine came on FSNL
		13.04.11	09.14	14.04.11	00.45	Machine stopped as generation available on open cycle mode
		16.04.11	10.05	17.04.11	12.50	
		21.05.11	04.00	23.05.11	10.37	Stopped due to low demand and high frequency.
		23.05.11	14.25	26.05.11	14.42	
		26.05.11	18.24	30.05.11	16.05	Machine stopped as generation available on spot RLNG
		02.06.11	09.35	03.06.11	10.50	
		03.06.11	11.15	06.06.11	10.40	Stopped due to low demand and high frequency.
		22.06.11	18.02	23.06.11	02.57	Machine stopped as generation available in open cycle mode
		16.07.11	14.20	31.07.11	23.59	
		01.08.11	00.00	05.08.11	12.17	Machine stopped as generation available on spot RLNG
		11.08.11	06.58	11.08.11	09.05	Machine tripped on loss of flame
		12.08.11	04.40	12.08.11	05.35	Machine tripped on high TAD
		12.08.11	06.52	12.08.11	15.40	Tripped without any alarm in control room
		15.08.11	10.42	16.08.11	06.15	
		16.08.11	15.31	16.08.11	20.28	Machine stopped as generation available on spot RLNG.
		16.08.11	23.50	21.08.11	00.55	
		21.08.11	08.15	27.08.11	23.59	Machine stopped as there was low demand
		03.09.11	13.05	03.09.11	13.40	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		03.09.11	14.10	09.09.11	19.50	Machine stopped as generation available on spot RLNG
		16.09.11	09.13	16.09.11	11.34	Machine tripped on exhaust over temp high
		16.09.11	15.35	16.09.11	17.08	Due to problem of AC supply the Battery voltage came down to 111 Volt. Machine stopped as per request from C&I division.
		21.09.11	14.23	21.09.11	21.27	Machine stopped as generation available on open cycle mode
		24.10.11	06.00	24.10.11	11.40	
		25.10.11	00.52	25.10.11	05.55	Machine stopped as generation available on spot RLNG
		25.10.11	19.20	26.10.11	17.55	
		27.10.11	15.15	02.11.11	11.40	
		13.11.11	23.58	14.11.11	05.58	Stopped due to low demand and high frequency.
		19.11.11	01.16	19.11.11	13.44	Machine stopped as generation available on spot RLNG
		20.11.11	07.15	20.11.11	09.33	Machine tripped on high TAD
		20.11.11	10.15	20.11.11	15.55	Machine tripped on high TAD
		03.12.11	19.05	05.12.11	05.25	
		18.12.11	00.01	19.12.11	02.44	Machine stopped as generation available on spot RLNG
19.12.11	07.42	19.12.11	11.22	Stopped on TAD very high.		
20.12.11	02.55	20.12.11	09.30	Tripped on TAD very high.		
21.12.11	00.02	21.12.11	07.50	Machine stopped due to low demand.		
21.12.11	18.14	22.12.11	08.25			
26.12.11	12.54	26.12.11	22.15	Machine stopped as generation available on spot RLNG		
14.01.12	23.00	18.01.12	12.10			
28.01.12	00.16	28.01.12	00.40	Tripped on Gen.Gac electrical protection trouble normal shut down. On protection pannel negative phase sequence trip appeared		
28.01.12	00.40	28.01.12	15.30	Machine stopped due to low demand.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	11.04.11	11.25	11.04.11	12.55	Due to failure of Auxiliary supply.
		11.04.11	14.25	11.04.11	14.55	Due to failure of Auxiliary supply.
		12.04.11	17.42	16.04.11	17.15	Machine stopped as generation available on open cycle
		17.04.11	14.32	18.04.11	20.17	Due to low demand and high frequency.
		21.04.11	22.45	30.04.11	17.24	
		03.05.11	04.01	03.05.11	14.40	Machine stopped as generation available on spot RLNG
		04.05.11	01.35	04.05.11	12.40	
		05.05.11	11.05	05.05.11	11.50	
		05.06.11	19.16	05.07.11	19.25	
		07.05.11	21.35	08.05.11	21.45	
		13.05.11	01.05	13.05.11	05.50	Machine stopped as generation available in open cycle
		13.05.11	18.30	15.05.11	18.28	Machine stopped as generation available on spot RLNG
		20.05.11	01.17	20.05.11	13.35	
		21.05.11	10.55	23.05.11	19.15	Due to low demand and high freq.
		31.05.11	00.05	31.05.11	16.13	Machine stopped as generation available in open cycle mode
		31.05.11	23.02	03.06.11	10.15	Machine tripped on high exhaust temperature trip
		05.06.11	08.04	05.06.11	12.28	
		07.06.11	14.58	07.06.11	16.28	Machine stopped as generation available in open cycle mode
		14.06.11	03.46	15.06.11	19.45	
		15.06.11	22.03	16.06.11	01.14	Machine tripped on high vibration
		16.06.11	05.17	16.06.11	11.44	
		16.06.11	20.02	16.06.11	22.50	Electrical trouble
		16.06.11	23.50	17.06.11	00.15	Machine came on FSNL while changing the faulty u/v relay
		26.06.11	09.02	03.07.11	16.18	Due to low demand and high freq
		07.07.11	14.55	16.07.11	13.15	Machine stopped as generation available on spot RLNG
		07.08.11	00.02	08.08.11	00.10	
		15.08.11	10.42	16.08.11	06.15	
		16.08.11	15.31	16.08.11	20.28	
		16.08.11	23.50	21.08.11	00.55	
		21.08.11	08.15	21.08.11	11.25	
		21.08.11	14.02	31.08.11	23.59	
		01.09.11	17.38	02.09.11	21.50	Machine stopped as generation available on spot RLNG
		03.09.11	13.05	03.09.11	13.45	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		04.09.11	02.50	14.09.11	18.30	Machine is stopped due to low demand and high freq
		14.09.11	18.30	29.10.11	22.45	machine taken under shut down for turbine rotor replacement
		30.10.11	01.50	31.10.11	11.38	Machine stopped as generation available in open cycle
		01.11.11	07.20	01.11.11	17.50	Machine is stopped due to low demand and high freq
		02.11.11	01.11	08.11.11	12.00	
		08.11.11	12.00	11.11.11	12.40	Machine not taken on load due problem in diesel Engine
		11.11.11	18.53	26.11.11	13.06	Machine stopped due to high vibration at BB4 & BB5 i.e 9 mm/se for further inspection by BGGTS
29.11.11	14.25	29.11.11	21.14	Machine tripped by tripping 11 KV breaker manually as reverse power operated fail alarm appeared on protection pannel.		
03.12.11	14.37	06.12.11	18.02	Machine stopped as generation available on spot RLNG		
07.12.11	03.40	07.12.11	06.00	Machine taken under Shut down by M-I division to attend lube oil leakage.		
07.12.11	11.30	07.12.11	18.30	Machine stopped as generation available on spot RLNG		
07.12.11	23.35	08.12.11	16.23			
12.12.11	19.29	14.12.11	14.23			
19.12.11	09.20	19.12.11	13.10	Tripped on TAD very high.		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
5	30	02.01.12	08.40	03.01.12	11.20	Machine stopped as generation available on spot RLNG
		13.01.12	01.15	14.01.12	06.48	
		19.01.12	00.00	19.01.12	08.00	
		20.01.12	00.00	20.01.12	10.10	
		24.01.12	11.20	24.01.12	12.45	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure
		25.01.12	18.20	27.01.12	10.05	Machine is stopped due to low demand and high freq
		27.01.12	15.02	31.01.12	23.59	

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	11.04.11	11.25	11.04.11	13.20	Due to failure of Auxiliary supply.
		11.04.11	14.25	11.04.11	20.55	Due to failure of Auxiliary supply.
		12.04.11	00.02	12.04.11	17.40	Machine stopped as generation available on open cycle mode
		12.04.11	18.37	16.04.11	12.20	Due to low demand and high frequency
		17.04.11	21.56	18.04.11	19.55	
		19.04.11	00.02	19.04.11	05.55	
		20.04.11	00.02	20.04.11	05.42	
		22.04.11	12.18	24.04.11	11.45	Machine stopped as generation available on Spot RLNG
		24.04.11	16.10	26.04.11	21.20	Due to low demand and high frequency
		27.04.11	00.05	30.04.11	12.12	
		07.05.11	03.40	07.05.11	11.02	
		08.05.11	22.02	09.05.11	21.25	Machine stopped as generation available on spot RLNG
		12.05.11	10.51	12.05.11	15.18	
		13.05.11	00.05	13.05.11	18.33	
		21.05.11	18.30	23.05.11	10.55	Stopped due to low demand and high frequency.
		26.06.11	09.02	04.07.11	11.00	
		04.07.11	15.15	05.07.11	11.00	Machine stopped as generation available on spot RLNG
		15.07.11	23.05	20.07.11	12.50	Due to low demand and high frequency
		23.07.11	02.17	23.07.11	03.27	Machine tripped on loss of flame
		24.07.11	04.15	25.07.11	09.17	Due to low demand and high frequency
		03.08.11	15.25	03.08.11	20.20	Machine stopped as generation available on spot RLNG
		05.08.11	02.01	05.08.11	20.58	
		17.08.11	04.02	20.08.11	22.10	
		22.08.11	16.30	23.08.11	11.30	
		24.08.11	01.50	31.08.11	23.59	
		01.09.11	17.48	02.09.11	21.40	Machine stopped as generation available on spot RLNG
		03.09.11	13.05	03.09.11	13.45	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		06.09.11	18.35	11.09.11	18.25	Stopped due to low demand and high frequency.
		21.09.11	18.40	23.09.11	00.27	Machine tripped due to blowing of fuse of Mark-Vi.
		27.09.11	15.15	27.09.11	15.30	Machine came on FSNL during checking of Bus Coupler differential trippings, Differential relay on BB-3 & 4 operated .
		01.10.11	17.30	01.10.11	22.02	Tripped with STG#3 Generator breaker trip battery voltage ground alarm
		20.10.11	20.16	21.10.11	15.10	Tripped on communication link failed with any of IO pack & loss of flame
		31.10.11	10.32	03.11.11	09.20	Stopped due to low demand and high frequency
01.12.11	00.45	01.12.11	06.25	Machine stopped as generation available on spot RLNG		
01.12.11	09.58	03.12.11	13.55			
05.12.11	19.02	07.12.11	03.05			
09.12.11	22.20	12.12.11	18.40			
15.12.11	23.55	16.12.11	08.41			
18.12.11	14.02	18.12.11	20.10			
19.12.11	04.10	19.12.11	10.55		Tripped on TAD very high.	
20.12.11	01.25	20.12.11	09.15	Tripped on TAD very high.		
21.12.11	18.32	22.12.11	07.52	Machine stopped as generation available on spot RLNG		
22.12.11	17.50	23.12.11	09.52			
23.12.11	14.20	24.12.11	08.40			
25.12.11	00.46	25.12.11	07.02			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
6	30	25.12.11	23.55	26.12.11	11.58	Machine stopped as generation available on spot RLNG
		27.12.11	00.05	27.12.11	05.25	
		28.12.11	00.45	28.12.11	05.15	
		28.12.11	23.25	29.12.11	09.40	
		29.12.11	23.01	30.12.11	07.55	
		31.12.11	00.45	31.12.11	05.25	
		31.12.11	17.10	02.01.12	06.15	
		04.01.12	23.02	05.01.12	02.50	
		05.01.12	23.52	06.01.12	07.46	
		06.01.12	23.50	11.01.12	12.30	
		12.01.12	00.30	12.01.12	08.00	
		12.01.12	23.58	13.01.12	00.59	
		13.01.12	02.00	13.01.12	07.55	
		13.01.12	14.45	14.01.12	06.40	
		16.01.12	00.30	17.01.12	06.10	
		21.01.12	00.10	21.01.12	08.20	
		22.01.12	00.02	23.01.12	08.45	
		24.01.12	00.02	24.01.12	06.45	
		24.01.12	11.25	24.01.12	12.25	Machine stopped as DD of HRSG#6 not taking close command due to failure of DC supply.
		24.01.12	22.25	25.01.12	11.40	Stopped due to low demand and high frequency
25.01.12	16.55	31.01.12	23.59			

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG -1	30	01.04.11	00.00	16.04.11	00.40	To attend miscellaneous problems
		16.04.11	11.10	17.04.11	14.27	Machine stopped attend leakage.
		17.04.11	17.02	21.04.11	20.58	Machine stopped due to low demand
		23.04.11	06.32	23.04.11	11.10	Problem in 24 Volt DC supply.
		30.04.11	00.52	30.04.11	02.56	Machine stopped due to low demand Machine tripped and following relay operated
		30.04.11	18.15	05.05.11	05.05	
		05.05.11	23.35	06.05.11	02.28	
		07.05.11	01.45	07.05.11	03.40	
		10.05.11	13.50	10.05.11	17.40	Low vacuum
		15.05.11	06.20	15.05.11	22.54	To attend various leakages
		21.05.11	09.50	21.05.11	14.05	Tripped on Ch-I &II
		21.05.11	16.22	21.05.11	17.35	Machine tripped on low vacuum.
		30.05.11	09.20	30.05.11	11.05	Machine tripped on low vacuum.
		07.06.11	02.43	07.06.11	05.20	Tripped on Ch-I &II
		19.06.11	07.04	21.06.11	02.10	To attend various leakages
		21.06.11	15.58	21.06.11	16.59	To attend various leakages
		08.07.11	23.05	10.07.11	19.34	Due to low demand and high frequency
		26.07.11	13.50	26.07.11	15.01	Machine tripped on flase alarm of Shaft Vibratrtion V. high and Housing vibration v.high
		26.07.11	15.20	26.07.11	16.46	Machine tripped on flase alarm of Shaft Vibratrtion V. high and Housing vibration v.high
		29.07.11	15.55	29.07.11	17.31	Machine tripped manually as the vaccum dropped upto -0.40 kg/cm2 due to tripping of BFP-1A as another BFP-1B was under preventive maintenance
		29.07.11	17.42	29.07.11	18.11	Machine tripped on hot well level high
		07.08.11	18.58	15.08.11	00.00	Machine tripped due to problem in Control valve and boxed up for further inspection as directed by Mech division
		15.08.11	00.00	16.08.11	15.20	Machine not taken on bar due to low demand
		03.09.11	13.05	03.09.11	14.40	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		11.09.11	17.25	14.10.11	05.10	Machine tripped on Generator shaft vibration v. high. Machine boxed for further inspection of generator Rotor & Excitor. After examining the parameters of Generator Rotor it was decided to replace it with new Rotor
		07.11.11	22.17	08.11.11	01.28	Tripped due to tripping of 2 MVA Tx-I
		08.11.11	06.48	08.11.11	08.18	STG#1 tripped due to coupling breaker of 2 MVR Tx-1&II and DG set tripped and no relay/alarm appearing on breaker of Tx.
		20.11.11	04.48	20.11.11	12.05	Machine tripped with following relay operated 27G, 40G ,86GA II, 27GX, 30GTA/30GTB,63 GT-1,multipliers,aux relay in Class A Group-I and Class B -86 GB, AVR VTI fuse and AVR VT-2 .
		25.11.11	19.02	25.11.11	22.15	Stopped to attend hot spot on Y-Phase line isolater.
		26.11.11	18.41	28.11.11	12.44	Machine stopped as generation available on spot RLNG
		28.11.11	12.58	29.11.11	14.55	Machine stopped due to high vibration on Turbine FJB & RJB.
		30.11.11	10.15	30.11.11	13.29	Machine tripped manually due to tripping of GT# 2
12.12.11	06.59	12.12.11	08.53	Tripped on low vaccum due to tripping CEP as 800KVA Trf-1 tripped on Buck-holtz relay		
13.12.11	11.05	13.12.11	13.32	Machine tripped		
16.12.11	22.45	17.12.11	08.20	Machine stopped as generation available on spot RLNG		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG #1	30	19.12.11	03.35	19.12.11	16.46	Tripped due to tripping of GT#2 as TAD of GT#2 very high.
		24.12.11	19.10	24.12.11	21.40	Tripped on Gen. front bearings vibration very high on right side probe. Relay operated 86GB, aux. relay 60A, 60AX, Aux. relay for 60PP, 60PPX, Aux. relay for 60 Pmax.
		29.12.11	14.34	29.12.11	19.35	Tripped on class A relay trip alarm. Following relay appear in DDC room of STG#1: Gen. class A trip relay 86GA, Gen. class B tripping relay 86GB, Aux. relay for 60AX, 60PPA, 60PMA, 32G & 27GX also appeared.
		30.12.11	14.53	30.12.11	15.52	Tripped on CH-I & CH-II operated.
		05.01.12	03.22	05.01.12	12.37	Stopped due to stopping of GT#1 due to high TAD.
		17.01.12	03.51	17.01.12	06.32	Tripped on turbine shaft vibration (RJB) very high alarm.
		17.01.12	06.32	18.01.12	12.25	Machine stopped as generation available on spot RLNG
		18.01.12	13.10	18.01.12	19.55	Tripped on Low vacuum.
		22.01.12	00.01	23.01.12	10.55	Machine stopped as generation available on spot RLNG
		24.01.12	11.20	24.01.12	16.10	Machine tripped due to failure of Aux. supply as 20 MVA Transformer tripped on lind stage gas pressure

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG 2	30	11.04.11	10.40	17.04.11	16.20	Low vacuum
		21.05.11	04.00	23.05.11	11.00	Machine stopped due to low demand
		23.05.11	11.00	25.05.11	12.59	Machine tripped on Rotor earth fault
		24.05.11	13.00	26.05.11	18.20	Machine stopped as generation available on spot RLNG
		26.05.11	18.24	30.05.11	20.25	
		02.06.11	09.36	06.06.11	10.40	Machine stopped due to low demand & high frequency
		19.06.11	15.05	19.06.11	20.00	Low vacuum
		22.06.11	18.02	23.06.11	04.25	To attend various leakages
		28.06.11	16.03	28.06.11	17.53	Tripped on Ch-I &II
		16.07.11	14.20	03.08.11	14.45	Machine stopped as generation available on spot RLNG
		14.08.11	11.36	16.08.11	07.50	
		03.09.11	03.20	03.09.11	04.25	Machine stopped for replacement of speed pick up
		03.09.11	13.05	03.09.11	14.10	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		03.09.11	14.10	09.09.11	21.25	Machine stopped as generation available on spot RLNG
		25.09.11	12.05	25.09.11	14.28	Machine tripped due to malfunctioning of deaerator level as BFP-2A tripped and 2B did not take start command due to non availability of Deaerator level.
		26.09.11	20.35	26.09.11	21.50	BFP-2A tripped due to malfunctioning of Deaerator level. Deaerator Level V.Low , Low, High, very high alarm appeared. BFP-2B taken into service it also tripped on same alarm. Machine tripped on low vacuum.
		11.10.11	14.30	11.10.11	16.50	Machine tripped from DDC for checking the hunting in parameters.
		19.10.11	03.02	19.10.11	07.08	Machine tripped due to class B relay operated.
		20.10.11	12.50	20.10.11	14.02	Tripped due to jerk in control room.
		21.10.11	11.50	21.10.11	13.05	Machine stopped due to choking of CEP Stainer as another CEP was under preventive maintenance
		27.10.11	15.15	31.10.11	10.20	Machine stopped due to low demand & high frequency
		12.12.11	06.59	12.12.11	10.10	Tripped due to tripping of 800KVA Trf-1 on low vacuum as both running CEPs tripped.
		18.12.11	14.50	18.12.11	15.45	Tripped due to the following parameters disappeared on BCD & CRT:lube oil temp.,exhaust steam temp.,condensate temp.,BFP discharge header pressure &temp.
		18.12.11	19.20	19.12.11	00.08	Tripped due to HRSG#3 drum level very low.
		19.12.11	02.15	19.12.11	03.40	Tripped due to tripping of GT#3 as TAD of GT#3 very high.
		19.12.11	07.42	19.12.11	13.45	Stopped due to stopping of GT#4 because TAD very high.
20.12.11	02.55	20.12.11	11.58	Tripped due to tripping of GT#4 as TAD of GT#4 very high.		
14.01.12	23.00	18.01.12	12.00	Machine stopped as generation on Spot R-LNG is not required by SLDC		
24.01.12	11.20	24.01.12	13.35	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG 3	30	11.04.11	11.25	17.04.11	16.28	Due to failure of Auxiliary supply.
		17.04.11	20.05	18.04.11	21.55	Machine stopped due to low demand
		22.04.11	12.17	30.04.11	16.16	Machine available on spot R-LNG
		01.05.11	14.52	01.05.11	15.40	Steam Turbine Speed very high.
		07.05.11	03.40	07.05.11	13.58	Machine stopped due to low demand
		12.05.11	09.16	13.05.11	20.35	Main steam temperature low
		21.05.11	18.30	23.05.11	13.55	Machine stopped due to low demand
		05.06.11	10.15	05.06.11	11.15	Low vacuum
		06.06.11	09.05	06.06.11	11.25	Turbine shaft vibration high
		13.06.11	13.10	13.06.11	14.34	Machine tripped on CH-I& II.
		26.06.11	09.02	30.06.11	23.59	Machine stopped due to low demand
		20.07.11	13.50	20.07.11	14.20	Machine tripped on Both the boiler trip alarm. No alarm appeared in the Turbine interlock page.
		20.07.11	14.36	20.07.11	15.20	Machine tripped on Both the boiler trip alarm. No alarm appeared in the Turbine interlock page.
		28.07.11	07.04	28.07.11	07.43	Machine tripped due to tripping of HRSGs. HRSG tripped on low drum level as BFP-3A tripped due to malfunctioning of temperature of NDE of motor.
		17.08.11	04.02	21.08.11	00.15	Machine stopped as generation available on spot RLNG.
		22.08.11	13.15	23.08.11	13.45	Machine tripped on Class A. machine cleared from Elect division but not taken on load due to low demand.
		24.08.11	01.50	31.08.11	23.59	Machine stopped due to low demand
		03.09.11	13.05	03.09.11	15.10	Machine tripped as Bus differential relay on BB-3 & 4 operated.
		06.09.11	18.35	11.09.11	22.10	Machine Stopped due to low demand & high frequency
		16.09.11	09.35	16.09.11	11.45	Machine tripped on class A alarm
		18.09.11	08.54	18.09.11	09.25	Machine tripped on Gen class A trip, AVR trip command and excitation field breaker open.
		20.09.11	09.03	20.09.11	09.27	Machine tripped on class A alarm
		21.09.11	16.40	23.09.11	03.10	Machine tripped due to tripping of GT#6
		27.09.11	15.15	27.09.11	16.00	Machine tripped as GT#6 came on FSNL
		01.10.11	17.30	02.10.11	01.45	Tripped with GT#6 Generator breaker trip battery voltage ground alarm.
		13.10.11	05.10	13.10.11	08.33	Machine tripped as all the parameters disapperaed.
		13.10.11	14.42	13.10.11	14.55	Machine tripped on low vaccum as CEP-3A tripped on Hot well very low alarm. It is found that Condensate water drained from the drain of CPH-5. This drain valve is being cut by the O/h team.
		20.10.11	20.16	21.10.11	17.25	Tripped due to tripping of GT#6.
		31.10.11	10.30	03.11.11	12.35	Machine Stopped due to low demand & high frequency
		19.12.11	09.20	19.12.11	12.57	Tripped due to tripping of GT#5 as TAD of GT#5 very high
		02.01.12	06.05	02.01.12	06.55	Stopped due to MS temprature low.
		04.01.12	07.09	04.01.12	07.39	Tripped on Hot well level high.
		13.01.12	02.00	14.01.12	08.58	Machine stopped as generation available on spot RLNG
24.01.12	11.20	24.01.12	14.15	Machine tripped due to failure of Aux.supply as 20 MVA Transformer tripped on lind stage gas pressure		
24.01.12	15.40	24.01.12	17.30	Machine tripped while normalizing the supply from 20 MVA Tx		
25.01.12	18.20	27.01.12	12.35	Machine Stopped due to low demand & high frequency		
27.01.12	15.02	31.01.12	23.59	Machine Stopped due to low demand & high frequency		

(C)

PRAGATI STATION

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	104	01.04.11	23.28	03.04.11	11.37	Stopped for maintenance work
		03.04.11	20.03	04.04.11	19.09	Rotor earth fault
		04.04.11	14.45	06.04.11	13.35	Unit stopped due to low demand and high frequency
		06.04.11	21.45	08.04.11	08.01	Stopped for maintenance work
		08.04.11	18.45	08.04.11	24.00	Internal fault
		09.04.11	00.00	10.04.11	15.52	Unit stopped due to low demand and high frequency
		25.04.11	17.58	25.04.11	23.08	Tripped alongwith trippings of associated transmission lines.
		21.05.11	01.30	21.05.11	02.56	Grid disturbance
		21.05.11	22.10	23.05.11	08.45	Generation backing down due to low demand and high frequency
		05.06.11	11.02	05.06.11	17.43	Shutdown for attending hot spot and general maintenance
		28.07.11	21.18	29.07.11	22.59	Leakage of air compressor
		02.11.11	00.00	02.11.11	05.58	Inspection of boiler
2	104	03.04.11	13.50	03.04.11	20.28	Stopped for maintenance work
		06.04.11	13.50	06.04.11	21.35	Stopped for maintenance work
		08.04.11	08.22	08.04.11	19.20	Stopped for maintenance work
		10.04.11	21.27	11.04.11	12.11	Internal fault
		30.04.11	00.52	30.04.11	01.10	Tripped alongwith trippings of associated transmission lines.
		05.05.11	10.51	07.05.11	05.26	Internal problem
		14.05.11	07.21	14.05.11	19.13	Internal check
		05.06.11	05.00	05.06.11	10.43	Shutdown for attending hot spot and general maintenance
		10.06.11	05.54	11.06.11	15.44	Generation backing down due to low demand and high frequency
		26.06.11	11.38	27.06.11	10.29	low demand and high frequency
		27.06.11	10.29	27.06.11	10.55	Lube oil system fault
		15.08.11	10.35	16.08.11	07.00	Generation backing down due to low demand and high frequency
		05.09.11	05.39	05.09.11	07.21	Grid disturbance
		05.12.11	22.00	06.12.11	01.07	Electrical fault
		09.12.11	14.05	09.12.11	14.32	Due to heavy jerk
		19.12.11	13.58	19.12.11	17.03	Air filter damage
		30.12.11	10.30	30.12.11	14.04	Replacement of air tube valve
		05.01.12	06.02	05.01.12	08.04	Grid disturbance
07.01.12	22.03	07.01.12	22.21	AVR Fault at generation end		
13.01.12	04.36	13.02.12	16.00	Generation backing down due to low demand and high frequency		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
STG	122	12.04.11	09.00	12.04.11	18.59	High furnace temperature
		25.04.11	17.57	25.04.11	18.56	Tripped alongwith trippings of associated transmission lines.
		21.05.11	01.32	21.05.11	02.53	
		05.06.11	09.50	05.06.11	13.38	Shutdown for attending hot spot and general maintenance
		07.06.11	00.47	13.06.2011	10.19	Internal fault
		05.09.11	09.44	05.09.11	10.28	Internal fault
		19.11.11	09.39	19.11.11	11.16	Internal fault
		05.12.11	22.00	06.12.11	02.18	Electrical fault
		09.12.11	14.05	09.12.11	16.51	
		26.12.11	01.01			Internal fault

(D) BADARPUR THERMAL POWER STATION

Unit	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
1	95	10.06.11	11.04	13.06.11	21.58	Generation backing down due to low demand and high frequency
		26.06.11	09.43	27.06.11	13.07	
		27.06.11	17.26	27.06.11	17.51	Furnaces pressure high
		08.07.11	20.25	12.07.11	15.53	Generation backing down due to low demand and high frequency
		15.07.11	18.11	15.07.11	18.47	Low vacuum
		20.08.11	11.22	20.08.11	12:05	Condenser tube leakage
		01.09.11	23.18	22.09.11	19:24	Planned shutdown
		23.09.11	02.09	23.09.11	18.54	Problem in coal mill
		25.09.11	13.26	25.09.11	14.20	Fire out
		03.10.11	21.06	03.10.11	22.26	Flame failure in furnance
		04.10.11	18.16	05.10.11	07.53	Boiler tube leakage
		05.10.11	19.46	15.10.11	20.30	Furnance vaccume failure
		08.10.11	08.27	08.10.11	09.17	Flame failure
		22.10.11	09.14	22.10.11	10.21	Furnance vaccume low
		30.10.11	00.05	30.10.11	01.17	Fire out
		25.12.11	02.30	27.12.11	01.19	Boiler tube leakage
		02.01.12	17.39	03.01.12	14.25	Boiler tube leakage
		07.01.12	02.38	07.01.12	03.28	
		09.01.12	01.44	03.01.12	03.26	Flame failure
16.01.12	15.05	16.01.12	15.47	False tripping of IO fan		
2	95	03.04.11	00.50	20.04.11	21.35	Shut-down for over-hauling
		21.05.11	23.13	23.05.11	20.52	Generation backing down due to low demand and high frequency
		27.06.11	16.41	02.07.11	17.42	
		11.07.11	14.54	11.07.11	16.37	False relay tripping
		12.09.11	10.34	12.09.11	17.27	Furnace disturbance
		14.09.11	09.46	14.09.11	09.11	Fire out
		10.10.11	11.20	10.10.11	13.56	Flame failure
		17.10.11	12.32	24.10.11	21.20	Water shortage
		24.10.11	21.35	24.10.11	22.00	Flame failure
		13.11.11	17.35	13.11.11	19.19	Grid disturbance
20.12.11	08.12	20.12.11	09.33	Vacuum pressure low		
3	95	17.04.11	17.01	17.04.11	18.58	Tripped along with tripping of associated transmission lines
		30.04.11	18.32	30.04.11	19.32	Due to tripping of generator transformer
		30.04.11	21.52	02.05.11	05.42	Electrical fault
		26.05.11	17.13	30.05.11	10.24	Generation backing down due to low demand and high frequency
		02.06.11	19.41	06.06.11	11.43	
		07.07.11	01.47	26.07.11	15.35	Turbine blade failure
		09.08.11	03.24	10.08.11	04.11	Generator failure
		02.10.11	21.56	02.10.11	23.10	Flame failure
		06.10.11	00.58	06.10.11	03.10	Flame failure
		11.10.11	20.16	11.10.11	21.07	Furnance fire out
		13.10.11	07.07	14.10.11	04.42	Boiler tube leakage
		15.10.11	01.12	25.10.11	18.27	Boiler tube leakage
		25.10.11	05.12	27.10.11	02.18	Water shortage
		20.11.11	14.11	21.11.11	07.23	Boiler tube leakage
25.11.11	05.33	26.11.11	09.50	Economizer tube leakage		
26.12.11	16.29	27.12.11	10.55	Boiler tube leakage		

Unit No	Capacity in MW	Outage		Synchronization		Reason of Outage
		Date	Time	Date	Time	
4	210	17.04.11	17.01	17.04.10	20.26	Tripped along with tripping of associated transmission lines
		04.05.11	07.41	08.05.11	11.18	Control system failure
		24.06.11	13.07	24.06.11	16.16	Excitation system failure
		22.08.11	06.59	24.08.11	08.40	Shortage of water
		11.09.11	19.38	13.09.11	16.19	Low furnace pressure
		16.09.11	05.21	16.09.11	07.28	Flame failure
		16.09.11	10.25	16.09.11	11.40	Flame failure
		11.10.11	07.10	11.10.11	08.55	Flame failure
		11.10.11	20.16	11.10.11	12.30	Flame failure
		27.10.11	13.05	31.10.11	23.59	Furnace vacuum low
		30.11.11	03.05	22.12.11	20.18	Annual maintenance
		23.12.11	01.30	24.12.11	19.10	Boiler tube leakage
5	210	17.06.11	17.47	21.06.11	10.10	Generation backing down due to low demand and high frequency
		21.06.11	11.41	21.06.11	13.04	Furnaces vacuum high
		22.06.11	01.09	22.06.11	04.55	Furnaces vacuum high
		22.06.11	05.07	22.06.11	08.15	Unit auxiliary transformer problem
		12.07.11	13.59	13.07.11	08.05	Hot spot on generation bus
		14.08.11	10.35	17.08.11	08.37	Generation backing down due to low demand and high frequency
		14.09.11	10.45	14.09.11	13.28	Flame failure
		16.09.11	13.50	16.09.11	15.15	Flame failure
		16.09.11	19.33	16.09.11	20.42	Flame failure
		17.09.11	07.52	17.09.11	13.47	Fire out
		19.10.11	11.16	29.10.11	16.45	Water shortage
		26.11.11	00.22	27.11.11	02.27	Boiler tube leakage
26.12.11	19.05	28.12.11	09.42	Furnace failure		

4

ALLOCATION OF POWER TO DELHI

A)

Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 22.05.2011**Time block 00.00hrs. to 12.00hrs. & 23.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota**

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
<u>NPC</u>							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	0	0	89
Total	15676	1766	2873	2537	0	0	2537
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	231	201	0	0	201
Grand Total	22386	1957	3393	2980	0	0	2980

B) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 22.05.2011

Time block 12.00hrs. to 23.00hrs. @ 16% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	39	34	165
Rihand	1000	150	100	87	20	17	104
Rihand Stage -II	1000	150	126	109	20	17	127
ANTA GPS	419	63	44	41	8	8	49
Auriya GPS	663.36	99	72	67	9	9	76
Dadri GPS	829.78	129	91	85	8	7	92
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	19	17	655
Unchahaar-I TPS	420	20	24	21	3	2	23
Unchahaar-II TPS	420	63	47	41	8	7	48
Unchahaar-III TPS	210	31	29	25	4	4	29
TOTAL	8782	1152	2174	1902	138	122	2023
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	7	7	45
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	2	2	17
Dhauri Ganga HEP	280	42	37	35	6	5	40
Koteshwar HEP	100	0	10	9	1	1	11
Dulhasti HEP	390	58	50	48	8	7	55
TOTAL	3174	172	361	343	24	23	365
<u>NPC</u>							
Narora APS	440	64	47	41	8	7	48
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	14	12	61
TOTAL	1320	194	103	89	23	20	109
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	20	19	142
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	13	12	102
Total	15776	1766	2882	2547	217	195	2741
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	231	201	5	4	205
Grand Total	22486	1957	3403	2989	222	199	3188

C) **Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 07.10.2011**

Time block 00.00hrs. to 12.00hrs. & 23.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
NTPC STATIONS							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
NHPC							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
NPC							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
SVJNL							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
THDC							
Tehri Hydro	1000	99	103	89	0	0	89
Total	15676	1766	2873	2537	0	0	2537
Allocation from ER and Tala HEP							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
Joint Venture							
Jhajjar TPS	500	38	0	0	0	0	0
Grand Total	22386	1957	3162	2779	0	0	2779

D) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 07.10.2011

Time block 12.00hrs. to 23.00hrs. @ 16% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	39	34	164
Rihand	1000	150	100	87	20	17	104
Rihand Stage -II	1000	150	126	109	20	17	126
ANTA GPS	419	63	44	41	8	8	49
Auriya GPS	663.36	99	72	67	9	8	75
Dadri GPS	829.78	129	91	85	8	7	92
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	19	17	655
Unchahaar-I TPS	420	20	24	21	3	2	23
Unchahaar-II TPS	420	63	47	41	8	7	48
Unchahaar-III TPS	210	31	29	25	4	4	29
TOTAL	8782	1152	2174	1902	137	121	2022
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	7	7	45
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	2	2	17
Dhauri Ganga HEP	280	42	37	35	5	5	40
Koteshwar HEP	100	0	10	9	1	1	11
Dulhasti HEP	390	58	50	48	8	7	55
TOTAL	3174	172	361	343	24	23	365
<u>NPC</u>							
Narora APS	440	64	47	41	8	7	48
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	9	7	56
TOTAL	1320	194	103	89	17	15	104
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	20	19	142
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	13	12	102
Total	15776	1766	2882	2547	211	189	2736
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	0	0	5	4	4
Grand Total	22486	1957	3172	2788	216	193	2982

E) Allocation of power to Delhi from Unallocated quota of Central Sector Generating Stations to Delhi w.e.f. 04.11.2011

Time block 00.00hrs. to 24.00hrs. @ 0% allocation from Unallocated Quota

Name of the Stn	Installed capacity	Total Un-allocated	Basic Allocation	Basic Allocation at periphery	Allocation out of Unallocated Quota	Allocation out of Un-allocated Quota at Delhi periphery	Total allocation at Delhi periphery
1	2	3	4	5	6	7	(8)=(5)+(7)
<u>NTPC STATIONS</u>							
Singrauli STPS	2000	300	150	130	0	0	130
Rihand	1000	150	100	87	0	0	87
Rihand Stage -II	1000	150	126	109	0	0	109
ANTA GPS	419	63	44	41	0	0	41
Auriya GPS	663.36	99	72	67	0	0	67
Dadri GPS	829.78	129	91	85	0	0	85
Dadri NCTPS (Th)	840	0	756	657	0	0	657
Dadri NCTPS (Th) Stage-II	980	147	735	639	0	0	639
Unchahaar-I TPS	420	20	24	21	0	0	21
Unchahaar-II TPS	420	63	47	41	0	0	41
Unchahaar-III TPS	210	31	29	25	0	0	25
TOTAL	8782	1152	2174	1902	0	0	1902
<u>NHPC</u>							
Baira Suil HPS	180	0	20	19	0	0	19
Salal HPS	690	0	80	76	0	0	76
Tanakpur HEP	94	0	12	11	0	0	11
Chamera HEP	540	0	43	41	0	0	41
Chamera-II HEP	300	54	40	38	0	0	38
URI HEP	480	0	53	50	0	0	50
Sewa HEP	120	18	16	15	0	0	15
Dhauri Ganga HEP	280	42	37	35	0	0	35
Dulhasti HEP	390	58	50	48	0	0	48
TOTAL	3074	172	351	333	0	0	333
<u>NPC</u>							
Narora APS	440	64	47	41	0	0	41
RAPP(B)	440	66	0	0	0	0	0
RAPP (C)	440	64	56	49	0	0	49
TOTAL	1320	194	103	89	0	0	89
<u>SVJNL</u>							
Nathpa Jhakri HEP	1500	149	142	123	0	0	123
<u>THDC</u>							
Tehri Hydro	1000	99	103	89	0	0	89
Koteshwar HEP	200	0	20	19	0	0	19
TOTAL	1200	99	123	108	0	0	108
Total	15876	1766	2892	2556	0	0	2556
<u>Allocation from ER and Tala HEP</u>							
Farakka	1600	0	22	19	0	0	19
Kahalgaon	840	0	51	43	0	0	43
Talchar	1000	0	0	0	0	0	0
Tala HEP	1020	153	30	25	0	0	25
Mejia TPS Unit-6	250	0	29	25	0	0	25
Kahalgaon-II	1500	0	157	131	0	0	131
Total ER	6210	153	290	242	0	0	242
<u>Joint Venture</u>							
Jhajjar TPS	500	38	0	0	0	0	0
Grand Total	22586	1957	3182	2798	0	0	2798

5 ALLOCATION OF POWER TO DISCOMS

ALLOCATION OF POWER TO VARIOUS LICENCEES AS PER ORDER OF DERC AND DECISION OF GNCTD FOR ALLOCATION OF CENTRAL SECTOR STATIONS (DADRI THERMAL & BTPS) AND STATE SECTOR GENERATING STATIONS w.e.f. 01.04.2011.

(Allocation In %)

(A) 10.00hrs. to 17.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.98	0.00	24.18	36.87	23.97	100.00
3. BTPS	15.94	7.09	21.88	33.37	21.72	100.00
4. RPH	0.85	0.00	28.39	42.97	27.79	100.00
5. GT	0.93	0.00	28.28	42.99	27.80	100.00
6. Pragati	26.69	0.00	20.77	31.76	20.7	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00

(B) 00.00hrs. to 10.00hrs. and 17.00hrs. to 24.00hrs.

SOURCES	LICENSEES					
	NDMC	MES	NDPL	BRPL	BYPL	TOTAL
1. Central Sector without Dadri (Th)	0.00	0.00	29.18	43.58	27.24	100.00
2. Dadri (Th)	14.05	0.00	24.18	36.87	24.90	100.00
3. BTPS	15.07	7.09	21.88	33.37	22.59	100.00
4. RPH	0.00	0.00	28.39	42.97	28.64	100.00
5. GT	0.00	0.00	28.28	42.99	28.73	100.00
6. Pragati	25.76	0.00	20.77	31.76	21.71	100.00
7. DVC	0.00	0.00	29.18	43.58	27.24	100.00

6 POWER AVAILABILITY-DEMAND POSITION AT THE TIME OF PEAK DEMAND MET DURING JANUARY 2012

All figures in MW

Date	Time of peak demand	Generation within Delhi							Import from the Grid	Schedule from the Grid	OD(-) / UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	BTPS	Rithala	Bawana	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)
1	11:00:51	93	158	310	561	20	167	1309	1959	2007	48	3268	0	3268
2	10:03:44	94	201	315	606	22	0	1238	2257	2307	50	3495	0	3495
3	10:19:38	95	201	312	511	22	0	1141	2421	2481	60	3562	0	3562
4	10:22:05	95	201	307	621	20	0	1244	2246	2520	274	3490	0	3490
5	19:40:11	48	200	313	466	30	0	1057	2260	2126	-134	3317	0	3317
6	10:41:33	48	201	307	465	17	0	1038	2655	2439	-216	3693	0	3693
7	10:01:16	49	197	314	483	0	0	1043	2380	2457	77	3423	0	3423
8	10:03:56	51	161	314	599	15	0	1140	2254	2322	68	3394	3	3397
9	10:03:42	51	198	312	581	15	40	1197	2493	2359	-134	3690	0	3690
10	10:02:23	52	195	320	623	15	182	1387	2350	2463	113	3737	0	3737
11	10:31:57	50	200	318	618	15	186	1387	2363	2370	7	3750	74	3824
12	10:37:21	49	239	317	408	15	185	1213	2489	2001	-488	3702	176	3878
13	08:53:52	52	189	324	327	15	132	1039	2811	2687	-124	3850	11	3861
14	09:53:59	53	233	316	594	15	139	1350	2264	2598	334	3614	1	3615
15	10:28:03	54	159	309	595	15	146	1278	2088	2385	297	3366	1	3367
16	08:55:18	53	78	308	555	15	149	1158	2147	2479	332	3305	0	3305
17	10:15:34	53	79	319	597	15	136	1199	2283	2499	216	3482	40	3522
18	10:16:16	54	110	321	623	19	137	1264	2396	2318	-78	3660	0	3660
19	09:50:40	52	201	323	610	19	132	1337	2354	2442	88	3691	0	3691
20	10:01:16	58	190	323	610	19	59	1259	2675	2416	-259	3934	0	3934
21	09:47:42	54	203	317	621	15	141	1351	2354	2473	119	3705	0	3705
22	11:03:45	106	125	319	621	19	145	1335	2413	2432	19	3748	2	3750
23	09:48:51	112	192	317	625	19	189	1454	2203	2692	489	3657	0	3657
24	09:31:51	56	202	314	620	19	0	1211	2529	2528	-1	3740	2	3742
25	10:06:18	55	200	314	583	19	0	1171	2478	2593	115	3649	0	3649
26	09:02:45	56	115	316	620	19	0	1126	1968	3254	1286	3094	0	3094
27	10:21:20	102	190	312	632	19	0	1255	2333	2619	286	3588	0	3588
28	10:03:21	101	121	316	587	19	0	1144	2302	2591	289	3446	0	3446
29	10:28:06	100	76	315	550	19	0	1060	2400	2520	120	3460	0	3460
30	9:57:43	99	75	318	592	19	0	1103	2404	2667	263	3507	13	3520
31	9:45:28	98	76	319	556	19	0	1068	2432	2560	128	3500	0	3500

POWER AVAILABILITY- DEMAND POSITION AT THE TIME OF MAXIMUM UNRESTRICTED DEMAND DURING JANUARY 2012

Date	Time of peak demand	Generation within Delhi							Import from the Grid	Schedule from the Grid	OD(-) / UD(+)	Demand met	Shedding	Un-Restricted Demand
		RPH	GT	PPCL	BTPS	Rithala	Bawana	Total						
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)= (3) to (8)	(10)	(11)	(12)= (11) - (10)	(13)= (11)+ (12)	(14)	(15)= (13)+ (14)
1	11:00:51	93	158	310	561	20	167	1309	1959	2007	48	3268	0	3268
2	10:03:44	94	201	315	606	22	0	1238	2257	2307	50	3495	0	3495
3	10:19:38	95	201	312	511	22	0	1141	2421	2481	60	3562	0	3562
4	10:22:05	95	201	307	621	20	0	1244	2246	2520	274	3490	0	3490
5	19:40:11	48	200	313	466	30	0	1057	2260	2126	-134	3317	0	3317
6	10:41:33	48	201	307	465	17	0	1038	2655	2439	-216	3693	0	3693
7	10:01:16	49	197	314	483	0	0	1043	2380	2457	77	3423	0	3423
8	10:03:56	51	161	314	599	15	0	1140	2254	2322	68	3394	3	3397
9	10:03:42	51	198	312	581	15	40	1197	2493	2359	-134	3690	0	3690
10	10:02:23	52	195	320	623	15	182	1387	2350	2463	113	3737	0	3737
11	10:31:57	50	200	318	618	15	186	1387	2363	2370	7	3750	74	3824
12	10:37:21	49	239	317	408	15	185	1213	2489	2001	-488	3702	176	3878
13	08:53:52	52	189	324	327	15	132	1039	2811	2687	-124	3850	11	3861
14	09:53:59	53	233	316	594	15	139	1350	2264	2598	334	3614	1	3615
15	10:28:03	54	159	309	595	15	146	1278	2088	2385	297	3366	1	3367
16	08:55:18	53	78	308	555	15	149	1158	2147	2479	332	3305	0	3305
17	10:15:34	53	79	319	597	15	136	1199	2283	2499	216	3482	40	3522
18	10:16:16	54	110	321	623	19	137	1264	2396	2318	-78	3660	0	3660
19	09:50:40	52	201	323	610	19	132	1337	2354	2442	88	3691	0	3691
20	10:01:16	58	190	323	610	19	59	1259	2675	2416	-259	3934	0	3934
21	09:47:42	54	203	317	621	15	141	1351	2354	2473	119	3705	0	3705
22	11:03:45	106	125	319	621	19	145	1335	2413	2432	19	3748	2	3750
23	09:48:51	112	192	317	625	19	189	1454	2203	2692	489	3657	0	3657
24	09:31:51	56	202	314	620	19	0	1211	2529	2528	-1	3740	2	3742
25	10:06:18	55	200	314	583	19	0	1171	2478	2593	115	3649	0	3649
26	09:02:45	56	115	316	620	19	0	1126	1968	3254	1286	3094	0	3094
27	10:21:20	102	190	312	632	19	0	1255	2333	2619	286	3588	0	3588
28	10:03:21	101	121	316	587	19	0	1144	2302	2591	289	3446	0	3446
29	10:28:06	100	76	315	550	19	0	1060	2400	2520	120	3460	0	3460
30	9:57:43	99	75	318	592	19	0	1103	2404	2667	263	3507	13	3520
31	9:45:28	98	76	319	556	19	0	1068	2432	2560	128	3500	0	3500

SOURCEWISE SCHEDULED DRAWL FROM NORTHERN GRID AS WELL AS AVAILABILITY WITHIN DELHI FOR JANUARY 2012

A) AVAILABILITY FROM GENCO AND PRAGATI STNs. (all fig in MUs)

A (i) RPH	55.234
(ii) GT+STG	117.983
(iii) PRAGATI	229.268
(iv) RITHALA	13.302
(v) BAWANA CCGT	52.768
TOTAL	468.555
B) AVAILABILITY FROM BTPS	409.177
C) AUXILIARY CONSUMPTION OF GENERATING STNs. EXCLUDING BTPS	17.020
D) NET GENERATION AVAILABLE WITHIN DELHI(A+B-C)	860.712

B) SOURCE WISE SCHEDULED DRAWL FROM THE NORTHERN GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
B/SUIL	1.884	1.785	1.884	1.785
SALAL	10.751	10.183	10.751	10.183
TANKAPUR	1.567	1.484	1.567	1.484
CHAMERA	2.726	2.592	2.726	2.592
CHAMERA -II	4.976	4.712	4.976	4.712
DHAULIGANGA	3.938	3.729	3.938	3.729
SEWA -2	2.293	2.174	2.293	2.174
URI	8.728	8.270	8.728	8.270
KOTESHWAR	8.005	7.579	8.005	7.579
ANTA (GAS)	19.372	18.349	13.627	12.908
ANTA (RLNG)	13.918	13.177	2.063	1.949
ANTA (LIQUID)	0.104	0.099	0.000	0.000
DADRI (GAS)	41.729	39.522	30.901	29.267
DADRI (RLNG)	26.047	24.664	3.102	2.931
DADRI (LIQUID)	0.099	0.094	0.000	0.000
AURAIYA (GAS)	23.222	21.992	16.751	15.863
AURAIYA (RLNG)	20.024	18.963	1.958	1.850
AURAIYA (LIQUID)	9.610	9.104	0.155	0.147
SINGRAULI	100.596	95.255	97.300	92.131
RIHAND -I	59.729	56.568	54.199	51.325
RIHAND -II	91.514	86.667	83.758	79.312
UNCHAHAR-I	16.221	15.364	13.723	12.997
UNCHAHAR-II	31.906	30.219	27.312	25.867
UNCHAHAR-III	19.694	18.653	16.747	15.861
DADRI (TH)	525.243	497.407	455.086	430.974
DADRI (TH) STAGE-II	428.647	405.833	403.561	382.139
NAPP	15.376	14.546	15.376	14.546
RAPP 'B'	0.000	0.000	0.000	0.000
RAPP 'C'	39.652	37.552	39.652	37.552
NATHPA JHAKRI	19.662	18.617	5.737	5.433
DULASTI	7.928	7.509	7.928	7.509
TEHRI	25.796	24.429	25.796	24.429
JHAJJAR	0.000	0.000	0.000	0.000
KHELGAON	22.771	21.558	19.957	18.896
KHELGAON-II	92.156	87.280	84.302	79.841
FARAKA	15.001	14.207	11.590	10.974
TALA	1.950	1.845	1.950	1.845
TALCHER	0.000	0.000	0.000	0.000
DVC	122.514	121.205	121.205	114.939
CHATTISHGARH	0.000	0.000	0.000	0.000
ANDHRA	0.000	0.000	0.000	0.000
DVC TATA STEEL (NDPL)	112.503	111.294	111.294	105.426
ORISSA	0.000	0.000	0.000	0.000
KERALA	0.000	0.000	0.000	0.000
HIMACHAL PRADESH	0.000	0.000	0.000	0.000
WEST BENGAL	0.000	0.000	0.000	0.000

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
MADHYA PRADESH(WR)	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR-ER)	0.000	0.000	0.000	0.000
NAGALAND	0.000	0.000	0.000	0.000
UTTRANCHAL	0.000	0.000	0.000	0.000
GOA	0.000	0.000	0.000	0.000
MAHARASHTRA	0.000	0.000	0.000	0.000
MEGHALAYA	0.000	0.000	0.000	0.000
RAJASTHAN	0.000	0.000	0.000	0.000
TO ANDHRA	0.000	0.000	0.000	0.000
TO MADHYA PRADESH	-74.728	-75.902	-75.902	-80.148
TO JAMMU & KASHMIR	-44.771	-45.935	-45.935	-48.508
TO MAHARASHTRA	-0.057	-0.058	-0.058	-0.062
TO RAJASTHAN	-46.928	-48.146	-48.146	-50.839
TO HIMACHAL PRADESH	-34.875	-35.780	-35.780	-37.782
TO KERALA(ER)	0.000	0.000	0.000	0.000
TO UTTRANCHAL	0.000	0.000	0.000	0.000
POWER EXCHANGE(IEX)	2.451	2.312	2.451	2.312
TO POWER EXCHANGE (IEX)	-126.636	-133.668	-126.636	-133.668
POWRER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TO POWER EXCHANGE (PX)	-7.938	-8.375	-7.938	-8.375
TO SHARE PROJECT (HARYANA)	-6.182	-6.536	-6.182	-6.536
TO SHARE PROJECT (PUNJAB)	-2.750	-2.910	-2.750	-2.910
TOTAL	1605.438	1499.482	1363.023	1252.904

C) AGENCY WISE BREAKUP OF ENERGY SCHEDULED DRAWL FROM THE GRID

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT DELHI PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT DELHI PERIPHERY
NTPC - NR	1427.675	1351.931	1220.243	1155.523
NTPC - ER	129.928	123.045	115.849	109.711
NHPC	44.791	42.437	44.791	42.437
NPC	55.028	52.098	55.028	52.098
KOTESHWAR	8.005	7.579	8.005	7.579
NATHPA JHAKRI	19.662	18.617	5.737	5.433
TEHRI	25.796	24.429	25.796	24.429
TALA	1.950	1.845	1.950	1.845
JHAJJAR	0.000	0.000	0.000	0.000
TALCHER	0.000	0.000	0.000	0.000
DVC	122.514	121.205	121.205	114.939
CHATTISHGARH	0.000	0.000	0.000	0.000
ANDHRA	0.000	0.000	0.000	0.000
DVC TATA STEEL (NDPL)	112.503	111.294	111.294	105.426
ORISSA	0.000	0.000	0.000	0.000
KERALA	0.000	0.000	0.000	0.000
HIMACHAL PRADESH	0.000	0.000	0.000	0.000
WEST BENGAL	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR)	0.000	0.000	0.000	0.000
MADHYA PRADESH(WR-ER)	0.000	0.000	0.000	0.000
NAGALAND	0.000	0.000	0.000	0.000
UTTRANCHAL	0.000	0.000	0.000	0.000
GOA	0.000	0.000	0.000	0.000
MAHARASHTRA	0.000	0.000	0.000	0.000
MEGHALAYA	0.000	0.000	0.000	0.000
RAJASTHAN	0.000	0.000	0.000	0.000
POWER EXCHANGE(IEX)	2.451	2.312	2.451	2.312
POWER EXCHANGE(PX)	0.000	0.000	0.000	0.000
TOTAL	1950.302	1856.792	1712.349	1621.732

D) AGENCY WISE BREAKUP OF ENERGY SCHEDULED BY NRLDC FOR EXPORT TO OTHER UTILITIES FROM DTL

NAME OF THE STATION	AVAILABILITY AT POWER PLANT	AVAILABILITY AT PERIPHERY	ALLOCATION MADE BY NRLDC AT POWER PLANT	ALLOCATION MADE BY NRLDC AT POWER PERIPHERY
TO MADHYA PRADESH	-74.728	-75.902	-75.902	-80.148
TO ANDHRA	0.000	0.000	0.000	0.000
TO JAMMU & KASHMIR	-44.771	-45.935	-45.935	-48.508
TO MAHARASHTRA	-0.057	-0.058	-0.058	-0.062
TO RAJASTHAN	-46.928	-48.146	-48.146	-50.839
TO HIMACHAL PRADESH	-34.875	-35.780	-35.780	-37.782
TO KERALA(ER)	0.000	0.000	0.000	0.000
TO UTTANCHAL	0.000	0.000	0.000	0.000
TO POWER EXCHANGE (IEX)	-126.636	-133.668	-126.636	-133.668
TO POWER EXCHANGE (PX)	-7.938	-8.375	-7.938	-8.375
TO SHARE PROJECT (HARYANA)	-6.182	-6.536	-6.182	-6.536
TO SHARE PROJECT (PUNJAB)	-2.750	-2.910	-2.750	-2.910
TOTAL	-344.865	-357.310	-349.326	-368.828
TOTAL SCHEDULED DRAWAL FROM THE GRID	1605.438	1499.482	1363.023	1252.904
TOTAL CONSUMPTION INCLUDING AUX. OF GENERATING STNs. EXCLUDING BTPS				1933.818
NET CONSUMPTION				1916.798
AVAILABILITY WITHIN DELHI				860.712
ACTUAL DRAWAL FROM THE GRID				1056.086
OVER DRAWAL(+)/UNDER DRAWAL(-) FROM THE GRID ON THE BASIS OF SCHEDULED ALLOCATION MADE BY NRLDC TO DELHI AT PERIPHERY				-196.818
LOAD SHEDDING				7.622
UNRESTRICTED DEMAND (GROSS)				1941.440
UNRESTRICTED DEMAND (NET)				1924.420
MAX. NET CONSUMPTION				69.264Mus. ON 19.01.2012
MAX. LOAD SHEDDING				556W ON 05.01.2012 AT 08.30HRS.
PEAK LOAD	Peak Demand during the month			SCHEDDING AT PEAK TIME
DAY PEAK	3934MW AT 10.01.16HRS ON 20.01.2012			NIL
EVENING PEAK	3527MW AT 19.00.00HRS ON 20.01.2012			NIL
P.L.F. OF GENCO AND PRAGATI STNs.	RPH			54.99%
	GT			58.73%
	PRAGATI			93.38%
	RITHALA			16.55%
	BAWANA			32.21%

SHEDDING DETAILS DURING THE MONTH OF JANUARY 2012.

ALL FIGURES IN MUs

DATE	No. of Under Freq. Relay Operated	Shedding due to under frequency relay operation in MUs					Shedding due to Grid Restrictions (Over drawal / low freq.)			
		BSES		NDPL	NDMC	TOTAL	BSES		NDPL	NDMC
		BYPL	BRPL				BYPL	BRPL		
1	2	3	4	5	6	7=3 to 6	8	9	10	11
01-Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02- Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03- Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
04- Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05- Jan -12	3	0.020	0.001	0.000	0.000	0.021	0.000	0.000	0.000	0.000
06 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000	0.000
07 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
08 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
09 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
11 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.094	0.089	0.000
12 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.717	0.816	0.131	0.000
13 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.101	0.030	0.000	0.000
14 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
16 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
17 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
19 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
20 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.034	0.235	0.036	0.000
21 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
22- Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
27 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31 - Jan -12	0	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Total	3	0.020	0.001	0.000	0.000	0.021	0.859	1.175	0.256	0.000

ALL FIGURES IN MUs

Date	Shedding due to Transmission/Grid Constraints in Central Sector Stations / TTC / ATC VOILATION				TOTAL	TOTAL SHEDDING DUE TO GRID RESTRICTIONS	Due to T&D Constraints				
	BSES		NDPL	NDMC			DTL				
	BYPL	BRPL					BSES		NDPL	NDMC	MES
			BYPL	BRPL							
1	12	13	14	15	16=8to15	17=16+7	18	19	20	21	22
01-Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
02- Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
03- Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.000
04- Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
05- Jan -12	0.000	0.000	0.000	0.000	0.000	0.021	0.723	0.122	1.239	0.000	0.000
06 - Jan -12	0.000	0.000	0.000	0.000	0.007	0.007	0.000	0.005	0.000	0.000	0.000
07 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.020	0.005	0.000	0.000
08 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.009	0.000	0.000	0.000
09 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
10 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.007	0.008	0.000	0.000	0.000
11 - Jan -12	0.000	0.000	0.000	0.000	0.183	0.183	0.000	0.000	0.000	0.000	0.000
12 - Jan -12	0.000	0.000	0.000	0.000	1.664	1.664	0.000	0.000	0.000	0.000	0.000
13 - Jan -12	0.000	0.000	0.000	0.000	0.131	0.131	0.000	0.000	0.000	0.000	0.000
14 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
15 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000	0.000	0.000
16 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000
17 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
18 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.017	0.000	0.000
19 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.005	0.000	0.000
20 - Jan -12	0.000	0.000	0.000	0.000	0.305	0.305	0.000	0.078	0.013	0.000	0.000
21 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.021	0.000	0.000
22- Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
23 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
24 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
25 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
26 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.006	0.000	0.000	0.000	0.000
27 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
28 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
29 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
30 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
31 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Total	0.000	0.000	0.000	0.000	2.290	2.311	0.737	0.244	1.307	0.000	0.000

ALL FIGURES IN MUs


DATE	DUE TO T&D CONSTRAINTS				OTHER AGENCIES LIKE GENCO, BBMB, BTPS ETC.	THEFT PRONE SHEDDING			TOTAL SHEDDING DUE TO T&D CONSTS. & THEFT PRONE	GRAND TOTAL
	DISCOMS					BSES		NDPL		
	BSES		NDPL	NDMC		BYPL	BRPL			
	BYPL	BRPL								
1	23	24	25	26	27	28	29	30=18 to29	31=30+17	
01-Jan -12	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.065	0.070	0.070
02- Jan -12	0.000	0.000	0.014	0.000	0.000	0.000	0.000	0.071	0.085	0.085
03- Jan -12	0.000	0.016	0.008	0.000	0.000	0.000	0.000	0.079	0.105	0.105
04- Jan -12	0.002	0.034	0.002	0.000	0.000	0.000	0.000	0.090	0.128	0.128
05- Jan -12	0.013	0.023	0.100	0.000	0.000	0.000	0.000	0.016	2.236	2.257
06 - Jan -12	0.006	0.011	0.003	0.000	0.000	0.000	0.000	0.045	0.070	0.077
07 - Jan -12	0.000	0.025	0.014	0.000	0.000	0.000	0.000	0.028	0.092	0.092
08 - Jan -12	0.000	0.009	0.006	0.000	0.000	0.000	0.000	0.078	0.102	0.102
09 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.087	0.087	0.087
10 - Jan -12	0.009	0.004	0.000	0.000	0.000	0.000	0.000	0.087	0.115	0.115
11 - Jan -12	0.002	0.000	0.001	0.000	0.000	0.000	0.000	0.000	0.003	0.186
12 - Jan -12	0.000	0.000	0.002	0.000	0.013	0.000	0.000	0.088	0.103	1.767
13 - Jan -12	0.007	0.000	0.000	0.000	0.000	0.000	0.000	0.091	0.098	0.229
14 - Jan -12	0.000	0.000	0.033	0.000	0.000	0.000	0.000	0.097	0.130	0.130
15 - Jan -12	0.000	0.000	0.006	0.000	0.000	0.000	0.000	0.079	0.086	0.086
16 - Jan -12	0.000	0.000	0.008	0.000	0.000	0.000	0.000	0.042	0.057	0.057
17 - Jan -12	0.000	0.126	0.001	0.000	0.000	0.000	0.000	0.095	0.222	0.222
18 - Jan -12	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.093	0.115	0.115
19 - Jan -12	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.098	0.104	0.104
20 - Jan -12	0.005	0.000	0.001	0.000	0.031	0.000	0.000	0.095	0.223	0.528
21 - Jan -12	0.000	0.000	0.000	0.000	0.002	0.000	0.000	0.093	0.116	0.116
22 - Jan -12	0.000	0.003	0.000	0.000	0.000	0.000	0.000	0.101	0.104	0.104
23 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.107	0.107	0.107
24 - Jan -12	0.000	0.000	0.018	0.000	0.000	0.000	0.000	0.105	0.123	0.123
25 - Jan -12	0.000	0.000	0.001	0.000	0.000	0.000	0.000	0.089	0.090	0.090
26 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.006	0.006
27 - Jan -12	0.000	0.000	0.004	0.000	0.000	0.000	0.000	0.087	0.091	0.091
28 - Jan -12	0.000	0.000	0.040	0.000	0.000	0.000	0.000	0.091	0.131	0.131
29 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.097	0.097	0.097
30 - Jan -12	0.000	0.012	0.020	0.000	0.000	0.000	0.000	0.090	0.122	0.122
31 - Jan -12	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.093	0.093	0.093
Total	0.044	0.268	0.288	0.000	0.046	0.000	0.000	2.377	5.311	7.622

DATE	(NET CONS.)	MAXL DEMAND MET DURING THE DAY	TIME OF OCCURRENCE OF MAX DEMAND	SHEDDING AT THIS TIME	UN-RESTRICTED DEMAND	MAXIMUM UN-RESTRICTED DEMAND DURING THE DAY	TIME OF MAX. UN-REST. DEMAND	DEMAND AT THAT TIME	SHEDDING AT THAT TIME
	In Mus.	IN MW	IN HRS.	IN MW	IN MW	IN MW	HRS.	IN MW	IN MW
1	32	33	34	35	36=33+35	37=39+40	38	39	40
01-Jan-12	59.549	3268	11:00:51	0	3268	3268	11:00:51	3268	0
02- Jan-12	58.543	3495	10:03:44	0	3495	3495	10:03:44	3495	0
03- Jan-12	58.871	3562	10:19:38	0	3562	3562	10:19:38	3562	0
04- Jan-12	60.413	3490	10:22:05	0	3490	3490	10:22:05	3490	0
05- Jan-12	55.184	3317	19:40:11	0	3317	3317	19:40:11	3317	0
06 - Jan-12	60.605	3693	10:41:33	0	3693	3693	10:41:33	3693	0
07 - Jan-12	58.231	3423	10:01:16	0	3423	3423	10:01:16	3423	0
08 - Jan-12	57.657	3394	10:03:56	3	3397	3397	10:03:56	3394	3
09 - Jan-12	62.745	3690	10:03:42	0	3690	3690	10:03:42	3690	0
10 - Jan-12	67.378	3737	10:02:23	0	3737	3737	10:02:23	3737	0
11 - Jan-12	67.908	3750	10:31:57	74	3824	3824	10:31:57	3750	74
12 - Jan-12	66.936	3702	10:37:21	176	3878	3878	10:37:21	3702	176
13 - Jan-12	65.418	3850	08:53:52	11	3861	3861	08:53:52	3850	11
14 - Jan-12	62.653	3614	09:53:59	1	3615	3615	09:53:59	3614	1
15 - Jan-12	60.612	3366	10:28:03	1	3367	3367	10:28:03	3366	1
16 - Jan-12	60.866	3305	08:55:18	0	3305	3305	08:55:18	3305	0
17 - Jan-12	65.834	3482	10:15:34	40	3522	3522	10:15:34	3482	40
18 - Jan-12	67.096	3660	10:16:16	0	3660	3660	10:16:16	3660	0
19 - Jan-12	69.264	3691	09:50:40	0	3691	3691	09:50:40	3691	0
20 - Jan-12	69.248	3934	10:01:16	0	3934	3934	10:01:16	3934	0
21 - Jan-12	66.859	3705	09:47:42	0	3705	3705	09:47:42	3705	0
22- Jan-12	65.174	3748	11:03:45	2	3750	3750	11:03:45	3748	2
23 - Jan-12	65.624	3657	09:48:51	0	3657	3657	09:48:51	3657	0
24 - Jan-12	61.776	3740	09:31:51	2	3742	3742	09:31:51	3740	2
25 - Jan-12	61.808	3649	10:06:18	0	3649	3649	10:06:18	3649	0
26 - Jan-12	51.034	3094	09:02:45	0	3094	3094	09:02:45	3094	0
27 - Jan-12	59.567	3588	10:21:20	0	3588	3588	10:21:20	3588	0
28 - Jan-12	58.347	3446	10:03:21	0	3446	3446	10:03:21	3446	0
29 - Jan-12	53.962	3460	10:28:06	0	3460	3460	10:28:06	3460	0
30 - Jan-12	58.517	3507	09:57:43	13	3520	3520	09:57:43	3507	13
31 - Jan-12	59.119	3500	09:45:28	0	3500	3500	09:45:28	3500	0
Total	1916.798	3934 20.01.12	10.01.16	0	3934 20.01.12	3934	10.01.16	3934	0

LOAD PATTERN OF DELHI ON THE DAY OF PEAK DEMAND MET DURING JANUARY 2012 ON 20.01.2012- 3934MW at 10.01.16HRS.

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1695	0	1695
2:00	1602	0	1602
3:00	1553	0	1553
4:00	1551	0	1551
5:00	1720	0	1720
6:00	2380	0	2380
7:00	3205	23	3228
8:00	3566	41	3607
9:00	3700	0	3700
10:00	3894	0	3894
10:01.16	3934	0	3934
11:00	3653	172	3825
12:00	3667	44	3711
13:00	3322	37	3359
14:00	3165	0	3165
15:00	2967	0	2967
16:00	2857	0	2857
17:00	3084	5	3089
18:00	3313	0	3313
19:00	3527	0	3527
20:00	3413	38	3451
21:00	3173	0	3173
22:00	2923	0	2923
23:00	2525	0	2525
24:00	2024	0	2024
ENERGY IN MUS	69.248	0.528	69.776



11 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UN-RESTRICTED DEMAND DURING JANUARY 2012 ON 20.01.2012-3934MW at 10.01.16HRS.

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1695	0	1695
2:00	1602	0	1602
3:00	1553	0	1553
4:00	1551	0	1551
5:00	1720	0	1720
6:00	2380	0	2380
7:00	3205	23	3228
8:00	3566	41	3607
9:00	3700	0	3700
10:00	3894	0	3894
10:01.16	3934	0	3934
11:00	3653	172	3825
12:00	3667	44	3711
13:00	3322	37	3359
14:00	3165	0	3165
15:00	2967	0	2967
16:00	2857	0	2857
17:00	3084	5	3089
18:00	3313	0	3313
19:00	3527	0	3527
20:00	3413	38	3451
21:00	3173	0	3173
22:00	2923	0	2923
23:00	2525	0	2525
24:00	2024	0	2024
ENERGY IN MUS	69.248	0.528	69.776



12 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM ENERGY CONSUMED DURING JANUARY 2012 – 19.01.2012 – 69.264 Mus

All figures in MW


Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1631	0	1631
2:00	1533	0	1533
3:00	1478	0	1478
4:00	1479	0	1479
5:00	1650	0	1650
6:00	2304	0	2304
7:00	3144	18	3162
8:00	3448	47	3495
9:00	3539	1	3540
10:00	3624	0	3624
11:00	3563	0	3563
12:00	3341	0	3341
13:00	3048	0	3048
14:00	2955	0	2955
15:00	2907	0	2907
16:00	2872	0	2872
17:00	2957	5	2962
18:00	3320	0	3320
19:00	3447	35	3482
20:00	3395	19	3414
21:00	3159	0	3159
22:00	2873	0	2873
23:00	2367	0	2367
24:00	1952	0	1952
ENERGY IN MUS	69.264	0.104	69.368



13 LOAD PATTERN OF DELHI ON THE DAY OF MAXIMUM UNRESTRICTED ENERGY DEMAND DURING JANUARY 2012 – 20.01.2012 – 69.776 Mus


All figures in MW

Hrs.	Demand	Load Shedding	Un-Restricted Demand
1:00	1695	0	1695
2:00	1602	0	1602
3:00	1553	0	1553
4:00	1551	0	1551
5:00	1720	0	1720
6:00	2380	0	2380
7:00	3205	23	3228
8:00	3566	41	3607
9:00	3700	0	3700
10:00	3894	0	3894
10:01.16	3934	0	3934
11:00	3653	172	3825
12:00	3667	44	3711
13:00	3322	37	3359
14:00	3165	0	3165
15:00	2967	0	2967
16:00	2857	0	2857
17:00	3084	5	3089
18:00	3313	0	3313
19:00	3527	0	3527
20:00	3413	38	3451
21:00	3173	0	3173
22:00	2923	0	2923
23:00	2525	0	2525
24:00	2024	0	2024
ENERGY IN MUS	69.248	0.528	69.776




14 **LOAD DURATION CURVE FOR JANUARY 2012**

Load in MW	Percentage of Time
Above 1100	100 %
Above 1300	99.3 %
Above 1500	90.93 %
Above 1700	80.78 %
Above 1900	75.64 %
Above 2100	71.88 %
Above 2300	68.41 %
Above 2500	62.8 %
Above 2700	52.03 %
Above 2900	37.48 %
Above 3100	26.3 %
Above 3300	13.93 %
Above 3500	5.18 %
Above 3700	0.65 %
Above 3900	0.01 %



FREQUENCY ANALYSIS FOR THE MONTH OF JANUARY 2012

Frequency Range in Hz.	Percentage of time
Above 49	100 %
Above 49.25	99.88 %
Above 49.5	97.57 %
Above 49.75	77.31 %
Above 50	35.6 %
Above 50.25	6.38 %
Above 50.5	1.04 %
Above 50.75	0.16 %



16 VOLTAGE PROFILE OF 220 KV SUB-STATIONS IN DELHI DURING JANUARY 2012

All figures in kV

Date	NARELA		GAZIPUR	
	Max	Min	Max	Min
01-Jan -12	238.73	225.44	234.34	221.05
02- Jan -12	239.63	218.86	234.98	216.67
03- Jan -12	237.05	217.57	232.66	214.48
04- Jan -12	239.24	219.25	233.82	214.73
05- Jan -12	239.75	--	231.89	217.06
06 - Jan -12	238.59	218.22	235.37	213.19
07 - Jan -12	243.63	--	237.30	217.70
08 - Jan -12	238.85	225.95	235.11	219.76
09 - Jan -12	241.17	219.76	235.11	214.99
10 - Jan -12	--	--	--	--
11 - Jan -12	236.92	218.47	233.82	217.06
12 - Jan -12	238.59	220.41	234.08	216.67
13 - Jan -12	236.92	218.86	231.50	217.06
14 - Jan -12	236.27	219.89	232.66	217.18
15 - Jan -12	240.14	224.79	235.63	218.47
16 - Jan -12	248.01	221.44	239.24	218.60
17 - Jan -12	240.27	225.05	234.60	--
18 - Jan -12	239.63	219.12	235.37	218.35
19 - Jan -12	239.50	220.15	233.69	219.76
20 - Jan -12	238.85	215.38	233.43	216.02
21 - Jan -12	237.95	--	233.43	215.38
22- Jan -12	237.95	222.21	233.43	214.48
23 - Jan -12	241.17	222.09	235.11	217.31
24 - Jan -12	237.82	214.48	232.79	215.12
25 - Jan -12	237.30	219.12	232.66	216.93
26 - Jan -12	237.17	225.05	234.08	221.44
27 - Jan -12	238.46	217.18	232.79	215.77
28 - Jan -12	238.34	217.83	231.11	214.99
29 - Jan -12	237.56	219.64	233.43	215.25
30 - Jan -12	238.34	216.41	233.18	216.02
31 - Jan -12	238.46	216.93	231.24	214.61

17 VOLTAGE PROFILE OF 400 KV SUB-STATIONS IN DELHI DURING DECEMBER 2011
All figures in kV

Date	400kV Barnauli Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Jan -12	419.50	03.59.53	399.81	06.27.25	409.38
02- Jan -12	421.38	01.15.41	392.30	12.20.55	405.24
03- Jan -12	416.69	20.55.35	389.25	10.58.10	405.34
04- Jan -12	419.27	04.04.22	391.60	11.33.10	405.08
05- Jan -12	415.75	05.05.00	391.36	14.34.53	404.40
06 - Jan -12	420.91	23.46.40	389.25	09.49.20	404.16
07 - Jan -12	425.13	04.03.34	394.41	12.12.43	407.98
08 - Jan -12	421.61	02.10.29	398.63	09.14.12	409.70
09 - Jan -12	422.52	02.14.14	391.03	06.47.20	404.76
10 - Jan -12	--	--	--	--	--
11 - Jan -12	418.56	23.52.52	--	13.18.06	408.08
12 - Jan -12	425.13	04.04.28	398.40	10.54.52	406.34
13 - Jan -12	418.56	04.02.06	392.07	11.04.41	406.73
14 - Jan -12	420.67	03.06.42	390.89	11.13.34	408.14
15 - Jan -12	425.36	04.07.10	396.29	10.18.02	411.75
16 - Jan -12	431.46	04.01.48	395.58	16.46.05	412.82
17 - Jan -12	423.25	02.09.02	398.40	10.07.43	410.25
18 - Jan -12	425.36	04.04.03	395.12	12.06.12	409.41
19 - Jan -12	422.08	02.22.14	398.40	16.12.57	410.41
20 - Jan -12	421.61	02.08.26	392.07	10.30.18	407.13
21 - Jan -12	422.08	04.12.22	394.65	11.28.48	407.66
22- Jan -12	421.38	23.53.39	395.12	10.20.12	410.78
23 - Jan -12	426.07	04.03.03	398.40	10.18.33	410.62
24 - Jan -12	420.67	03.09.19	392.07	10.11.13	406.60
25 - Jan -12	419.27	02.10.18	392.30	10.00.57	406.03
26 - Jan -12	419.74	16.03.48	401.68	08.57.44	411.07
27 - Jan -12	419.03	04.04.19	390.89	10.17.50	404.53
28 - Jan -12	417.16	03.49.10	389.25	08.41.27	404.86
29 - Jan -12	419.74	09.59.03	388.78	12.20.02	407.08
30 - Jan -12	419.03	03.28.52	390.43	12.16.04	404.67
31 - Jan -12	416.69	04.02.19	388.78	12.28.29	402.68

Date	400kV Bawana Grid Sub-Station				
	Max KV	Max Time	Min KV	Min Time	Average KV
01-Jan -12	423.02	04.01.44	401.68	08.45.03	413.40
02- Jan -12	424.90	01.15.41	397.46	11.49.43	409.59
03- Jan -12	421.38	20.54.25	395.58	10.56.50	410.03
04- Jan -12	423.02	04.04.22	396.99	11.34.20	409.96
05- Jan -12	420.67	05.07.00	411.06	05.54.53	417.23
06 - Jan -12	426.07	23.46.40	398.40	14.50.38	409.93
07 - Jan -12	429.59	04.03.34	399.81	12.13.13	413.97
08 - Jan -12	425.60	04.06.25	403.79	09.40.14	414.73
09 - Jan -12	426.77	02.14.34	397.23	06.47.10	409.99
10 - Jan -12	--	--	--	--	--
11 - Jan -12	423.02	03.01.29	399.81	16.46.09	411.52
12 - Jan -12	425.13	04.05.58	400.51	10.55.02	409.45
13 - Jan -12	419.74	04.01.56	396.99	11.05.01	409.55
14 - Jan -12	420.91	03.02.51	394.88	11.13.34	410.51
15 - Jan -12	426.30	04.04.50	399.34	10.17.52	413.83
16 - Jan -12	433.10	04.02.08	398.40	16.45.55	415.65
17 - Jan -12	425.60	02.09.02	401.68	15.47.50	412.80
18 - Jan -12	427.24	04.04.23	398.40	12.05.52	411.93
19 - Jan -12	423.72	02.38.04	400.74	16.12.47	412.47
20 - Jan -12	423.72	04.03.55	379.40	17.35.57	409.56
21 - Jan -12	424.19	04.12.02	396.99	11.28.48	410.23
22 - Jan -12	422.79	23.53.29	397.23	10.21.42	412.62
23 - Jan -12	426.30	04.02.23	400.98	10.18.33	412.54
24 - Jan -12	422.55	03.09.19	395.82	10.10.43	410.20
25 - Jan -12	424.19	02.10.28	398.16	10.00.57	411.88
26 - Jan -12	425.36	16.04.08	407.31	08.56.24	416.35
27 - Jan -12	423.72	04.05.29	395.82	10.17.50	409.98
28 - Jan -12	421.61	03.49.10	395.12	08.42.27	410.27
29 - Jan -12	424.23	03.56.13	394.41	12.19.52	412.73
30 - Jan -12	423.96	03.09.21	396.99	10.10.04	410.42
31 - Jan -12	421.38	04.02.19	393.71	12.28.49	408.19

DETAILS OF LUMPED CAPACITORS AT NEAREST 220 KV SUBSTATION

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
1	IP YARD		30		30				30		30		
1	Kamla Market			16.35	16.35					16.35	16.35	8	
2	Minto Road												
3	GB Pant Hosp			15.88	15.88					10.48	10.48	5	
4	Delhi Gate			10.9	10.9					10.9	10.9	8	
5	Tilakmarg			5.04	5.04					5.04	5.04	12	
6	Electric Lane			5.04	5.04					5.04	5.04	19	
7	Cannaught Place			10.08	10.08					10.08	10.08	20	
8	Kilokri		10.08	10.48	20.56				0	5.03	5.03	4	
9	NDSE			5.03	5.03					5.03	5.03	6	
10	AIIMS		10	5.04	15.04				10	5.04	15.04	18	
11	Nizamuddin												
12	Exhibition-I		10		10				0		0	11	
13	Exhibition-II												
14	Defence Colony												
15	IG Stadium		10.08	5.45	15.53				0	5.45	5.45	4	
16	Lajpat Nagar												
17	IP Estate			10.9	10.9					5.45	5.45		
	Total				170.4	239	11	0	40	83.89	123.9	115	
2	IP Extn.												
1	School Lane			5.04	5.04					5.04	5.04	51	
2	Scindia House			5.04	5.04					5.04	5.04		
3	Vidyut Bhawan			10.08	10.08					10.08	10.08	52	
4	Nirman Bhawan			5.04	5.04					5.04	5.04	30	
5	Dalhousie Road			5.04	5.04					5.04	5.04		
	Total				30.24	129	12	0	0	30.24	30.24	133	
3	RPH Station		20	5.04	25.04				20	5.04	25.04		
1	Lahori Gate			10.49	10.49					10.49	10.49	7	
2	Jama Masjid			5.03	5.03					5.03	5.03	8	
4	Kamla Market												
5	Minto Road			10.9	10.9					10.9	10.9	6	
6	GB Pant Hosp												
7	IG Stadium												
	Total				51.46	100	30	0	20	31.46	51.46	21	
4	Parkstreet S/stn	20	20		40			20	20		40		
1	Shastri Park		10.89 6	5.45	16.35				10.89 6	5.45	16.35	47	
2	Faiz Road			10.9	10.9					10.9	10.9	12	
3	Motia Khan			16.3	16.3					16.3	16.3	11	
4	Prasad Nagar			16.25	16.25					16.25	16.25	11	
5	Anand Parbat			10.8	10.8					7.2	7.2	7	
6	Shankar Road			5.04	5.04					5.04	5.04	8	
7	Rama Road			14.4	14.4					7.2	7.2	3	
8	Baird Road			10.08	10.08					10.08	10.08	22	
9	Hanuman Road			5.04	5.04					0	0	11	
10	Pusa			7.2	7.2					7.2	7.2	7	
11	Ridge Valley											53	
12	SJ Airport			5.04	5.04					0	0	9	
13	B. D. Marg											11	
	Total				157.4	233	41	20	30.9	85.62	136.5	212	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
5	Naraina S/stn		20	5.04	25.04				20	0	20		
1	DMS			10.85	10.85					10.85	10.85	6	
2	Mayapuri		10.87	5	15.87				10.87	5	15.87	13	
3	Inderpuri		13.26	5.04	18.3				0	5.04	5.04	7	
4	Rewari line			7.2	7.2					7.2	7.2		
5	Khyber Lane			5.04	5.04					5.04	5.04		
6	Kirbi Place	10		5.97	15.97			10		5.97	15.97		
7	Payal			14.4	14.4					7.2	7.2	4	
	Total				112.7	140	21	10	30.87	46.3	87.17	30	
6	Mehrauli S/stn	80		5.04	85.04			60		5.04	65.04		
1	Adchini			15.12	15.12					10.08	10.08	9	
2	Andheria Bagh			10.85	10.85					10.85	10.85	7	
3	IIT			10.9	10.9					5.45	5.45	7	
4	JNU		10.03	10.08	20.11				10.03	5.04	15.07	23	
5	Bijwasan			10.08	10.08					5.04	5.04	6	
6	DC Saket		10.08	4.54	14.62				0	0	0	10	
7	Malviya Nagar												
8	C Dot			5.4	5.4					0	0	3	
9	Vasant kunj B-Blk	21.79		10.9	32.69			0		0	0	2	
10	Vasant kunj C-Blk	20.16		10.49	30.65			0		0	0	2	
11	Palam											12	
12	IGNOU											2	
13	R. K. Puram-I			10.08	10.08					10.08	10.08	6	
14	Vasant Vihar			15.12	15.12					15.12	15.12	8	
15	Pusp Vihar			9.6	9.6					9.6	9.6		
16	Bhikaji Cama Place		10	10.08	20.08				10	5.04	15.04	9	
	Total				290.3	213	32	60	20.03	81.34	161.4	106	
7	Vasantkunj S/stn	40		5.04	45.04			40		5.04	45.04		
1	R. K. Puram-II			7.2	7.2					0	0	4	
2	Vasant kunj C-Blk										0		
3	Vasant kunj D-Blk	20.16		10.25	30.41			0		0	0	1	
4	Race Course			5.04	5.04					5.04	5.04		
5	Bapu Dham			10.08	10.08					10.08	10.08	24	
6	Nehru Park			10	10					10	10	8	
7	Ridge Valley										0		
	Total				107.8	244	35	40	0	30.16	70.16	37	
8	Okhla S/stn	60	10	5.04	75.04			60	10	5.04	75.04		
1	Balaji			7.2	7.2					3.6	3.6	6	
2	East of Kailash			10	10					5	5	13	
3	Alaknanda			16.25	16.25					10.85	10.85	9	
4	Malviya Nagar	21.79	20.16	10.49	52.44			21.79	20.16	10.49	52.44	77	
5	Masjid Moth			15.94	15.94					5.04	5.04	7	
6	Nehru Place			21.35	21.35					21.35	21.35	20	
7	Okhla Ph-I	21.79		10.9	32.69			21.79		0	21.79	6	
8	Okhla Ph-II		20.93	15.53	36.46				10.9	15.53	26.43	13	
9	Shivalik			10.9	10.9					10.9	10.9	9	
10	Batra			15.8	15.8					15.8	15.8	5	
11	VSNL			10.8	10.8					0	0	7	
12	Siri Fort			10.49	10.49					5.04	5.04	9	
13	Tuglakabad			10.8	10.8					0	0	11	
	Total				326.2	360	52	103.6	41.06	108.6	253.3	192	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kv	TOTAL	MW	MVAR	66KV	33kv	11kv	TOTAL	MW	MVAR
9	Lodhi Road S/stn		20		20				20		20		
1	Defence Colony			10.9	10.9					5.45	5.45	13	
2	Hudco			10.9	10.9					0	0	7	
4	Lajpat Nagar			10.9	10.9					0	0	6	
5	Nizamuddin			10.49	10.49					10.49	10.49	10	
6	Vidyut Bhawan										0	6	
7	Kidwai Nagar			5.04	5.04					5.04	5.04	9	
8	Ex. Gr. II										0		
9	IHC										0		
	Total				68.23	157	61	0	20	20.98	40.98	51	
10	Sarita Vihar S/stn	20		5.04	25.04			20		5.04	25.04		
1	Sarita Vihar			10.08	10.08					10.08	10.08	13	
2	MCIE			10.06	10.06					0	0	4	
3	Mathura Road	20.16		10.08	30.24			20.16		5.04	25.2	3	
4	Jamia Millia			5.4	5.4					0	0	4	
5	Sarai Julena		10.08	10.9	20.98				10.08	10.9	20.98	14	
	Total				101.8	140	-3	40.16	10.08	31.06	81.3	38	
11	South of Wazirabad										0		
1	Bhagirathi		10.03	10.9	20.93				0	10.9	10.9	10	
2	Ghonda	21.79	22.56	15.94	60.29			0	0	15.94	15.94	20	
3	Seelam Pur		10.08	21.39	31.47				0	10.9	10.9	10	
4	Dwarkapuri			15.46	15.46					15.46	15.46	8	
5	Nandnagri	20.16		16.35	36.51			20.16		10.9	31.06	4	
6	Yamuna Vihar			10.8	10.8					1.8	1.8	5	
7	East of Loni Road			10.8	10.8					10.8	10.8	3	
8	Shastri Park			10.9	10.9					5.45	5.45	10	
9	Karawal Nagar			5.4	5.4					5.4	5.4	9	
	Total				202.6	214	64	20.16	0	87.55	107.7	79	
12	Geeta Colony										0		
1	Geeta Colony			10.49	10.49					10.49	10.49	12	
2	Kanti Nagar			10.9	10.9					10.9	10.9	8	
3	Kailash Nagar			15.48	15.48					5.45	5.45	12	
4	Seelam Pur										0		
5	Shakar Pur										0	6	
	Total				36.87	105	45	0	0	26.84	26.84	32	
13	Gazipur S/stn	40		5.04	45.04			40		5.04	45.04		
1	Dallupura	21.79		10.9	32.69			0		10.9	10.9	2	
2	Vivek Vihar			10.57	10.57					5.03	5.03	18	
3	GT Road			10.85	10.85					10.85	10.85	7	
4	Kondli	20.16		10.85	31.01			0		5.45	5.45	3	
5	MVR-I			10.9	10.9					0	0		
6	MVR-II	20.16		10.9	31.06			0		10.9	10.9		
7	PPG Ind. Area			10.06	10.06					0	0	2	
	Total				182.2	164	0	40	0	48.17	88.17	32	
14	Patparganj S/stn	40	20	5.04	65.04			40	10	5.04	55.04		
1	GH-I	19.89		10.45	30.34			0		10.45	10.45	2	
2	GH-II	20.09		10.9	30.99			0		0	0	3	
3	CBD		10.03	15.48	25.51				0	15.48	15.48	9	
4	Guru Angad Nagar			15.49	15.49					15.49	15.49	11	
5	Karkadooma		10.08	10.44	20.52				10.08	10.44	20.52	6	
6	Preet Vihar			10.07	10.07					5.04	5.04	9	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kV	TOTAL	MW	MVAR	66KV	33kv	11kV	TOTAL	MW	MVAR
7	CBD-II			7.2	7.2					0	0	4	
8	Shakarapur			5.4	5.4					3.6	3.6		
9	Jhilmil			9	9					0	0	5	
10	Dilshad Garden	20.16		16.35	36.51			0		0	0	4	
11	Khichripur	21.79		10.49	32.28			0		5.45	5.45	7	
12	Mother Dairy										0		
13	Scope Building										0		
14	Vivek Vihar										0		
15	Akhardham			14.4	14.4					0	0		
	Total				302.8	169	-25	40	20.08	70.99	131.1	60	
15	Najafgarh S/stn	60		5.04	65.04			60		5.04	65.04		
1	A4 Paschim Vihar			10.9	10.9					5.45	5.45	6	
2	Nangloi	21.73		15.85	37.58			21.73		10.85	32.58	39	
3	Nangloi W/W	20.89		5.45	26.34			20.89		5.45	26.34	3	
4	Pankha Road			15.69	15.69					15.69	15.69	6	
5	Jaffarpur			15.49	15.49					0	0	3	
7	Inst. Area Janakpuri			15.9	15.9					5.45	5.45		
8	Paschimpuri		10.05	15.53	25.58				0	5.04	5.04	9	
9	Paschim Vihar	41.83		15.44	57.27			20.1		15.44	35.54	36	
10	Mukherjee Park			15.49	15.49					15.49	15.49	11	
11	Udyog Nagar			10.04	10.04					0	0	8	
12	Choukhandi			10.08	10.08					0	0	7	
	Total				305.4	322	38	122.7	0	83.9	206.6	128	
16	Pappankalan-I S/stn	20		5.04	25.04			20		5.04	25.04		
1	Bindapur	21.73		15.9	37.63			0		5	5	6	
2	Bodella-I	20.1		15.9	36			20.1		15.9	36	6	
3	Bodella-II	21.73		14.53	36.26			0		14.53	14.53	6	
4	DC Janakpuri			10.04	10.04					10.04	10.04	8	
5	G-2 PPK			10.9	10.9					10.9	10.9	3	
6	G-5 PPK			15.53	15.53					15.53	15.53	6	
7	G-6 PPK			5.45	5.45					5.45	5.45	5	
8	G-15 PPK			10.08	10.08					10.08	10.08		
9	Harinagar	21.18		10.49	31.67			0		10.49	10.49	6	
	Total				218.6	334	38	40.1	0	103	143.1	46	
17	BBMB Rohtak Road										0		
1	S.B. Mill			10.08	10.08					0	0	3	
2	GTK Road				0						0		
3	Ram Pura			12.24	12.24					12.24	12.24	7	
4	Rohtak Road			10.08	10.08					5.04	5.04	2	
5	Vishal			5.4	5.4					5.4	5.4	13	
6	Madipur			10.43	10.43					5	5	7	
7	Sudershan Park			10.08	10.08					0	0		
	Total				58.31	151	15	0	0	27.68	27.68	32	
18	Shalimarbagh S/stn		40	6	46				30	6	36		
1	S.G.T. Nagar			13.15	13.15					0	0		
2	Wazirpur-1			20.7	20.7					20.7	20.7	11	
3	Wazirpur-2			14.4	14.4					7.2	7.2	6	
4	Shalimarbagh										0		
5	Ashok Vihar			20.35	20.35					20.35	20.35	11	
6	Rani Bagh			14.4	14.4					7.2	7.2	3	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kV	TOTAL	MW	MVAR	66KV	33kv	11kV	TOTAL	MW	MVAR
7	Haiderpur			13.15	13.15					13.15	13.15	6	
8	SMB FC			7.2	7.2					7.2	7.2		
9	SMB KHOSLA			7.2	7.2					7.2	7.2	4	
	Total				156.6	185	4	0	30	89	119	41	
19	Subzimandi S/stn			6	6					6	6		
1	Shakti Nagar			5.04	5.04					5.04	5.04	4	
2	Gulabibagh			7.2	7.2					7.2	7.2	4	
3	Shahzadabagh			19.44	19.44					19.44	19.44	10	
4	Tripolia			14.4	14.4					7.2	7.2	4	
5	B. G. Road										0	3	
	Total				52.08	105	17	0	0	44.88	44.88	25	
20	Narela S/stn	40		5.04	45.04			40		5.04	45.04		
1	A-7 Narela			14.4	14.4					14.4	14.4		
2	AIR Kham pur			13.15	13.15					0	0	7	
3	Badli	20		5.95	25.95			20		5.95	25.95	21	
4	DSIDC Narela	20		5.95	25.95			20		5.95	25.95	14	
5	DSIDC Narela-2			14.4	14.4					0	0		
6	Jahangirpuri	20	20	5.95	45.95			20	10	5.95	35.95	27	
	Total				184.8	203	-38	100	10	37.29	147.3	69	
21	Gopalpur S/stn		30	5.04	35.04				20	5.04	25.04		
1	Azad Pur			21.6	21.6					21.6	21.6	12	
2	Hudson Lane			5.95	5.95					5.95	5.95	4	
3	Wazirabad			7.2	7.2					7.2	7.2	3	
4	Indra Vihar			5.95	5.95					5.95	5.95		
5	Tri Nagar			14.4	14.4					7.2	7.2	3	
6	GTK Road			13.15	13.15					7.2	7.2	3	
7	Jahangirpuri				0						0		
8	Civil lines			6	6					6	6		
9	DIFR			7.2	7.2					7.2	7.2		
10	Delhi Univ.			7.2	7.2					7.2	7.2		
11	Tiggipur			14.4	14.4					14.4	14.4		
	Total				138.1	209	20				114.9	25	
22	Rohini S/stn	40		6	46			40		6	46		
1	Rohini Sec-24 Ckt-I			14.4	14.4					14.4	14.4	9	
2	Rohini Sec-24 Ckt-II	20		14.4	34.4			20		0	20	9	
3	Rohini-1			7.2	7.2					7.2	7.2	3	
4	Rohini-2			13.15	13.15					5.95	5.95	7	
5	Rohini-3			5.95	5.95					5.95	5.95	4	
6	Rohini-4			13.15	13.15					13.15	13.15	9	
7	Rohini-5			13.15	13.15					13.15	13.15	22	
8	Rohini-6	20		5.95	25.95			20		5.95	25.95	3	
9	Mangolpuri-1			20.35	20.35					5.95	5.95	3	
10	Mangolpuri-2	20		5.04	25.04			20		0	20	13	
11	Saraswati Garden			10.08	10.08					5.04	5.04	4	
12	Pitam Pura-1	20		12.24	32.24			20		5.04	25.04	14	
13	Pitam Pura-2			12.24	12.24					0	0	0	
14	Pitam Pura-3			7.2	7.2					7.2	7.2	4	
15	Rohini DC-1			14.4	14.4					14.4	14.4		
	Total				294.9	317	21				229.4	104	

Sl. No	SUB-STATION	INSTALLED CAPACITY IN MVAR				Load IN		WORKING CAPACITY IN MVAR				Lumped Load IN	
		66KV	33kv	11kV	TOTAL	MW	MVAR	66KV	33kv	11kV	TOTAL	MW	MVAR
23	Kanjhawala S/stn	20		5.04	25.04			20		5.04	25.04		
1	Bawana Clear Water			14.4	14.4					7.2	7.2	3	
2	Pooth Khoord			7.2	7.2					7.2	7.2	3	
3	Ghevra			14.4	14.4					14.4	14.4		
	Total				61.04	58	-13				53.84	6	
24	BAWANA S/stn												
1	Bawana S/stn No. 6				0						0		
2	Bawana S/stn No. 7				0						0		
	Total				0	47	20				0		
25	Kashmeregata S/stn			5.04	5.04					5.04	5.04		
1	Civil lines			6	6					6	6	9	
2	Town Hall			8.64	8.64					8.64	8.64	8	
3	Fountain			5.45	5.45					5.45	5.45	4	
	Total				25.13	50	7				25.13	21	
26	Pappankalan-II												
1	DMRC-I												
2	DMRC-II												
	Total					99	12						
	TOTAL CAPACITY				3636	4687	604				2502	1635	

20 DETAILS OF BREAK-DOWNS DURING THE MONTH OF JANUARY 2012

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
01	02.01.12	07.46	220KV BTPS – MEHRAULI CKT-I	02.01.12	15.17	CKT. TRIPPED ON `R` PHASE E/F AT BTPS AND ON DIST PROT `A` PHASE, 86 AT MEHRAULI. CKT. TRIED TO CLOSE AT 08.20HRS. BUT DID NOT HOLD AND AGAIN TRIPPED ON DIST PROT `A` PHASE ZONE-I AT MEHRAULI. LINE WAS PATROLLED AND NO FAULT OBSERVED. CKT. FINALLY CHARGED AT 15.17HRS.
02	05.01.12	00.58	VARIOUS TRIPPINGS IN DTL SYSTEM			DETAILED REPORT ENCLOSED
03	05.01.12	23.01	220KV PANIPAT – NARELA CKT-I	05.01.12	23.19	CKT. TRIPPED ON DIST PROT `ABC` PHASE ZONE-I AT NARELA. AUTO RECLOSE OPERATED AT PANIPAT
04	06.01.12	00.31	220KV PANIPAT – NARELA CKT-I	06.01.12	16.42	CKT. TRIPPED ON DIST PROT `ABC` PHASE ZONE-I AT NARELA. RELAY INDICATIONS AT PANIPAT END ARE NOT AVAILABLE.
05	06.01.12	00.59	220KV BTPS – MEHRAULI CKT-I & II	06.01.12	01.40	THE CKTS TRIPPED ON FOLLOWING INDICATIONS :- AT BTPS 220KV MEHRAULI CKT-I : 186, 30G, 30H, 30A, 86X1, 86X2 220KV MEHRAULI CKT-II : 186, 30G, 30C, 86X1, 86X2 AT MEHRAULI : 220KV BTPS CKT-I : DIST PROT `A` PHASE ZONE-I, 186, 86 220KV BTPS CKT-II : DIST PROT `ABC` PHASE ZONE-I, 186 CKT-I & II CHARGED AT 01.30HRS. AND 01.40HRS RESPECTIVELY FROM BTPS.
06	06.01.12	03.23	220KV BTPS – MEHRAULI CKT-II	06.01.12	20.48	CKT. TRIPPED ON 30G, 30B, 186, 86X1, 86X2 AT MEHRAULI. EARTH WIRE REPORTED TO BE BROKEN NEAR PLOT NO.162, SULTANPUR METRO STATION.
07	06.01.12	22.25	220/33KV 100MVA PR. TR.-II AT IP	06.01.12	02.50	TR. TRIPPED ON O/C `Y` PHASE AS `Y` PHASE CONDUCTOR OF BAY-14 (100MVA TR-II) AND JUMPER OF 33KV BAY-25 (IP - KILOKARI) SNAPPED
08	06.01.12	23.15	220/33KV 100MVA PR. TR.-III AT IP	07.01.12	02.15	TR. TRIPPED AS `Y` PHASE CONDUCTOR OF BAY-14 AND JUMPER OF 33KV BAY-25 SNAPPED
09	06.01.12	19.35	400KV BAWANA – MUNDKA CKT-I	06.01.12	20.50	CB-42052 OF 400KV BAWANA – MUNDKA CKT-I TRIPPED ON POLE DISCREPANCY AT MUNDKA. CKT. REMAINED CHARGED THROUGH CB-41952.
10	06.01.12	22.31	220KV MANDOLA – WAZIRABAD CKT-IV	07.01.12	16.33	CKT. TRIPPED ON DIST PROT `RYB` PHASE ZONE-III, SOTF AT WAZIRABAD AND ON DIST PROT ZONE-I AT MANDOLA.
11	06.01.12	22.35	220KV PRAGATI – SARITA VIHAR CKT.	07.01.12	02.33	CKT. TRIPPED ON POLE DISCREPANCY AT SARITA VIHAR END. CKT. TRIED TO CLOSE AT 23.45HRS. BUT DID NOT HOLD AND COULD BE CHARGED AT 02.30HRS. ON 07.01.2012
12	07.01.12	06.03	220KV BAMNAULI – NAJAFGARH CKT-I	07.01.12	06.45	CKT. TRIPPED ON POLE DISCREPANCY, 186A&B AT BAMNAULI. CKT. DID NOT TRIP AT NAJAFGARH.
13	07.01.12	07.04	400KV BAWANA – MUNDKA CKT-I	07.01.12	12.04	CB-42052 OF THE CKT. TRIPPED ON POLE DISCREPANCY AT MUNDKA END. CKT. REMAINED CHARGED THROUGH CB-41952
14	07.01.12	07.45	220KV BAMNAULI – NAJAFGARH CKT-I	07.01.12	12.14	CKT. TRIPPED ON POLE DISCREPANCY AT NAJAFGARH. NO TRIPPING AT BAMNAULI.
15	07.01.12	16.29	220/33KV 100MVA PR. TR -III AT SHALIMAR BAGH	07.01.12	18.40	TR. TRIPPED ON 86, 87, LVREF ALONG WITH 33KV I/C-III WHICH TRIPPED ON 86
16	10.01.12	07.52	220KV WAZIRABAD – GEETA COLONY CKT-II	10.01.12	08.10	CKT. TRIPPED PM 596X, 30E AT GEETA COLONY. NO TRIPPING AT WAZIRABAD. 220KV BUS BAR PROTECTION OPERATED ON 220KV BUS-II AT GEETA COLONY.

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
17	10.01.12	07.52	220KV GEETA COLONY – PATPARGANJ CKT-II	10.01.12	08.10	CKT. TRIPPED PM 396X, 30E AT GEETA COLONY. NO TRIPPING AT PATPARGANJ. 220KV BUS BAR PROTECTION OPERATED ON 220KV BUS-II AT GEETA COLONY.
18	10.01.12	07.52	220/33KV 100MVA PR. TR -II AT GEETA COLONY	10.01.12	08.10	TR. TRIPPED ON 796X, 30E ALONG WITH 33KV I/C-II WHICH TRIPPED ON INTER TRIPPING. 220KV BUS COUPLER ALSO TRIPPED ON 196XB, 30E. 220KV BUS BAR PROTECTION OPERATED ON 220KV BUS-II AT GEETA COLONY.
19	10.01.12	07.52	220KV MANDOLA – WAZIRABAD CKT-IV	10.01.12	08.13	CKT. TRIPPED ON SOTF AT WAZIRABAD. NO TRIPPING AT MANDOLA.
20	10.01.12	09.42	220KV BAWANA – ROHINI CKT-I	10.01.12	09.47	CKT. TRIPPED ON LOW AIR PRESSURE AT BAWANA. NO TRIPPING AT ROHINI.
21	15.01.12	13.36	220KV WAZIRABAD – KASHMIRI GATE CKT-I	15.01.12	14.47	CKT. TRIPPED ON DIST PROT 'RYB' PHASE ZONE-I AT WAZIRABAD. NO TRIPPING AT KASHMIRI GATE.
22	16.01.12	04.01	400KV JHAJJAR – MUNDKA CKT-I	16.01.12	07.30	BOTH CB TRIPPED ON 86A&B, PANEL-I DIRECT TRIP AT MUNDKA. RELAY INDICATION AT JHAJJAR END ARE NOT AVAILABLE. CKT. REMAINED UNCHARGED UPTO 07.30HRS. DUE TO HIGH VOLTAGE AND AS PER INSTRUCTION OF NRLDC. CKT CLOSED AT 07.30HRS.
23	16.01.12	04.44	66/11KV 20MVA PR. TR.- II AT PAPPANKALAN-I	17.01.12	18.40	TR. TRIPPED ON 86, 87BC, 64RLV, E/F ALONG WITH 11KV I/C-II WHICH TRIPPED WITHOUT INDICATION. CABLE END BOX BURNT AND LA DAMAGED.
24	16.01.12	04.54	220KV BAWANA – ROHINI CKT-II	16.01.12	18.26	CKT. TRIPPED ON DIST PROT 'B' PHASE AT BAWANA. NO TRIPPING AT ROHINI. CKT. TRIED TO CLOSE AT 05.12HRS. BUT DID NOT HOLD AND TRIPPED ON SOTF, 186A&B 'Y' PHASE LA BLAST AT 220KV ROHINI.
25	17.01.12	09.15	220KV KANJHAWALA – NAJAFGARH CKT.	17.01.11	19.19	CKT. TRIPPED ON DIST PROT 'ABC' PHASE ZONE-I. 186 AT NAJAFGARH. 220KV BUS COUPLER TRIPPED AT KANJHAWALA.
26	17.01.12	09.15	220KV BAWANA – NAJAFGARH CKT.	17.01.11	09.28	CKT. TRIPPED ON 186, 21XR1, 21XY1, 21XR2, 21XYZ, 21XB2 AT BAWANA AND ON DIST PROT 'ABC' PHASE ZONE-I AT NAJAFGARH.
27	18.01.12	05.16	220KV BAMNAULI – NARAINA CKT-I & II	18.01.11	06.22	BOTH CKT. TRIPPED ON A/R/L, 186A&B AT NARAINA. NO TRIPPING AT BAMNAULI. 220KV BUS DIFFERENTIAL OPERATED AT NARAINA. CKT-I & II CHARGED AT 06.40HRS. AND 06.22HRS. RESPECTIVELY.
28	18.01.12	05.16	220/33KV 100MVA PR. TR.-III AT NARAINA	18.01.12	06.26	TR. TRIPPED WITHOUT INDICATION. 220KV BUS DIFFERENTIAL OPERATED AT NARAINA.
29	18.01.12	05.56	220KV NARAINA – RIDGE VALLEY CKT.	18.01.12	06.42	CKT. TRIPPED WITHOUT INDICATION AT NARAINA. NO TRIPPING AT RIDGE VALLEY. 220KV BUS DIFFERENTIAL OPERATED AT NARAINA.
30	18.01.12	08.00	220KV GEETA COLONY – PATPARGANJ CKT-II	18.01.12	08.46	AT GEETA COLONY, CKT. TRIPPED ON DIST PROT. ZONE-II, 3-ΦTRIP. AT PATPARGANJ, CKT. TRIPPED ON ZONE-II, 3-ΦTRIP, 186
31	19.01.12	22.53	220KV BAMNAULI – NARAINA CKT-II	19.01.11	23.05	CKT. TRIPPED ON 96, 86B AT NARAINA DUE TO OPERATION OF BUS BAR PROTECTION AT NARAINA. NO TRIPPING AT BAMNAULI
32	19.01.12	22.53	220/33KV 100MVA PR. TR.-III AT NARAINA	19.01.12	23.05	TR. TRIPPED WITHOUT INDICATION DUE TO OPERATION OF BUS BAR PROTECTION AT NARAINA.
33	19.01.12	22.53	220KV NARAINA – RIDGE VALLEY CKT.	20.01.12	07.50	CKT. TRIPPED WITHOUT INDICATION AT NARAINA. DUE TO OPERATION OF BUS BAR PROTECTION AT NARAINA. NO TRIPPING AT RIDGE VALLEY.

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
34	20.01.12	11.22	220KV BTPS – NOIDA – GAZIPUR CKT.	20.01.12	14.25	CKT. TRIPPED ON E/F AT BTPS. NO TRIPPING AT GAZIPUR
35	20.01.12	14.48	220KV MAHARANI BAGH – PRAGATI CKT.	20.01.12	15.28	CKT. TRIPPED ON POLE DISCREPANCY 'R&Y' PHASE AT MAHARANI BAGH. NO TRIPPING AT PRAGATI.
36	20.01.12	17.35	400/220KV 315MVA ICT-II & II AT BAMNAULI.	20.01.12	19.46	ICT-II TRIPPED ON AUTO RECLOSE, 186A&B, TRIP GROUP-I, 86A-1, TRIP GROUP-B XB86-B-1 AND ICT-IV TRIPPED ON AUTO RECLOSE, 186A&B ALONG WITH 220KV I/C-II & IV WHICH TRIPPED ON INTER TRIPPING. BOTH ICT CHARGED AT 19.46HRS.
37	20.01.12	17.35	220KV BAMNAULI – PAPPANKALAN-II CKT-I & II	20.01.12	18.29	THE FOLLOWING TRIPPINGS OCCURRED :- AT BAMNAULI 220KV PAPPANKALAN-II CKT-I : NO TRIPPING. 220KV PAPPANKALAN-II CKT-II : DIST PROT 'A&B' PHASE AT PAPPANKALAN-II : 220KV BAMNAULI CKT-I : 86, DIST PROT. 220KV BAMNAULI CKT-II : NO TRIPPING CKT-I & II CHARGED AT 17.53HRS. AND 18.29HRS. RESPECTIVELY.
38	20.01.12	17.35	220KV BAMNAULI – NAJAFGARH CKT-I	20.01.12	11.55	CKT. TRIPPED ON DIST PROT 'A&B' PHASE AT BAMNAULI AND ON DIST PROT ZONE-I, 186 AT NAJAFGARH.
39	20.01.12	17.35	220KV BAMNAULI – NARAINA CKT-I & II	20.01.12	17.50	CKT-I TRIPPED ON DIRECTIONAL E/F, 67N, 186XYB AND CKT-II TRIPPED ON DIST PROT 86A, 86B, 86, 186X, 186B, AUTO RECLOSE AT NARAINA.
40	20.01.12	17.35	220KV BAMNAULI – PAPPANKALAN-I CKT-I & II	20.01.12	17.45	THE FOLLOWING TRIPPINGS OCCURRED : AT PAPPANKALAN-I : 220KV BAMNAULI CKT-I : DIRECTIONAL E/F, 67N, 186XA, 186XB, ABB, AUTO RECLOSE, D/P. VT FUSE FAIL 220KV BAMNAULI CKT-I : DIST PROT, 86A, 86B, AUTO RECLOSE, 186A&B, VT FUSE FAIL. NO TRIPPING AT BAMNAULI ON BOTH CIRCUITS. CKT.-I & II CHARGED AT 19.11HRS. AND 17.45HRS. RESPECTIVELY.
41	20.01.12	17.35	220/66KV 100MVA PR. TR.-I & II AT PAPPANKALAN-I	20.01.12	17.58	TR.-I TRIPPED ON PROTECTION GROUP-B, 86B, 51N, E/F, O/C AND TR.-II TRIPPED ON 51N, E/F, 86B, PROTECTION GROUP-B. 66KV I/C-II ALSO TRIPPED ON 86. BOTH TRANSFORMERS CHARGED AT 17.58HRS.
42	20.01.12	17.35	220KV BAMNAULI – DIAL CKT-I & II	22.01.12	11.03	THE FOLLOWING TRIPPINGS OCCURRED :- AT DIAL : 220KV BAMNAULI CKT-I : RLL FUSE FAIL, RED COMMUNICATION 52, CVT AVAILABLE. 220KV BAMNAULI CKT-II : BREAKER PROTECTION INDICATION, 52 CB TROUBLE ALARM, CVT AVAILABLE. NO TRIPPING AT BAMNAULI. DIAL LOAD CHANGED OVER TO MEHRAULI AT 17.40HRS.
43	20.01.12	17.35	220/66KV 100MVA PR. TR.-I AT PAPPANKALAN-II	20.01.12	18.29	TR. TRIPPED ON 86, O/C
44	20.01.12	17.35	220/66KV 160MVA PR. TR.-II AT RIDGE VALLEY	20.01.12	17.50	TR. TRIPPED ON 86A&B, GENERAL TRIP ALONG WITH 66KV I/C-II WHICH TRIPPED ON 86A&B
45	21.01.12	14.58	220KV MANDOLA – NARELA CKT-I & II	21.01.12	16.17	MAL OPERATION OF SPECIAL PROTECTION SCHEME AT MANDOLA. NO TRIPPING AT NARELA.
46	21.01.12	14.58	220KV MANDOLA – GOPALPUR CKT-II	21.01.12	16.09	MAL OPERATION OF SPECIAL PROTECTION SCHEME AT MANDOLA. NO TRIPPING AT GOPALPUR

SL NO	OCCURRENCE OF BREAK-DOWN		DETAILS OF THE BREAKDOWN	TIME OF RESTORATION		REMARKS
	DATE	TIME		DATE	TIME	
47	21.01.12	14.58	220/33KV 100MVA PR. TR.-I AT GOPALPUR	21.01.12	15.33	TR. TRIPPED WITHOUT INDICATION.
48	26.01.12	03.53	220/33KV 100MVA PR. TR.-I & II AT GEETA COLONY	26.01.12	04.08	TR.-I & II TRIPPED ON 86, 30E. 33KV I/C-I TRIPPED ON 30, O/C AND 33KV I/C-II TRIPPED ON 30, O/C, E/F.
49	26.01.12	23.34	66/11KV 20MVA PR. TR.-I AT VASANT KUNJ	29.01.12	05.47	TR. TRIPPED ON 86, 87, O/C, HV LV REF ALONG WITH 11KV I/C-I WHICH TRIPPED ON INTER TRIPPING.
50	31.01.12	12.19	220KV PANIPAT – NARELA CKT-I	31.01.12	12.28	CKT. TRIPPED ON DIST PROT `ABC` PHASE ZONE-I, 186 AT NARELA. NO TRIPPING AT PANIPAT.

20

DETAILS OF UNDER FREQUENCY RELAY OPERATIONS IN DELHI POWER SYSTEM DURING THE MONTH OF JANUARY 2012

DATE	S. N.	TIME		Name of Grid	NAME OF AFFECTED FEEDERS	LOAD RELIEF IN MW
		OUT	IN			
05.01.2012	1	06.58	07.50	RPH STATION	BAY NO. 1, 2, 5, 6, 13 & 18	23
	2	06:58	7:14	I.P.STATION	BAY NO. 37 (KILOKARI)	4
	3	7:40	7:47	I.P.STATION	BAY NO. 24 (DEFENCE COLONY)	0